

KYANCUTTA, Australia

WMO: 946570

Lat: 33.133S

Lon: 135.555E

Elev: 190

StdP: 14.60

Time Zone: 9.50 (AUA)

Period: 94-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.5	35.9	27.6	21.7	57.6	30.5	24.8	54.2	27.5	58.0	26.2	55.1	0.1	70	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	29.2	104.3	69.4	99.9	68.1	95.7	67.0	73.5	92.2	71.3	90.5	69.4	89.4	8.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.9	106.9	79.7	65.8	96.0	76.1	63.3	87.8	74.2	37.2	91.5	35.2	89.1	33.5	89.7	93.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.1	19.8	16.3	28.8	111.2	2.8	1.9	26.8	112.6	25.2	113.7	23.6	114.8	21.6	116.2		
(5)			28.6	79.5	2.8	6.9	26.6	84.5	25.0	88.5	23.4	92.4	21.4	97.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.6	74.9	75.4	68.4	62.4	57.4	53.3	52.1	52.7	57.5	61.0	66.6	71.1	(6)
(7)		DBStd	10.23	7.69	7.93	6.89	5.60	5.18	3.97	4.16	4.40	6.14	7.03	7.28	7.47	(7)
(8)		HDD50	59	0	0	0	0	1	12	24	20	2	0	0	0	(8)
(9)		HDD65	2041	6	5	35	116	247	353	399	382	242	172	63	21	(9)
(10)		CDD50	4676	773	710	569	372	230	110	90	104	227	340	498	653	(10)
(11)		CDD65	1181	314	295	139	38	12	1	0	1	16	46	111	208	(11)
(12)		CDH74	16561	4194	3920	1870	632	143	5	0	24	300	809	1754	2910	(12)
(13)		CDH80	8693	2422	2277	908	208	31	0	0	1	93	352	862	1539	(13)
(14)	Wind	WSAvg	5.6	6.8	6.1	5.1	4.1	4.0	4.9	4.7	4.9	6.2	6.6	6.6	6.8	(14)
(15)	Precipitation	PrecAvg	11.8	0.6	0.6	0.4	0.7	1.3	1.5	1.5	1.3	0.9	0.7	0.7	0.7	(15)
(16)		PrecMax	21.3	5.6	2.6	1.9	3.3	3.6	4.0	3.0	3.1	3.9	3.3	3.2	2.4	(16)
(17)		PrecMin	6.1	0.0	0.0	0.0	0.0	0.2	0.2	0.3	0.2	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	3.0	1.0	0.6	0.5	0.8	0.7	0.9	0.7	0.8	0.9	0.8	0.6	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	109.6	107.6	101.9	90.0	84.9	72.8	70.9	77.7	88.5	95.8	102.8	106.7	(19)
(20)			MCWB	71.4	71.8	68.2	65.8	61.0	60.9	55.2	57.3	61.9	63.8	67.9	69.2	(20)
(21)		2%	DB	104.1	103.9	95.4	85.2	78.1	67.5	67.2	71.7	81.7	89.6	95.6	100.5	(21)
(22)			MCWB	69.0	71.1	65.6	62.4	59.1	55.6	53.9	55.4	60.7	61.5	66.5	67.4	(22)
(23)		5%	DB	99.2	98.3	90.1	81.0	73.0	64.6	63.9	67.3	76.3	83.4	89.5	95.5	(23)
(24)			MCWB	68.1	69.4	64.5	61.0	57.9	54.6	53.3	54.2	58.3	59.8	63.7	65.6	(24)
(25)		10%	DB	93.6	93.6	84.5	76.6	68.5	61.9	61.0	63.3	71.3	77.7	84.8	89.0	(25)
(26)			MCWB	67.2	67.8	63.3	59.6	56.6	53.7	52.5	52.7	56.7	58.5	61.8	64.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.8	78.0	71.1	68.7	64.4	61.3	58.4	59.8	65.0	65.8	70.2	73.1	(27)
(28)			MCDWB	92.3	93.0	94.2	78.8	72.9	68.7	65.6	72.5	81.3	84.9	94.4	95.6	(28)
(29)		2%	WB	72.6	74.6	67.9	65.0	61.9	58.1	56.0	57.1	61.9	63.1	67.9	69.9	(29)
(30)			MCDWB	91.1	91.0	82.4	76.9	71.5	63.9	62.2	66.7	76.2	83.7	89.5	89.8	(30)
(31)		5%	WB	70.5	72.3	66.3	62.8	59.7	56.2	54.7	55.5	59.7	61.3	65.6	67.9	(31)
(32)			MCDWB	91.6	90.6	82.5	75.8	68.8	61.6	61.1	63.7	72.5	79.8	83.8	87.3	(32)
(33)		10%	WB	68.3	70.1	64.7	61.2	58.1	54.8	53.3	54.0	57.9	59.5	63.3	66.0	(33)
(34)			MCDWB	89.9	88.7	81.4	74.2	66.8	60.4	59.5	61.8	69.4	74.8	80.9	86.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	30.1	29.2	28.0	27.9	22.9	18.6	19.9	22.5	25.4	26.8	28.3	29.2	(35)
(36)			MCDBR	38.8	36.1	36.6	35.2	30.7	23.1	24.0	30.2	35.7	36.9	37.5	38.5	(36)
(37)			MCWBR	12.4	11.9	12.5	15.8	15.2	12.8	13.4	15.9	15.8	14.8	13.1	12.7	(37)
(38)		5% WB	MCDWB	31.6	28.4	29.4	28.7	23.0	17.7	19.8	24.3	29.4	32.1	32.1	31.2	(38)
(39)			MCWBR	11.1	11.1	11.5	13.5	12.5	10.9	12.4	14.1	14.2	14.1	12.7	12.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.342	0.325	0.316	0.310	0.296	0.295	0.303	0.332	0.343	0.345	0.335	(40)	
(41)		taud	2.505	2.527	2.558	2.567	2.557	2.585	2.581	2.544	2.455	2.427	2.456	2.513	(41)	
(42)		Ebn at Noon	315	309	304	290	274	271	277	290	296	305	313	319	(42)	
(43)		Edh at Noon	36	34	31	27	24	22	23	27	34	37	37	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2496	2228	1825	1349	970	823	887	1174	1588	2009	2298	2466	(44)	
(45)		RadStd	117	126	100	85	41	40	38	70	109	138	114	121	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page