

WOOMERA, Australia

WMO: 946590

Lat: 31.1558S

Lon: 136.8053E

Elev: 553

StdP: 14.40

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.5	41.3	3.3	6.7	84.7	10.4	9.5	78.5	27.8	60.9	25.9	61.4	7.3	110	0.560

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.4	106.1	65.8	102.6	64.7	99.5	64.2	72.7	87.3	70.4	88.0	68.5	88.2	12.9	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.4	110.3	76.7	65.7	96.7	76.0	62.3	85.6	75.3	36.7	87.5	34.7	88.1	33.0	87.5	96.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.8	23.8	21.5	35.8	111.1	1.4	2.6	34.8	112.9	33.9	114.5	33.2	115.9	32.2	117.8		
(5)			32.6	79.2	1.8	7.6	31.3	84.7	30.2	89.2	29.2	93.5	27.9	99.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.3	81.9	80.5	74.9	67.6	59.8	54.0	53.2	55.8	62.0	67.7	73.7	78.0	(6)
(7)		DBStd	11.93	7.84	7.73	7.11	6.12	5.21	3.84	3.90	5.00	6.49	7.60	8.16	7.99	(7)
(8)		HDD50	21	0	0	0	0	0	7	10	4	0	0	0	0	(8)
(9)		HDD65	1415	0	0	6	40	180	331	365	289	136	55	11	2	(9)
(10)		CDD50	6351	988	854	771	527	303	127	110	184	360	550	710	867	(10)
(11)		CDD65	2271	523	434	312	117	18	1	0	5	47	140	271	403	(11)
(12)		CDH74	30033	7498	5934	3635	1141	143	7	6	78	637	1838	3579	5537	(12)
(13)		CDH80	16515	4624	3508	1808	408	23	1	0	12	216	848	1892	3175	(13)
(14)	Wind	WSAvg	11.4	13.1	12.4	11.4	10.0	9.4	9.2	9.9	10.8	12.2	12.7	12.7	12.8	(14)
(15)	Precipitation	PrecAvg	7.2	0.6	0.7	0.3	0.5	0.7	0.6	0.5	0.6	0.6	0.7	0.6	0.6	(15)
(16)		PrecMax	19.4	3.7	4.8	1.8	2.7	4.7	3.0	2.2	2.8	3.4	3.2	5.2	3.4	(16)
(17)		PrecMin	2.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	3.5	0.7	1.1	0.4	0.7	0.9	0.6	0.5	0.5	0.7	0.7	0.8	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	111.3	109.2	102.1	94.5	83.4	73.6	73.7	81.0	92.5	99.5	105.6	109.1	(19)
(20)			MCWB	66.7	69.2	64.2	62.1	56.8	56.0	54.0	54.4	60.1	61.2	63.0	66.1	(20)
(21)		2%	DB	106.4	104.6	98.3	88.3	78.0	68.2	69.7	75.4	86.2	93.6	100.2	103.9	(21)
(22)			MCWB	66.3	66.2	63.8	59.7	56.7	53.7	52.2	52.7	56.1	59.4	62.7	63.9	(22)
(23)		5%	DB	102.7	100.5	93.7	84.6	73.8	64.9	65.9	71.3	81.2	89.5	95.2	99.5	(23)
(24)			MCWB	65.3	65.3	62.8	58.7	55.5	52.0	50.8	51.1	54.9	58.1	60.6	63.1	(24)
(25)		10%	DB	98.8	96.9	89.8	80.6	70.3	62.6	62.7	67.6	76.8	84.3	90.9	95.2	(25)
(26)			MCWB	64.7	64.6	61.8	57.8	54.2	51.7	49.7	50.2	53.5	56.7	59.7	62.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.6	76.1	72.0	67.4	61.7	60.4	58.4	58.6	63.8	67.1	69.8	73.0	(27)
(28)			MCD B	88.7	83.0	83.2	73.7	70.4	66.6	65.0	70.6	73.8	84.8	83.8	85.4	(28)
(29)		2%	WB	72.2	72.7	68.9	64.7	59.3	57.1	54.6	55.2	59.6	62.7	66.4	70.1	(29)
(30)			MCD B	87.3	90.2	85.1	74.6	71.0	63.9	64.0	68.1	76.2	83.4	81.9	85.3	(30)
(31)		5%	WB	70.0	70.1	66.2	62.0	57.5	54.9	52.6	53.3	57.2	60.6	64.6	67.3	(31)
(32)			MCD B	90.0	89.7	85.1	78.0	69.3	61.5	62.1	66.1	75.0	80.7	84.9	87.9	(32)
(33)		10%	WB	68.0	68.0	64.2	60.2	55.9	53.1	51.0	51.8	55.2	58.6	62.7	65.1	(33)
(34)			MCD B	91.5	88.9	84.9	76.5	67.3	60.0	60.3	63.8	72.7	79.7	84.6	88.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	25.4	24.0	22.6	21.0	19.1	17.3	19.0	20.9	23.2	24.4	24.5	25.2	(35)
(36)			MCDBR	29.3	27.7	26.8	26.3	22.8	20.6	23.5	26.0	30.2	30.7	29.7	29.5	(36)
(37)			MCWBR	9.9	8.7	8.9	10.1	10.0	10.3	11.5	11.3	12.3	11.8	10.2	10.0	(37)
(38)		5% WB	MCD BR	22.8	21.5	21.5	20.2	18.5	16.3	19.6	21.6	24.7	25.9	23.6	23.8	(38)
(39)			MCWBR	11.3	8.3	8.9	9.3	9.3	9.8	11.0	10.6	11.8	11.4	10.1	10.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.354	0.348	0.330	0.322	0.305	0.292	0.296	0.311	0.341	0.347	0.355	0.344	(40)	
(41)		taud	2.433	2.473	2.499	2.509	2.531	2.558	2.533	2.473	2.391	2.382	2.396	2.440	(41)	
(42)		Ebn at Noon	313	308	303	289	279	276	279	289	295	305	310	317	(42)	
(43)		Edh at Noon	39	36	33	30	26	23	25	30	36	39	40	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2504	2277	1940	1489	1123	959	1046	1352	1792	2138	2366	2522	(44)	
(45)		RadStd	121	123	113	69	59	49	40	56	87	108	102	98	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.81	N/A	N/A	+1.98	N/A	N/A	N/A	N/A	+284	+193	(46)
(47)	Regional (3 neighbors)	+0.79	N/A	N/A	+1.91	N/A	N/A	N/A	N/A	+284	+193	(47)

Nomenclature: See separate page