

ADELAIDE AP, Australia

WMO: 946720

Lat: 34.9525S

Lon: 138.5203E

Elev: 27

StdP: 14.68

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.0	41.0	22.7	17.1	78.1	26.9	20.8	75.2	28.6	54.1	25.9	54.7	3.6	50	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.2	98.2	65.4	93.4	64.2	89.5	63.5	71.0	82.7	69.3	82.1	67.7	81.5	13.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.8	102.2	75.4	65.0	92.7	74.8	62.8	85.6	73.6	34.9	82.4	33.5	81.8	32.1	81.5	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.5	22.9	20.8	DB	34.8	105.8	1.6	3.0	33.6	107.9	32.7	109.7	31.8	111.4	30.6	113.6	(4)
(5)			WB	34.0	74.2	1.7	1.8	32.8	75.5	31.8	76.6	30.9	77.6	29.6	78.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.0	72.5	72.1	68.0	62.8	57.7	53.3	52.1	53.2	56.9	60.9	65.7	68.8	(6)	
(7)		DBStd	9.23	7.35	7.16	6.70	5.42	4.49	3.70	3.51	4.01	5.16	6.51	7.43	7.34	(7)	
(8)		HDD50	44	0	0	0	0	1	11	19	12	1	0	0	0	(8)	
(9)		HDD65	2032	7	7	36	105	231	350	398	367	252	168	79	32	(9)	
(10)		CDD50	4408	698	619	557	385	240	111	85	110	209	338	472	584	(10)	
(11)		CDD65	923	240	206	128	40	6	0	0	1	10	41	100	151	(11)	
(12)		CDH74	9712	2544	2135	1249	357	32	0	0	7	96	484	1107	1701	(12)	
(13)		CDH80	4343	1257	985	530	99	3	0	0	1	15	165	472	816	(13)	
(14)	Wind	WSAvg	10.3	11.2	10.5	9.9	8.8	8.8	9.2	10.1	10.4	10.9	11.1	11.0	11.3	(14)	
(15)	Precipitation	PrecAvg	17.3	0.7	0.8	0.8	1.3	2.0	2.1	2.4	2.0	1.8	1.4	0.9	0.9	(15)	
(16)		PrecMax	28.7	2.4	4.1	4.4	6.3	4.9	5.4	4.6	4.1	4.5	3.5	3.7	3.5	(16)	
(17)		PrecMin	9.2	0.0	0.0	0.0	0.0	0.2	0.3	0.7	0.4	0.5	0.0	0.0	0.1	(17)	
(18)		PrecStd	4.2	0.6	0.9	0.9	1.1	1.0	1.1	1.0	0.9	0.9	1.0	0.7	0.7	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.4	100.8	97.1	88.6	77.4	68.8	66.9	73.6	82.2	90.8	97.0	101.9	(19)	
(20)			MCWB	66.3	68.0	63.8	61.4	57.4	56.3	53.5	55.2	58.3	59.2	63.2	65.3	(20)	
(21)		2%	DB	98.2	95.4	91.3	82.4	73.0	64.3	62.9	68.3	76.6	84.4	90.3	94.8	(21)	
(22)			MCWB	65.9	66.5	64.4	60.3	56.7	54.2	51.9	53.2	56.6	58.0	61.4	62.8	(22)	
(23)		5%	DB	91.9	91.0	86.1	77.7	68.8	62.1	60.7	64.3	71.6	79.1	85.7	89.3	(23)	
(24)			MCWB	64.9	65.4	63.3	58.8	56.5	54.1	51.8	52.3	54.7	57.2	60.9	62.4	(24)	
(25)		10%	DB	86.4	86.0	80.7	73.5	66.0	60.4	58.8	60.9	67.6	73.9	80.5	83.6	(25)	
(26)			MCWB	64.3	65.1	62.7	58.4	56.2	53.6	52.1	51.9	54.2	56.2	60.3	61.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.9	74.1	71.3	66.4	62.2	59.8	57.2	57.9	61.4	64.0	68.4	70.8	(27)	
(28)			MCD B	83.5	87.1	80.7	74.0	67.3	63.8	61.1	65.6	72.6	75.8	81.4	82.4	(28)	
(29)		2%	WB	70.8	71.2	68.9	64.0	60.3	57.3	55.4	55.8	59.0	61.8	66.0	68.2	(29)	
(30)			MCD B	83.5	83.0	79.9	72.6	65.9	61.2	58.9	62.4	69.8	73.1	79.1	81.0	(30)	
(31)		5%	WB	69.1	69.3	66.8	62.4	59.1	55.8	54.4	54.7	57.3	60.1	64.3	66.1	(31)	
(32)			MCD B	84.0	81.6	78.3	71.4	65.1	59.8	58.1	60.5	66.0	71.4	77.4	79.7	(32)	
(33)		10%	WB	67.1	67.6	64.7	60.7	57.6	54.7	53.1	53.4	55.8	58.5	62.3	64.2	(33)	
(34)			MCD B	82.8	81.3	77.8	70.3	64.0	58.9	57.2	58.9	63.7	69.3	76.6	77.9	(34)	
(35)	Mean Daily Temperature Range			MDBR	20.2	19.3	18.3	17.5	14.6	13.3	12.9	14.3	15.7	17.8	18.8	19.3	(35)
(36)		5% DB	MCD BR	29.0	26.6	26.5	24.8	19.3	15.9	15.7	21.1	24.8	28.3	28.5	29.6	(36)	
(37)			MCWBR	10.9	10.7	10.5	11.1	9.8	9.7	9.2	10.9	11.2	11.3	10.6	11.3	(37)	
(38)		5% WB	MCD BR	22.8	20.8	20.2	18.6	13.9	11.9	11.5	15.4	19.0	21.5	23.4	22.9	(38)	
(39)			MCWBR	11.4	11.1	11.1	10.8	8.8	8.5	8.3	9.9	10.5	10.5	10.5	11.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.345	0.344	0.326	0.319	0.309	0.301	0.300	0.311	0.335	0.346	0.348	0.340	(40)	
(41)		taud		2.536	2.555	2.598	2.599	2.608	2.614	2.607	2.559	2.489	2.462	2.488	2.534	(41)	
(42)		Ebn at Noon		314	308	302	286	272	266	272	285	294	304	311	317	(42)	
(43)		Edh at Noon		35	33	29	26	23	21	22	26	32	36	36	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg		2470	2164	1759	1276	874	718	780	1070	1470	1909	2255	2424	(44)	
(45)		RadStd		124	103	80	69	37	45	34	67	112	118	102	94	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.77	N/A	N/A	N/A	N/A	+1.15	N/A	-162	+284	+133
(47) Regional (25 neighbors)		+0.77	N/A	N/A	N/A	N/A	N/A	N/A	-176	+290	+126

Nomenclature: See separate page