

ADELAIDE AP, Australia

WMO: 946720

Lat: 34.9525S

Lon: 138.5203E

Elev: 8

StdP: 101.23

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	5.0	-5.2	2.4	25.6	-2.8	3.0	24.0	12.8	12.3	11.6	12.6	1.6	50	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.2	36.8	18.5	34.1	17.9	32.0	17.5	21.7	28.2	20.7	27.8	19.8	27.5	5.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	14.6	24.1	18.4	13.2	23.8	17.1	12.2	23.1	63.3	28.0	59.9	27.7	56.7	27.5	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	10.3	9.3	DB	1.6	41.0	0.9	1.7	0.9	42.2	0.4	43.2	-0.1	44.1	-0.8	45.3	(4)
(5)			WB	1.1	23.4	0.9	1.0	0.4	24.2	-0.1	24.8	-0.6	25.3	-1.3	26.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	22.5	22.3	20.0	17.1	14.3	11.8	11.2	11.8	13.9	16.1	18.7	20.5	(6)
(7)		DBStd	5.13	4.08	3.98	3.72	3.01	2.49	2.05	1.95	2.23	2.87	3.62	4.13	4.08	(7)
(8)		HDD10.0	24	0	0	0	0	1	6	11	7	1	0	0	0	(8)
(9)		HDD18.3	1129	4	4	20	58	128	194	221	204	140	93	44	18	(9)
(10)		CDD10.0	2449	388	344	309	214	133	62	47	61	116	188	262	324	(10)
(11)		CDD18.3	513	133	114	71	22	3	0	0	1	6	23	56	84	(11)
(12)		CDH23.3	5396	1413	1186	694	198	18	0	0	4	53	269	615	945	(12)
(13)		CDH26.7	2413	698	547	294	55	2	0	0	1	8	92	262	453	(13)
(14)	Wind	WSAvg	4.6	5.0	4.7	4.4	3.9	3.9	4.1	4.5	4.6	4.9	5.0	4.9	5.1	(14)
(15)	Precipitation	PrecAvg	440	19	20	21	34	52	54	60	51	45	36	24	24	(15)
(16)		PrecMax	730	62	103	112	159	125	138	118	104	114	90	95	90	(16)
(17)		PrecMin	234	1	0	0	0	5	7	18	9	12	1	1	2	(17)
(18)		PrecStd	106	14	24	22	29	26	28	26	23	24	25	18	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.2	38.2	36.1	31.4	25.2	20.5	19.4	23.1	27.9	32.7	36.1	38.8	(19)
(20)			MCWB	19.0	20.0	17.7	16.3	14.1	13.5	11.9	12.9	14.6	15.1	17.3	18.5	(20)
(21)		2%	DB	36.8	35.2	33.0	28.0	22.8	18.0	17.2	20.2	24.8	29.1	32.4	34.9	(21)
(22)			MCWB	18.8	19.1	18.0	15.7	13.7	12.4	11.0	11.8	13.7	14.5	16.3	17.1	(22)
(23)		5%	DB	33.3	32.8	30.0	25.4	20.4	16.7	15.9	18.0	22.0	26.2	29.8	31.8	(23)
(24)			MCWB	18.3	18.6	17.4	14.9	13.6	12.3	11.0	11.3	12.6	14.0	16.0	16.9	(24)
(25)		10%	DB	30.2	30.0	27.1	23.0	18.9	15.8	14.9	16.0	19.8	23.3	27.0	28.6	(25)
(26)			MCWB	18.0	18.4	17.1	14.6	13.5	12.0	11.2	11.0	12.3	13.4	15.7	16.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.7	23.4	21.8	19.1	16.8	15.4	14.0	14.4	16.3	17.8	20.2	21.5	(27)
(28)			MCDWB	28.6	30.6	27.1	23.3	19.6	17.7	16.2	18.7	22.5	24.3	27.4	28.0	(28)
(29)		2%	WB	21.6	21.8	20.5	17.8	15.7	14.1	13.0	13.2	15.0	16.6	18.9	20.1	(29)
(30)			MCDWB	28.6	28.4	26.6	22.6	18.8	16.2	14.9	16.9	21.0	22.9	26.2	27.2	(30)
(31)		5%	WB	20.6	20.7	19.3	16.9	15.0	13.2	12.4	12.6	14.1	15.6	18.0	19.0	(31)
(32)			MCDWB	28.9	27.5	25.7	21.9	18.4	15.4	14.5	15.8	18.9	21.9	25.2	26.5	(32)
(33)		10%	WB	19.5	19.8	18.2	16.0	14.2	12.6	11.7	11.9	13.2	14.7	16.8	17.9	(33)
(34)			MCDWB	28.2	27.4	25.4	21.3	17.8	14.9	14.0	14.9	17.6	20.7	24.8	25.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.2	10.7	10.1	9.7	8.1	7.4	7.2	8.0	8.7	9.9	10.5	10.7	(35)
(36)			MCDBR	16.1	14.8	14.7	13.8	10.7	8.8	8.7	11.7	13.8	15.7	15.8	16.4	(36)
(37)			MCWBR	6.1	5.9	5.8	6.1	5.4	5.4	5.1	6.0	6.2	6.3	5.9	6.3	(37)
(38)		5% WB	MCDWB	12.7	11.5	11.2	10.3	7.7	6.6	6.4	8.5	10.6	11.9	13.0	12.7	(38)
(39)			MCWBR	6.3	6.2	6.2	6.0	4.9	4.7	4.6	5.5	5.8	5.8	5.8	6.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.344	0.326	0.319	0.309	0.301	0.300	0.311	0.335	0.346	0.348	0.340	(40)	
(41)		taud	2.536	2.555	2.598	2.599	2.608	2.614	2.607	2.559	2.489	2.462	2.488	2.534	(41)	
(42)		Ebn at Noon	991	971	953	902	857	838	859	897	926	957	981	1000	(42)	
(43)		Edh at Noon	110	104	92	82	71	66	70	83	101	112	114	111	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.79	6.82	5.55	4.02	2.75	2.26	2.46	3.37	4.63	6.02	7.11	7.64	(44)	
(45)		RadStd	0.39	0.33	0.25	0.22	0.12	0.14	0.11	0.21	0.35	0.37	0.32	0.30	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.43	N/A	N/A	N/A	N/A	+0.64	N/A	-90	+158	+74
(47)	Regional (25 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	-98	+161	+70

Nomenclature: See separate page