

ADELAIDE KENT TOWN, Australia

WMO: 946750

Lat: 34.9211S

Lon: 138.6217E

Elev: 167

StdP: 14.61

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.2	42.2	23.3	17.7	77.6	27.5	21.6	72.3	19.0	56.8	17.4	56.9	1.5	50	0.427

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	100.6	66.5	96.5	65.5	92.3	64.7	71.2	86.7	69.4	86.0	67.7	85.3	9.3	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.2	100.6	76.5	64.3	90.9	74.7	61.6	82.4	73.7	35.1	87.2	33.6	85.1	32.1	85.0	85.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	15.9	14.2	36.3	107.7	1.4	3.4	35.3	110.2	34.4	112.2	33.6	114.1	32.5	116.6
			35.4	74.6	1.6	3.8	34.3	77.4	33.4	79.6	32.5	81.8	31.4	84.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.0	74.2	73.9	69.3	63.7	58.1	53.7	52.7	53.9	57.8	62.0	67.0	70.4	(6)
(7)		DBStd	9.90	8.32	8.18	7.32	5.75	4.56	3.56	3.53	4.27	5.40	6.88	8.08	8.18	(7)
(8)		HDD50	29	0	0	0	0	0	7	13	8	1	0	0	0	(8)
(9)		HDD65	1890	6	7	27	92	222	340	382	344	230	146	67	27	(9)
(10)		CDD50	4775	751	670	599	411	251	117	96	131	234	374	510	631	(10)
(11)		CDD65	1159	292	257	162	52	7	0	0	1	14	54	127	193	(11)
(12)		CDH74	13213	3474	2935	1691	448	33	0	0	9	116	627	1503	2377	(12)
(13)		CDH80	6377	1866	1505	755	129	3	0	0	1	18	221	671	1208	(13)
(14)	Wind	WSAvg	6.5	7.0	6.8	6.3	5.5	5.2	5.4	6.1	6.5	7.2	7.2	7.3	7.2	(14)
(15)	Precipitation	PrecAvg	21.7	0.8	0.6	1.0	1.5	2.4	3.3	3.0	2.8	2.5	1.9	1.2	1.0	(15)
(16)		PrecMax	28.2	1.7	2.5	4.2	4.2	5.0	6.9	6.3	5.1	5.9	4.1	4.2	2.9	(16)
(17)		PrecMin	14.1	0.0	0.0	0.0	0.0	0.3	1.2	0.9	0.8	0.6	0.2	0.0	0.2	(17)
(18)		PrecStd	3.7	0.5	0.6	1.0	1.2	1.3	1.4	1.3	1.3	1.2	1.1	0.9	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.1	103.4	99.5	90.3	78.0	69.6	67.6	74.7	82.5	92.1	99.2	104.0	(19)
(20)		MCWB	67.9	69.1	65.4	62.4	57.7	56.1	52.9	55.1	58.1	60.9	64.5	66.3	(20)	
(21)		2%	DB	100.8	98.5	93.0	83.3	73.3	64.6	63.8	69.4	77.2	86.0	92.9	97.8	(21)
(22)		MCWB	66.9	67.4	64.7	60.3	57.5	54.1	51.6	53.3	56.4	58.3	63.0	64.2	(22)	
(23)		5%	DB	95.6	94.0	88.2	78.9	69.3	62.3	61.2	65.5	72.9	80.9	87.4	92.1	(23)
(24)		MCWB	66.4	66.2	63.9	59.2	56.1	53.3	51.4	52.0	54.9	57.9	61.6	63.0	(24)	
(25)		10%	DB	90.1	89.3	83.3	75.0	66.2	60.2	59.1	62.0	68.9	76.0	82.8	86.7	(25)
(26)		MCWB	64.8	65.3	62.8	58.4	55.6	52.6	51.1	51.0	54.2	56.7	60.8	62.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.4	74.7	71.0	66.1	61.9	59.4	56.6	57.6	62.0	64.7	69.3	71.6	(27)
(28)		MADB	87.2	93.3	84.0	75.5	68.7	63.7	61.0	67.0	73.1	79.3	85.9	85.4	(28)	
(29)		2%	WB	71.1	71.3	68.6	63.8	60.0	56.7	54.9	55.6	59.0	62.1	66.3	68.4	(29)
(30)		MADB	87.5	87.3	82.5	74.1	66.8	61.0	58.8	63.6	71.3	75.7	83.7	85.0	(30)	
(31)		5%	WB	69.2	69.3	66.3	62.1	58.5	55.3	53.7	54.1	57.1	60.3	64.5	66.2	(31)
(32)		MADB	88.0	85.5	81.7	73.4	65.4	59.7	57.8	61.0	68.2	74.5	80.4	84.5	(32)	
(33)		10%	WB	67.2	67.3	64.3	60.4	57.2	54.1	52.6	52.9	55.5	58.4	62.4	64.1	(33)
(34)		MADB	87.0	84.7	80.5	71.4	64.1	58.5	56.9	59.3	65.1	71.7	79.4	81.7	(34)	
(35)	Mean Daily Temperature Range	MDBR	21.0	20.0	18.5	17.1	14.2	12.7	12.4	14.0	15.6	18.3	19.3	20.2	(35)	
(36)		5% DB	MADB	28.3	25.7	25.4	24.1	19.0	15.8	15.0	20.4	23.3	27.4	26.8	28.6	(36)
(37)		MCWBR	9.5	9.2	8.7	9.0	8.5	8.3	7.7	9.4	9.6	9.9	9.6	9.9	(37)	
(38)		5% WB	MADB	22.5	20.7	20.4	18.2	14.4	11.6	11.3	15.3	19.1	21.4	22.9	22.8	(38)
(39)		MCWBR	10.5	9.7	9.2	9.0	7.9	7.5	7.2	8.6	9.6	9.8	10.0	10.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.342	0.324	0.318	0.307	0.298	0.298	0.310	0.333	0.346	0.348	0.338	(40)	
(41)		taud	2.525	2.547	2.586	2.590	2.601	2.609	2.609	2.601	2.550	2.480	2.449	2.475	2.524	(41)
(42)		Ebn at Noon	315	309	303	287	272	267	273	285	294	304	312	318	(42)	
(43)		Edh at Noon	35	33	30	26	23	21	23	27	32	36	37	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2475	2172	1766	1280	877	722	784	1073	1473	1912	2258	2429	(44)	
(45)		RadStd	124	104	80	69	38	45	34	68	113	119	103	94	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.94	N/A	N/A	+2.47	N/A	N/A	N/A	-131	+310	+198
(47)	Regional (24 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	-176	+290	+126

Nomenclature: See separate page