

HINDMARSH ISLAND, Australia

WMO: 946770

Lat: 35.5194S

Lon: 138.8178E

Elev: 33

StdP: 14.68

Time Zone: 9.50 (AUA)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.6	43.5	30.2	24.3	73.6	33.3	27.9	64.3	33.0	55.4	30.4	55.5	8.4	10	0.620

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	95.2	64.7	90.0	64.1	84.4	63.2	69.3	82.4	67.8	79.8	66.4	77.7	15.8	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.5	94.4	73.7	63.9	89.1	72.5	62.6	85.0	71.0	33.5	82.9	32.2	79.7	31.1	77.9	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 30.1	27.3	24.8	37.1	105.9	1.6	4.5	36.0	109.1	35.0	111.7	34.1	114.2	32.9	117.4		
(5)			35.5	72.9	1.5	1.2	34.4	73.7	33.5	74.5	32.6	75.1	31.5	76.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.8	68.6	67.6	66.2	62.5	58.0	53.8	52.9	53.9	56.5	60.3	63.7	66.4	(6)
(7)		DBStd	7.54	6.28	5.56	5.86	5.07	3.78	3.24	3.18	3.67	4.47	6.02	6.54	6.30	(7)
(8)		HDD50	19	0	0	0	0	0	6	9	4	0	0	0	0	(8)
(9)		HDD65	2063	17	21	48	108	222	337	375	345	260	177	104	49	(9)
(10)		CDD50	3972	575	494	503	376	247	119	99	124	195	320	411	509	(10)
(11)		CDD65	539	127	96	86	33	4	0	0	0	5	32	64	92	(11)
(12)		CDH74	4582	1045	599	659	268	22	0	0	10	61	428	636	854	(12)
(13)		CDH80	2164	558	286	303	94	2	0	0	1	8	172	297	443	(13)
(14)	Wind	WSAvg	13.1	14.7	14.4	13.2	11.5	11.3	11.3	12.4	13.0	13.1	13.7	14.4	14.4	(14)
(15)	Precipitation	PrecAvg	18.2	0.7	0.8	0.7	1.5	1.9	2.4	2.5	2.4	1.9	1.6	1.1	0.8	(15)
(16)		PrecMax	26.9	3.2	4.2	3.2	4.2	4.3	6.9	6.0	4.6	4.4	4.0	4.3	2.7	(16)
(17)		PrecMin	10.7	0.0	0.0	0.0	0.0	0.4	0.7	0.7	0.9	0.6	0.2	0.1	0.1	(17)
(18)		PrecStd	3.2	0.7	1.0	0.7	1.1	0.9	1.3	1.1	0.8	0.9	1.0	0.8	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.1	97.3	96.2	89.8	77.3	68.1	67.2	74.7	80.4	91.9	95.8	100.1	(19)
MCWB			66.5	67.3	65.0	62.4	57.4	55.7	53.1	55.8	57.5	61.3	62.5	64.7	(20)	
2%		DB	94.6	89.0	88.5	81.5	71.3	63.3	62.8	68.3	74.7	85.0	88.3	91.9	(21)	
		MCWB	67.0	66.1	64.1	60.6	56.9	54.5	52.1	53.9	56.0	58.5	62.5	63.2	(22)	
5%		DB	85.7	80.7	81.1	75.4	67.5	61.1	60.5	64.0	69.7	77.9	81.5	83.5	(23)	
		MCWB	65.6	66.2	63.7	59.5	56.6	53.8	52.2	52.4	54.8	57.5	62.4	63.6	(24)	
10%		DB	77.9	74.7	74.7	70.6	64.4	59.4	58.7	60.7	65.3	71.4	74.5	75.9	(25)	
		MCWB	65.2	64.8	62.8	59.4	56.1	53.2	51.9	52.0	54.4	57.1	61.3	63.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.5	70.8	70.0	65.4	60.9	58.4	56.3	57.8	60.1	63.5	69.0	70.0	(27)
MCDWB			86.4	85.3	81.4	76.3	68.9	63.6	61.6	68.3	72.9	79.6	81.7	83.9	(28)	
2%		WB	69.4	68.5	67.7	63.5	59.3	56.3	54.7	55.7	58.1	61.3	65.8	67.4	(29)	
		MCDWB	84.0	79.8	79.2	73.2	66.1	61.1	59.6	64.1	69.1	75.3	79.3	79.2	(30)	
5%		WB	67.7	67.1	65.7	62.1	58.1	55.1	53.6	54.2	56.5	59.5	63.9	65.5	(31)	
		MCDWB	80.5	77.2	76.1	70.4	64.5	59.9	58.4	61.5	66.0	71.7	75.9	77.2	(32)	
10%		WB	65.9	65.8	64.3	60.8	57.0	53.9	52.5	52.9	55.1	58.1	62.1	63.9	(33)	
		MCDWB	77.6	74.7	72.8	68.3	63.1	58.5	57.5	59.3	63.5	68.7	72.7	74.5	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.1	12.8	13.9	14.5	12.0	11.0	10.8	12.4	14.4	16.2	15.2	15.1	(35)
MCDBR			31.6	26.6	28.2	24.7	18.0	14.0	14.1	19.9	24.5	30.8	29.9	31.8	(36)	
MCWBR			10.4	9.6	10.0	9.9	8.6	8.4	8.1	9.7	10.7	11.1	10.1	10.3	(37)	
5% WB		MCDWB	22.8	19.3	19.2	17.7	13.5	11.2	11.0	15.9	19.2	22.7	23.1	21.9	(38)	
		MCWBR	9.6	8.5	8.8	9.1	7.7	7.5	7.3	8.9	9.6	10.1	9.7	9.3	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.345	0.343	0.326	0.317	0.310	0.301	0.301	0.315	0.333	0.348	0.347	0.339	(40)	
taud		2.534	2.552	2.594	2.608	2.609	2.615	2.607	2.552	2.494	2.454	2.489	2.534	(41)		
Ebn at Noon		314	308	302	286	271	265	271	282	294	303	312	317	(42)		
Edh at Noon		35	33	29	25	23	21	22	26	32	36	36	35	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2431	2114	1709	1231	834	692	750	1040	1432	1865	2214	2394	(44)	
(45)		RadStd	123	109	74	73	36	45	34	59	110	113	94	95	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (23 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-178	+284	+119

Nomenclature: See separate page