

MT CRAWFORD, Australia

WMO: 946780

Lat: 34.7253S

Lon: 138.9280E

Elev: 1724

StdP: 13.80

Time Zone: 9.50 (AUA)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	37.7	39.1	22.0	17.6	73.9	25.8	21.0	69.9	32.5	48.0	30.0	46.8	12.9	100	0.670

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	95.5	63.0	91.2	61.9	87.3	61.0	67.5	80.8	65.7	80.6	64.0	79.6	13.2	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.4	96.7	69.5	61.6	87.4	68.3	59.2	79.9	66.5	32.9	80.2	31.4	80.6	30.1	79.7	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.8	25.0	22.7	DB	35.3	102.1	2.3	2.8	33.6	104.1	32.3	105.7	31.0	107.3	29.4	109.4	(4)
(5)			WB	34.2	70.9	2.4	2.7	32.4	72.9	31.0	74.5	29.6	76.0	27.9	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.2	68.2	67.6	63.6	58.8	52.8	48.0	47.0	48.0	51.4	55.6	61.3	64.7	(6)	
	DBStd	10.25	9.18	8.70	8.02	7.01	5.14	3.53	3.56	4.76	5.92	7.54	8.56	8.78	(7)	
	HDD50	388	2	0	0	5	24	80	108	99	47	21	2	0	(8)	
	HDD65	3462	65	65	129	213	380	511	558	528	410	309	177	117	(9)	
	CDD50	3015	567	494	421	270	111	19	15	36	90	196	340	456	(10)	
	CDD65	611	165	138	85	28	2	0	0	0	3	19	64	107	(11)	
	CDH74	7326	2236	1644	873	173	2	0	0	0	8	185	767	1438	(12)	
	CDH80	3185	1127	744	310	39	0	0	0	0	0	43	279	643	(13)	
(14) Wind	WSAvg	13.2	13.6	13.5	12.9	12.1	12.3	12.5	13.7	13.6	13.7	13.6	13.3	13.5	(14)	
(15) Precipitation	PrecAvg	21.1	0.9	0.9	0.9	1.5	2.1	2.8	2.9	2.5	2.5	1.6	1.2	1.3	(15)	
	PrecMax	33.3	2.3	4.2	4.7	4.5	4.3	5.3	5.8	5.7	6.4	5.1	3.4	4.6	(16)	
	PrecMin	12.3	0.0	0.0	0.1	0.2	0.3	0.7	0.8	0.5	0.7	0.0	0.2	0.2	(17)	
	PrecStd	4.6	0.6	1.0	0.9	1.1	1.0	1.3	1.1	1.3	1.3	1.1	0.8	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.2	98.1	93.0	85.0	71.8	62.7	60.4	66.9	74.8	85.5	92.4	98.5	(19)	
		MCWB	64.0	65.3	63.5	59.4	54.8	52.5	50.3	52.9	55.2	57.5	61.7	62.7	(20)	
	2%	DB	96.4	93.0	87.3	78.6	67.0	58.0	57.1	62.2	70.2	79.0	87.2	92.5	(21)	
		MCWB	63.5	63.3	61.2	56.9	53.4	50.8	48.8	50.6	53.8	56.3	60.5	60.8	(22)	
	5%	DB	91.2	88.9	83.2	74.3	63.9	55.2	54.6	58.6	66.3	74.5	82.5	86.9	(23)	
		MCWB	62.1	62.2	60.3	55.7	52.8	49.5	48.0	49.3	52.6	55.2	58.6	59.6	(24)	
	10%	DB	86.0	84.4	78.8	70.6	60.7	53.1	52.4	55.6	62.3	70.2	77.6	82.1	(25)	
		MCWB	61.0	61.7	59.0	54.9	51.5	48.7	47.4	48.1	51.0	54.0	57.9	58.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.7	71.1	67.2	62.7	58.0	55.6	53.7	54.8	58.7	62.9	66.1	67.2	(27)	
		MCDB	77.2	87.5	79.4	70.3	63.8	58.4	55.8	61.5	68.4	75.6	78.4	78.2	(28)	
	2%	WB	67.4	67.6	64.9	60.3	56.1	52.6	51.4	52.5	55.9	59.4	63.6	64.6	(29)	
		MCDB	82.3	80.5	77.9	69.4	61.4	55.3	54.0	58.9	65.6	71.2	78.3	80.3	(30)	
	5%	WB	65.4	65.5	62.9	58.5	54.7	51.2	49.9	50.8	53.9	57.2	61.9	62.4	(31)	
		MCDB	83.3	79.4	76.7	69.0	59.9	53.4	52.3	56.1	63.2	69.6	76.0	79.7	(32)	
	10%	WB	63.5	63.5	61.1	56.8	53.3	49.9	48.6	49.3	52.1	55.4	59.9	60.6	(33)	
		MCDB	81.4	78.7	74.8	67.1	58.4	52.0	50.9	53.8	60.2	66.4	73.1	76.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	23.4	21.9	18.9	14.8	9.6	7.7	7.8	9.5	12.9	17.0	20.4	21.8	(35)	
		MCDBR	28.2	26.4	23.5	19.4	12.8	9.9	10.4	13.3	18.9	23.8	26.0	27.7	(36)	
		MCWBR	8.9	9.1	8.3	7.5	6.3	6.5	6.4	7.9	9.2	10.1	9.9	9.9	(37)	
	5% WB	MCDBR	24.3	22.7	20.8	16.6	10.5	8.0	8.7	11.7	16.6	20.7	22.9	23.9	(38)	
		MCWBR	10.3	10.0	9.0	7.8	6.5	6.3	6.4	7.7	9.3	10.3	10.2	10.6	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.319	0.317	0.303	0.295	0.286	0.277	0.277	0.287	0.309	0.319	0.322	0.314	(40)	
	taud		2.544	2.571	2.601	2.606	2.617	2.628	2.619	2.570	2.498	2.476	2.502	2.548	(41)	
	Ebn at Noon		323	317	310	295	281	276	282	294	303	312	320	325	(42)	
	Edh at Noon		35	32	29	26	22	21	22	26	32	35	36	35	(43)	
(44) All-Sky Solar Radiation	RadAvg		2491	2198	1793	1299	895	738	798	1088	1488	1926	2268	2445	(44)	
	RadStd		124	106	83	69	39	45	33	71	117	122	107	92	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.77	N/A	N/A	N/A	N/A	N/A	-166	+283	+126	

Nomenclature: See separate page