

MILDURA, Australia

WMO: 946930

Lat: 34.2358S

Lon: 142.0867E

Elev: 173

StdP: 14.60

Time Zone: 8.00 (E08)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.9	36.3	16.7	12.9	79.7	21.9	16.6	77.2	20.9	58.9	19.0	58.7	3.7	200	0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.0	103.4	66.2	99.2	65.5	95.5	64.6	72.1	85.2	70.1	85.5	68.4	86.1	10.0	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.8	106.7	75.7	66.1	97.0	74.9	63.0	86.5	73.7	36.0	82.3	34.2	85.0	32.7	86.0	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	17.7	15.9	29.4	109.0	1.8	3.1	28.1	111.3	27.1	113.2	26.1	114.9	24.8	117.2
			29.2	74.6	1.7	2.0	28.0	76.0	27.0	77.1	26.0	78.2	24.8	79.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.8	77.1	76.1	69.4	61.7	55.6	51.1	49.6	52.3	57.5	62.1	68.8	72.6	(6)
	DBStd	11.33	7.61	7.65	6.96	6.10	5.13	4.47	3.82	4.91	6.12	6.76	7.92	7.34	(7)
	HDD50	130	0	0	0	0	7	37	54	28	4	0	0	0	(8)
	HDD65	2190	2	4	30	135	294	416	476	396	242	139	45	11	(9)
	CDD50	4787	840	731	601	353	181	71	43	98	228	376	564	701	(10)
	CDD65	1373	377	315	167	37	3	0	0	1	16	51	159	247	(11)
	CDH74	18724	5146	4050	2038	533	46	1	0	34	291	872	2262	3451	(12)
	CDH80	9657	2955	2235	931	153	2	0	0	3	87	346	1127	1818	(13)
(14) Wind	WSAvg	8.1	9.1	8.6	7.8	7.0	6.6	7.2	7.3	8.1	8.7	8.9	8.9	9.1	(14)
(15) Precipitation	PrecAvg	11.1	0.9	0.8	0.6	0.7	0.9	0.8	1.0	1.0	1.1	1.0	1.0	1.1	(15)
	PrecMax	24.2	5.0	7.2	5.0	4.7	2.8	3.2	2.3	3.0	3.7	4.8	4.3	7.1	(16)
	PrecMin	4.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	4.0	1.1	1.2	0.9	1.0	0.7	0.6	0.6	0.7	0.8	1.1	0.9	1.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	108.5	107.2	100.7	89.6	79.0	70.6	68.3	78.5	87.8	95.5	103.0	105.7	(19)
		MCWB	68.0	68.3	64.6	61.1	57.6	55.2	51.4	55.3	56.3	60.9	64.3	64.9	(20)
	2%	DB	104.1	101.6	94.4	84.5	74.4	65.9	64.1	71.9	82.0	88.4	96.8	99.7	(21)
		MCWB	67.1	67.4	64.3	60.4	57.0	53.8	51.2	52.8	56.2	58.3	63.0	64.5	(22)
	5%	DB	98.8	97.0	89.7	80.2	70.4	62.8	61.1	67.8	76.3	83.2	91.4	95.1	(23)
		MCWB	65.9	66.5	64.0	59.4	56.1	52.7	50.6	52.0	55.1	57.1	61.8	63.0	(24)
	10%	DB	94.4	92.9	85.0	76.0	66.5	60.3	58.6	64.1	71.6	78.0	86.4	90.3	(25)
		MCWB	65.3	65.5	62.6	58.1	54.9	51.7	49.8	50.7	53.8	56.2	60.2	62.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.1	75.5	70.7	65.7	61.7	59.2	55.4	58.1	62.3	65.1	69.7	71.1	(27)
		MCDB	88.6	90.0	85.2	75.7	70.5	62.9	61.6	70.2	72.7	79.0	80.3	83.4	(28)
	2%	WB	71.7	73.1	68.5	63.3	59.4	56.4	53.3	55.3	59.7	62.4	67.2	68.7	(29)
		MCDB	85.9	84.6	81.6	75.5	67.6	62.2	59.3	66.5	73.4	75.3	82.8	83.3	(30)
	5%	WB	69.7	71.0	66.2	61.5	57.7	54.4	52.1	53.2	57.4	60.3	65.1	66.5	(31)
		MCDB	87.8	84.9	80.6	75.0	66.2	60.6	57.9	64.1	71.9	75.5	83.6	85.5	(32)
	10%	WB	67.8	68.6	64.3	59.6	56.2	52.7	50.9	51.8	55.3	58.2	63.0	64.3	(33)
		MCDB	89.1	86.8	82.0	73.3	64.9	58.8	56.7	62.3	69.0	74.4	81.1	86.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	27.0	25.6	25.1	24.5	21.2	18.7	18.6	21.9	24.0	25.7	26.1	27.3	(35)
		MCDBR	32.1	30.9	30.7	30.0	25.7	21.3	21.9	27.7	31.2	33.3	32.7	33.6	(36)
	5% WB	MCWBR	10.3	10.1	10.7	12.1	11.6	11.3	11.6	12.8	12.0	12.0	10.9	11.4	(37)
		MCWBR	25.8	22.2	24.4	23.9	20.3	17.3	18.0	23.6	25.7	24.8	25.9	26.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.336	0.336	0.319	0.309	0.298	0.290	0.292	0.299	0.328	0.330	0.343	0.331	(40)
		taud	2.514	2.532	2.570	2.569	2.578	2.594	2.582	2.550	2.458	2.468	2.464	2.514	(41)
	Ebn at Noon		318	311	305	291	277	271	277	290	297	309	313	320	(42)
		Edh at Noon	36	34	30	27	23	22	23	27	33	36	37	36	(43)
(44) All-Sky Solar Radiation	RadAvg		2519	2258	1877	1383	974	792	858	1173	1599	2039	2294	2522	(44)
	RadStd		130	113	97	69	48	47	41	74	102	123	112	99	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-81	N/A	N/A	(46)
(47)	Regional (7 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+214	+142	(47)

Nomenclature: See separate page