

MILDURA, Australia

WMO: 946930

Lat: 34.2358S

Lon: 142.0867E

Elev: 53

StdP: 100.69

Time Zone: 8.00 (E08)

Period: 94-14

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 1.1	(c) 2.4	(d) -8.5	(e) 1.8	(f) 26.5	(g) -5.6	(h) 2.4	(i) 25.1	(j) 9.3	(k) 14.9	(l) 8.5	(m) 14.8	(n) 1.7	(o) 200	(p) 0.479

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 15.0	(c) 39.7	(d) 19.0	(e) 37.3	(f) 18.6	(g) 35.3	(h) 18.1	(i) 22.3	(j) 29.6	(k) 21.2	(l) 29.7	(m) 20.2	(n) 30.0	(o) 4.5	(p) 350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 20.5	(b) 15.2	(c) 24.3	(d) 19.0	(e) 13.9	(f) 23.8	(g) 17.2	(h) 12.4	(i) 23.2	(j) 65.9	(k) 27.9	(l) 61.6	(m) 29.5	(n) 58.2	(o) 30.0	(p) 26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.9	7.9	7.1	-1.4	42.8	1.0	1.7	-2.2	44.1	-2.7	45.1	-3.3	46.1	-4.0	47.3
			-1.6	23.6	0.9	1.1	-2.2	24.4	-2.8	25.1	-3.3	25.7	-4.0	26.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.1	25.1	24.5	20.8	16.5	13.1	10.6	9.8	11.3	14.1	16.7	20.4	22.6		
	DBStd	6.29	4.23	4.25	3.87	3.39	2.85	2.48	2.12	2.73	3.40	3.75	4.40	4.08		
	HDD10.0	72	0	0	0	0	4	21	30	16	2	0	0	0		
	HDD18.3	1217	1	2	17	75	163	231	264	220	134	77	25	6		
	CDD10.0	2659	467	406	334	196	101	39	24	54	127	209	313	389		
	CDD18.3	763	209	175	93	21	2	0	0	1	9	28	88	137		
	CDH23.3	10402	2859	2250	1132	296	26	1	0	19	162	484	1257	1917		
	CDH26.7	5365	1642	1242	517	85	1	0	0	2	48	192	626	1010		
(14) Wind	WSAvg	3.6	4.1	3.8	3.5	3.1	3.0	3.2	3.3	3.6	3.9	4.0	4.0	4.1		
(15) Precipitation	PrecAvg	282	24	20	16	19	23	21	25	26	27	26	26	28		
	PrecMax	615	127	183	128	120	70	82	59	75	94	121	110	181		
	PrecMin	122	0	0	0	0	0	0	1	1	0	0	0	0		
	PrecStd	102	27	31	22	26	18	16	16	17	21	29	22	36		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	42.5	41.8	38.2	32.0	26.1	21.4	20.2	25.8	31.0	35.3	39.5	40.9		
		MCWB	20.0	20.2	18.1	16.2	14.2	12.9	10.8	13.0	13.5	16.1	18.0	18.3		
	2%	DB	40.0	38.6	34.6	29.2	23.5	18.9	17.8	22.2	27.8	31.3	36.0	37.6		
		MCWB	19.5	19.6	18.0	15.8	13.9	12.1	10.6	11.6	13.4	14.6	17.2	18.1		
	5%	DB	37.1	36.1	32.1	26.8	21.3	17.1	16.2	19.9	24.6	28.5	33.0	35.0		
		MCWB	18.8	19.2	17.8	15.2	13.4	11.5	10.3	11.1	12.8	13.9	16.5	17.2		
	10%	DB	34.7	33.9	29.4	24.4	19.2	15.7	14.8	17.8	22.0	25.6	30.2	32.4		
		MCWB	18.5	18.6	17.0	14.5	12.7	11.0	9.9	10.4	12.1	13.4	15.7	16.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.4	24.2	21.5	18.7	16.5	15.1	13.0	14.5	16.8	18.4	20.9	21.7		
		MCDB	31.4	32.2	29.5	24.3	21.4	17.1	16.5	21.2	22.6	26.1	26.8	28.6		
	2%	WB	22.0	22.8	20.3	17.4	15.2	13.6	11.8	12.9	15.4	16.9	19.6	20.4		
		MCDB	29.9	29.2	27.6	24.1	19.8	16.8	15.2	19.1	23.0	24.1	28.2	28.5		
	5%	WB	21.0	21.7	19.0	16.4	14.3	12.4	11.1	11.8	14.1	15.7	18.4	19.1		
		MCDB	31.0	29.4	27.0	23.9	19.0	15.9	14.4	17.8	22.2	24.2	28.7	29.7		
	10%	WB	19.9	20.3	17.9	15.3	13.5	11.5	10.5	11.0	13.0	14.6	17.2	17.9		
		MCDB	31.7	30.5	27.8	23.0	18.3	14.9	13.7	16.8	20.6	23.6	27.3	30.2		
(35) Mean Daily Temperature Range	MDBR		15.0	14.2	14.0	13.6	11.8	10.4	10.3	12.2	13.3	14.3	14.5	15.2		
	5% DB	MCDBR	17.8	17.1	17.0	16.7	14.3	11.8	12.2	15.4	17.3	18.5	18.1	18.6		
		MCWBR	5.7	5.6	5.9	6.7	6.5	6.3	6.4	7.1	6.7	6.7	6.1	6.3		
	5% WB	MCDBR	14.3	12.3	13.6	13.3	11.3	9.6	10.0	13.1	14.3	13.8	14.4	14.6		
		MCWBR	5.8	4.6	5.9	6.1	5.7	5.6	5.9	6.7	6.6	6.3	5.8	6.1		
(40) Clear-Sky Solar Irradiance	taub		0.336	0.336	0.319	0.309	0.298	0.290	0.292	0.299	0.328	0.330	0.343	0.331		
	taud		2.514	2.532	2.570	2.569	2.578	2.594	2.582	2.550	2.458	2.468	2.464	2.514		
	Ebn at Noon		1001	980	962	916	872	854	872	913	935	975	987	1010		
	Edh at Noon		112	106	95	84	74	68	72	84	105	112	117	113		
(44) All-Sky Solar Radiation	RadAvg		7.94	7.12	5.92	4.36	3.07	2.50	2.71	3.70	5.04	6.43	7.23	7.95		
	RadStd		0.41	0.36	0.31	0.22	0.15	0.15	0.13	0.23	0.32	0.39	0.35	0.31		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-45	N/A	N/A
(47) Regional (7 neighbors)		+0.44	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+119	+79

Nomenclature: See separate page