

BOURKE, AustraliaWMO: **947030**Lat: **30.0361S**Lon: **145.9522E**Elev: **354**StdP: **14.51**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.8	36.3	16.8	13.0	68.1	19.8	15.0	67.8	18.8	62.2	16.9	61.0	3.6	170	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.6	106.9	68.3	103.6	67.5	100.6	67.1	75.5	87.9	73.6	86.1	72.1	86.5	10.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.7	122.6	79.4	70.3	112.8	78.2	68.3	105.3	77.1	39.2	87.4	37.5	85.3	36.0	85.9	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.3	17.4	15.7	DB	28.6	111.8	1.7	3.3	27.4	114.1	26.4	116.1	25.5	117.9	24.3	120.3	(4)
(5)			WB	27.0	78.1	1.9	2.9	25.7	80.2	24.6	81.9	23.6	83.5	22.2	85.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	69.0	85.6	83.8	77.8	69.3	59.6	53.8	52.2	55.3	63.1	70.3	76.4	81.6	(6)
(7)		DBStd	13.08	6.41	6.20	6.09	6.15	5.49	4.98	4.86	5.50	6.40	6.70	6.97	6.77	(7)
(8)		HDD50	56	0	0	0	0	2	17	28	9	0	0	0	0	(8)
(9)		HDD65	1395	0	0	1	29	181	337	398	307	113	25	4	0	(9)
(10)		CDD50	6987	1103	947	862	580	300	131	97	173	392	629	793	980	(10)
(11)		CDD65	2851	638	527	399	159	14	1	6	55	189	347	515		(11)
(12)		CDH74	38003	9239	7105	4512	1638	190	13	12	141	968	2492	4440	7253	(12)
(13)		CDH80	21292	5805	4234	2311	612	19	0	0	29	364	1162	2394	4362	(13)
(14)	Wind	WSAvg	8.0	9.3	9.1	8.3	7.3	6.6	6.7	6.5	7.3	8.0	8.6	8.8	9.3	(14)
(15)	Precipitation	PrecAvg	14.4	1.9	1.6	1.5	1.3	1.5	0.7	1.1	0.9	0.8	0.9	1.1	1.1	(15)
(16)		PrecMax	23.1	7.7	10.1	7.8	8.1	7.7	3.2	4.2	3.9	2.6	3.0	3.7	6.7	(16)
(17)		PrecMin	5.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	(17)
(18)		PrecStd	5.3	2.0	2.0	1.7	2.1	1.8	0.7	1.1	0.8	0.7	0.8	1.0	1.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	111.5	109.2	103.0	93.9	82.7	75.8	75.5	83.6	93.5	99.5	106.1	109.4	(19)
(20)			MCWB	69.8	70.0	68.2	64.4	60.5	58.8	56.0	57.4	60.6	63.2	66.5	67.3	(20)
(21)		2%	DB	107.5	105.2	98.6	89.8	78.9	71.2	71.6	77.8	88.3	95.0	101.3	104.2	(21)
(22)			MCWB	68.8	69.2	66.6	63.5	59.3	56.9	54.6	55.4	58.7	62.1	64.8	66.5	(22)
(23)		5%	DB	103.9	101.4	95.1	86.6	75.8	67.9	67.9	73.4	83.9	91.0	96.9	100.7	(23)
(24)			MCWB	68.1	68.2	66.1	62.3	58.2	55.2	53.5	53.8	57.5	61.1	64.0	66.2	(24)
(25)		10%	DB	100.3	98.1	91.5	83.4	72.4	64.8	64.5	69.5	79.5	86.7	92.4	97.5	(25)
(26)			MCWB	68.0	67.5	65.4	61.6	57.1	53.8	51.9	52.5	56.6	60.0	63.3	65.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.8	77.4	75.0	70.9	66.3	62.5	62.2	61.8	65.8	69.0	72.6	76.3	(27)
(28)			MCDWB	90.5	87.4	83.4	79.7	70.9	69.4	67.5	71.4	75.7	80.9	86.5	87.2	(28)
(29)		2%	WB	75.5	75.4	72.4	67.5	63.0	60.1	57.8	58.7	62.9	66.5	70.4	72.9	(29)
(30)			MCDWB	88.5	88.4	82.5	78.5	72.1	66.2	65.2	70.8	75.4	81.1	84.2	84.9	(30)
(31)		5%	WB	73.4	73.6	70.7	65.5	60.9	57.7	55.3	56.1	60.8	64.7	68.8	70.9	(31)
(32)			MCDWB	86.8	86.7	83.1	78.0	70.5	64.1	63.7	69.5	75.5	81.5	82.1	85.8	(32)
(33)		10%	WB	71.8	71.9	69.0	63.7	59.1	55.9	53.4	53.9	58.6	62.7	67.2	69.2	(33)
(34)			MCDWB	88.5	87.2	83.2	78.0	69.6	62.8	62.3	67.4	75.5	80.2	81.3	86.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	24.6	23.0	23.1	24.3	23.9	21.9	24.5	27.3	27.9	26.7	25.2	25.7	(35)
(36)			MCDBR	28.9	27.7	27.5	28.2	26.9	25.2	28.7	32.2	35.0	33.5	31.3	30.4	(36)
(37)			MCWBR	8.9	9.3	9.8	11.5	12.3	13.6	15.4	15.3	14.6	12.8	10.8	11.0	(37)
(38)		5% WB	MCDBR	21.5	20.5	20.2	20.9	20.3	19.0	21.9	25.7	25.6	24.7	22.5	23.2	(38)
(39)			MCWBR	8.1	7.5	8.3	9.4	10.5	11.1	13.1	13.2	12.1	11.2	8.5	9.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.349	0.328	0.310	0.293	0.288	0.284	0.297	0.335	0.337	0.353	0.344	(40)	
(41)		taud	2.521	2.548	2.598	2.605	2.608	2.624	2.614	2.549	2.437	2.458	2.463	2.511	(41)	
(42)		Ebn at Noon	314	309	305	296	286	281	287	296	298	309	311	317	(42)	
(43)		Edh at Noon	36	34	30	27	24	23	23	28	35	36	37	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2443	2218	1926	1556	1199	977	1114	1422	1819	2161	2327	2482	(44)	
(45)		RadStd	127	155	122	81	60	60	58	71	95	141	192	134	134	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page