

BOURKE, Australia

WMO: 947030

Lat: 30.0361S

Lon: 145.9522E

Elev: 108

StdP: 100.04

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.0	2.4	-8.5	1.9	20.1	-6.8	2.1	19.9	8.4	16.8	7.6	16.1	1.6	170	0.453

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.7	41.6	20.2	39.8	19.7	38.1	19.5	24.1	31.0	23.1	30.0	22.3	30.3	4.5	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.6	17.5	26.3	21.3	16.1	25.6	20.2	15.0	25.0	73.4	30.8	69.3	29.6	66.0	29.9	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.6	7.8	7.0	DB	-1.9	44.3	0.9	1.8	-2.6	45.6	-3.1	46.7	-3.6	47.7	-4.3	49.0
			WB	-2.8	25.6	1.0	1.6	-3.5	26.8	-4.1	27.7	-4.7	28.6	-5.4	29.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	29.8	28.8	25.5	20.7	15.3	12.1	11.2	12.9	17.3	21.3	24.7	27.6
	DBStd	7.27	3.56	3.44	3.38	3.42	3.05	2.77	2.70	3.06	3.55	3.72	3.87	3.76
	HDD10.0	31	0	0	0	0	1	9	16	5	0	0	0	0
	HDD18.3	775	0	0	1	16	101	187	221	171	63	14	2	0
	CDD10.0	3882	613	526	479	322	167	73	54	96	218	349	441	544
	CDD18.3	1584	354	293	222	88	8	1	1	3	31	105	193	286
	CDH23.3	21113	5133	3947	2507	910	106	7	7	78	538	1384	2467	4029
	CDH26.7	11829	3225	2352	1284	340	11	0	0	16	202	646	1330	2423
Wind	WSAvg	3.6	4.1	4.1	3.7	3.2	2.9	3.0	2.9	3.3	3.6	3.8	3.9	4.2
Precipitation	PrecAvg	366	49	41	38	32	39	18	27	24	20	24	27	27
	PrecMax	587	195	256	198	206	196	81	106	99	66	76	95	169
	PrecMin	133	1	1	0	0	0	0	0	1	0	2	0	0
	PrecStd	135	52	50	43	53	45	18	27	21	18	20	25	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	44.2	42.9	39.5	34.4	28.2	24.3	24.2	28.7	34.2	37.5	41.2	43.0
		MCWB	21.0	21.1	20.1	18.0	15.8	14.9	13.4	14.1	15.9	17.3	19.2	19.6
	2%	DB	41.9	40.6	37.0	32.1	26.1	21.8	22.0	25.4	31.3	35.0	38.5	40.1
		MCWB	20.5	20.6	19.2	17.5	15.2	13.8	12.5	13.0	14.8	16.7	18.2	19.2
	5%	DB	39.9	38.6	35.1	30.3	24.3	19.9	19.9	23.0	28.8	32.8	36.1	38.2
		MCWB	20.0	20.1	19.0	16.8	14.5	12.9	11.9	12.1	14.2	16.2	17.8	19.0
	10%	DB	37.9	36.7	33.1	28.6	22.5	18.2	18.0	20.8	26.4	30.4	33.6	36.4
		MCWB	20.0	19.7	18.6	16.4	13.9	12.1	11.0	11.4	13.7	15.5	17.4	18.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.5	25.2	23.9	21.6	19.1	16.9	16.8	16.6	18.8	20.6	22.5	24.6
		MCDB	32.5	30.8	28.5	26.5	21.6	20.8	19.7	21.9	24.3	27.2	30.3	30.7
	2%	WB	24.2	24.1	22.4	19.7	17.2	15.6	14.3	14.8	17.2	19.2	21.3	22.7
		MCDB	31.4	31.3	28.0	25.8	22.3	19.0	18.5	21.6	24.1	27.3	29.0	29.4
	5%	WB	23.0	23.1	21.5	18.6	16.1	14.3	13.0	13.4	16.0	18.1	20.5	21.6
		MCDB	30.4	30.4	28.4	25.6	21.4	17.8	17.6	20.8	24.2	27.5	27.9	29.9
	10%	WB	22.1	22.2	20.5	17.6	15.0	13.3	11.9	12.2	14.8	17.1	19.6	20.7
		MCDB	31.4	30.7	28.5	25.6	20.9	17.1	16.8	19.7	24.2	26.8	27.4	30.2
Mean Daily Temperature Range	5% DB	MDBR	13.7	12.8	12.8	13.5	13.3	12.2	13.6	15.2	15.5	14.8	14.0	14.3
		MCDBR	16.0	15.4	15.3	15.7	14.9	14.0	16.0	17.9	19.4	18.6	17.4	16.9
		MCWBR	5.0	5.2	5.4	6.4	6.8	7.6	8.5	8.5	8.1	7.1	6.0	6.1
	5% WB	MCDBR	11.9	11.4	11.2	11.6	11.3	10.5	12.2	14.3	14.2	13.7	12.5	12.9
	MCWBR	4.5	4.2	4.6	5.2	5.8	6.2	7.3	7.3	6.7	6.2	4.7	5.1	
Clear-Sky Solar Irradiance	taub	0.352	0.349	0.328	0.310	0.293	0.288	0.284	0.297	0.335	0.337	0.353	0.344	
	taud	2.521	2.548	2.598	2.605	2.608	2.624	2.614	2.549	2.437	2.458	2.463	2.511	
	Ebn at Noon	989	973	963	932	902	885	904	932	938	973	980	999	
	Edh at Noon	112	106	95	85	76	71	74	88	110	115	118	114	
All-Sky Solar Radiation	RadAvg	7.70	6.99	6.07	4.91	3.78	3.08	3.51	4.48	5.73	6.81	7.33	7.82	
	RadStd	0.40	0.49	0.39	0.26	0.19	0.19	0.18	0.22	0.30	0.44	0.60	0.42	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page