

GRIFFITH, Australia

WMO: 947050

Lat: 34.317S

Lon: 146.067E

Elev: 125

StdP: 99.83

Time Zone: 10.00 (AUS)

Period: 90-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) -0.4	(c) 0.9	(d) -3.8	(e) 2.8	(f) 18.5	(g) -2.2	(h) 3.2	(i) 15.4	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 13.6	(c) 37.3	(d) 19.2	(e) 35.2	(f) 19.2	(g) 33.4	(h) 18.8	(i) 23.3	(j) 28.5	(k) 22.0	(l) 28.4	(m) 21.0	(n) 28.3	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	17.0	25.1	20.3	15.2	24.1	19.0	14.0	23.5	70.0	28.3	65.0	27.7	61.3	28.2	35.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) N/A	(b) N/A	(c) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(4) N/A	(5) N/A	(6) N/A	(7) -2.2	(8) 26.8	(9) 0.8	(10) 4.2	(11) -2.8	(12) 29.8	(13) -3.3	(14) 32.3	(15) -3.7	(16) 34.7	(17) -4.3	(18) 37.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	23.5	24.0	20.4	16.1	12.9	10.2	9.1	9.9	12.5	15.7	18.9	22.1
	DBStd	6.23	3.72	3.99	3.61	3.36	2.99	2.68	2.32	2.82	3.31	3.59	4.18	4.35
	HDD10.0	127	0	0	0	1	7	29	44	37	9	1	0	0
	HDD18.3	1399	2	3	19	84	169	244	285	262	177	101	41	11
	CDD10.0	2407	420	392	323	184	97	36	18	33	85	178	268	374
	CDD18.3	637	164	162	84	17	1	0	0	1	3	19	59	127
	CDH23.3	7817	1932	1856	906	213	12	0	0	7	39	304	807	1740
	CDH26.7	3619	947	934	347	43	1	0	0	1	3	102	353	888
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(15) Precipitation	PrecAvg	407	37	26	30	33	41	35	36	39	37	38	30	30
	PrecMax	660	257	138	217	170	136	70	88	88	116	143	128	104
	PrecMin	178	0	0	0	0	2	0	1	3	6	5	0	0
	PrecStd	119	47	32	39	33	31	22	26	21	25	32	27	27
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.9	39.1	35.9	29.6	24.8	21.3	19.1	23.5	27.0	33.6	37.2	39.4
		MCWB	21.0	21.0	18.8	17.1	15.1	14.0	11.9	13.8	14.9	18.1	17.8	19.0
	2%	DB	36.6	36.4	32.4	28.0	22.9	19.0	17.1	19.6	24.4	29.5	33.8	36.8
		MCWB	20.4	20.1	18.8	16.4	14.6	13.2	11.8	12.6	14.8	15.9	17.1	18.5
	5%	DB	34.1	34.3	30.2	26.0	20.8	17.1	15.3	17.7	22.0	26.6	30.5	34.3
		MCWB	20.2	19.7	18.4	16.0	14.4	12.6	11.0	11.6	14.1	15.8	16.4	17.9
	10%	DB	31.8	32.3	28.3	23.8	18.9	15.3	14.1	16.1	19.7	24.2	28.0	31.9
		MCWB	19.1	19.6	17.8	15.2	13.6	11.7	10.7	10.9	13.1	14.9	15.9	17.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	29.9	25.2	24.0	19.7	18.1	15.6	14.1	15.8	17.8	24.6	20.7	23.3
		MCDB	30.9	29.4	25.7	25.1	20.1	18.4	15.9	19.4	22.1	25.0	27.1	28.3
	2%	WB	23.0	23.1	21.3	18.4	16.7	14.4	13.0	13.8	16.5	18.7	19.5	21.1
		MCDB	28.6	29.2	27.0	22.3	19.6	16.9	15.2	17.6	21.5	24.1	27.8	28.3
	5%	WB	21.9	22.0	19.9	17.2	15.5	13.3	11.8	12.6	15.3	17.1	18.3	19.9
		MCDB	27.9	30.0	27.0	22.9	18.9	16.3	14.7	16.6	19.7	23.9	26.8	29.3
	10%	WB	20.9	21.0	18.7	16.0	14.4	12.0	10.8	11.4	13.9	15.9	17.2	18.9
		MCDB	28.2	28.8	26.1	22.0	18.2	14.9	13.5	15.1	18.5	21.7	26.0	28.5
(35) Mean Daily Temperature Range	5% DB	MDBR	14.0	13.6	13.5	13.4	11.8	9.9	10.3	11.6	12.5	13.6	14.2	14.7
		MCDBR	16.7	15.9	15.6	16.3	14.3	12.2	12.1	14.2	15.2	17.1	17.9	17.6
		MCWBR	5.8	5.2	6.0	7.1	7.1	6.9	7.4	7.7	7.1	6.7	5.9	5.0
	5% WB	MCDBR	12.3	12.2	12.7	11.9	10.1	9.8	9.9	11.6	11.9	13.2	13.2	14.0
		MCWBR	5.5	5.7	6.4	6.1	6.2	6.2	6.8	7.0	6.6	7.1	5.8	5.5
(40) Clear-Sky Solar Irradiance	taub		0.339	0.340	0.319	0.308	0.297	0.289	0.285	0.293	0.322	0.326	0.343	0.336
	taud		2.505	2.526	2.570	2.568	2.567	2.592	2.597	2.557	2.459	2.478	2.469	2.498
	Ebn at Noon		997	975	961	917	873	855	879	920	941	978	987	1005
	Edh at Noon		113	107	95	84	74	68	71	84	104	111	117	115
(44) All-Sky Solar Radiation	RadAvg		7.82	6.92	5.84	4.35	3.16	2.47	2.72	3.67	5.10	6.42	7.19	7.90
	RadStd		0.45	0.37	0.33	0.19	0.16	0.18	0.16	0.27	0.35	0.41	0.48	0.30

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (10 neighbors)	+0.49	N/A	N/A	+1.28	+0.41	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page