

COBAR AP, Australia

WMO: 947100

Lat: 31.5389S

Lon: 145.7964E

Elev: 218

StdP: 98.73

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.1	0.3	-7.7	2.0	19.4	-6.1	2.3	17.4	9.1	15.7	8.2	14.6	0.4	60	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.6	40.2	19.6	38.4	19.2	36.7	18.7	23.0	30.1	22.1	30.0	21.3	30.1	5.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.6	16.7	24.7	20.3	15.3	24.2	19.0	14.2	24.0	69.5	30.1	65.9	29.3	62.9	29.9	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.1	7.3	DB	-3.5	42.9	1.2	2.1	-4.4	44.4	-5.1	45.7	-5.7	46.8	-6.6	48.4
			WB	-4.1	24.2	1.3	1.5	-5.0	25.2	-5.8	26.1	-6.5	26.9	-7.4	28.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	28.3	26.7	23.5	18.7	13.6	10.5	9.6	11.2	15.3	18.9	22.8	25.5	(6)
(7)		DBStd	7.39	4.00	3.95	3.82	3.84	3.44	3.02	2.87	3.44	3.99	4.20	4.39	3.99	(7)
(8)		HDD10.0	103	0	0	0	0	7	29	42	23	2	0	0	0	(8)
(9)		HDD18.3	1092	0	1	6	42	151	236	269	222	111	44	9	1	(9)
(10)		CDD10.0	3269	566	468	418	260	118	44	31	62	159	277	384	482	(10)
(11)		CDD18.3	1217	308	236	165	52	4	0	0	3	19	63	143	224	(11)
(12)		CDH23.3	16098	4372	3051	1860	568	43	1	0	32	295	854	1899	3122	(12)
(13)		CDH26.7	8530	2644	1715	859	176	1	0	0	5	83	346	966	1734	(13)
(14)	Wind	WSAvg	3.5	4.2	3.9	3.5	3.0	2.7	2.7	2.8	3.1	3.5	3.9	4.1	4.1	(14)
(15)	Precipitation	PrecAvg	407	42	42	36	26	34	31	29	28	25	35	36	36	(15)
(16)		PrecMax	764	234	189	218	201	144	112	101	76	107	105	160	152	(16)
(17)		PrecMin	102	0	0	0	0	0	0	0	0	0	0	0	1	(17)
(18)		PrecStd	171	53	48	40	37	31	26	26	22	27	26	38	38	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.1	42.1	37.5	33.2	26.4	22.6	22.0	27.1	31.7	35.2	40.0	40.8	(19)
(20)			MCWB	20.2	21.0	19.0	17.1	15.3	14.1	12.4	14.3	15.0	16.4	18.1	18.4	(20)
(21)		2%	DB	40.6	39.2	35.2	30.7	24.6	20.0	19.7	23.4	28.9	32.9	37.0	38.4	(21)
(22)			MCWB	19.9	19.9	18.7	16.8	14.6	12.9	11.7	12.5	14.2	15.9	17.7	18.3	(22)
(23)		5%	DB	38.8	37.0	33.3	28.6	22.8	18.2	17.8	21.0	26.7	30.6	34.5	36.5	(23)
(24)			MCWB	19.7	19.2	18.2	16.0	13.8	12.0	10.9	11.7	13.7	15.4	17.1	18.0	(24)
(25)		10%	DB	36.9	34.9	31.4	26.7	20.8	16.7	16.2	19.1	24.4	28.2	32.1	34.6	(25)
(26)			MCWB	19.4	19.2	18.0	15.5	13.2	11.5	10.3	10.8	13.0	14.9	16.5	17.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.2	24.2	23.9	20.6	18.3	15.9	15.6	15.9	17.8	19.2	21.4	23.0	(27)
(28)			MCD B	30.7	30.5	27.4	25.9	20.7	19.0	18.3	21.0	24.1	26.2	29.4	28.7	(28)
(29)		2%	WB	22.8	23.1	22.0	18.7	16.5	14.5	13.3	14.1	16.4	18.2	20.4	21.4	(29)
(30)			MCD B	31.3	30.6	27.0	24.0	20.5	17.2	16.5	20.6	22.9	25.6	28.0	28.7	(30)
(31)		5%	WB	21.9	22.2	20.8	17.6	15.2	13.5	12.1	12.6	15.2	17.1	19.6	20.4	(31)
(32)			MCD B	31.9	29.9	27.5	24.5	20.4	16.4	15.7	19.4	22.6	25.1	27.1	29.0	(32)
(33)		10%	WB	21.2	21.2	19.7	16.7	14.2	12.4	11.0	11.5	14.0	16.1	18.6	19.5	(33)
(34)			MCD B	31.9	29.6	27.5	24.5	19.5	15.8	15.4	18.0	22.5	26.0	27.2	29.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.6	12.8	13.1	13.7	13.1	11.8	12.6	14.1	14.7	14.5	14.1	14.4	(35)
(36)			MCD BR	15.5	15.3	14.8	15.4	14.6	13.5	14.3	15.8	17.0	16.9	16.7	16.4	(36)
(37)			MCWBR	5.2	5.3	5.6	6.5	7.1	7.6	8.0	7.8	7.5	6.6	6.0	5.9	(37)
(38)		5% WB	MCD BR	12.1	11.4	11.2	11.6	10.4	9.1	10.5	13.4	12.8	12.7	12.0	12.4	(38)
(39)			MCWBR	4.8	4.2	4.9	5.3	5.6	5.6	6.2	7.1	6.3	5.7	4.6	5.4	(39)
(40)																
(41)	Clear-Sky Solar Irradiance	taub	0.335	0.338	0.317	0.300	0.287	0.283	0.280	0.289	0.323	0.325	0.338	0.330	(41)	
(42)		taud	2.584	2.600	2.642	2.650	2.644	2.648	2.638	2.593	2.481	2.514	2.522	2.566	(42)	
(43)		Ebn at Noon	1004	983	972	938	903	883	903	936	947	984	994	1012	(43)	
		Edh at Noon	105	100	90	80	72	68	71	83	104	108	111	108		
(44)	All-Sky Solar Radiation	RadAvg	7.73	6.88	5.98	4.70	3.54	2.85	3.22	4.17	5.53	6.66	7.27	7.84	(44)	
(45)		RadStd	0.39	0.47	0.42	0.25	0.18	0.17	0.19	0.25	0.30	0.45	0.61	0.35	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page