

COBAR MO, Australia

WMO: 947110

Lat: 31.4839S

Lon: 145.8294E

Elev: 264

StdP: 98.20

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.8	3.9	-11.3	1.5	24.5	-8.9	1.8	24.6	8.3	15.1	7.4	14.2	2.2	200	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.7	40.1	18.9	38.2	18.5	36.5	18.2	22.5	29.1	21.6	29.1	20.8	29.5	4.5	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	16.2	24.3	19.7	14.9	23.9	18.4	13.7	23.6	67.9	29.2	64.2	28.2	61.3	29.3	33.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	7.4	6.6	DB	0.4	42.9	0.9	1.9	-0.3	44.3	-0.8	45.4	-1.3	46.5	-1.9	47.9	(4)
(5)			WB	-0.6	24.7	0.9	2.4	-1.3	26.4	-1.8	27.8	-2.3	29.1	-3.0	30.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.4	28.4	26.9	23.8	19.6	14.7	11.5	10.9	12.4	15.9	20.0	23.2	26.0	(6)	
	DBStd	7.01	3.85	3.85	3.62	3.63	3.10	2.65	2.53	3.16	3.81	4.13	4.36	3.98	(7)	
	HDD10.0	43	0	0	0	0	2	13	18	9	1	0	0	0	(8)	
	HDD18.3	909	0	0	4	28	120	204	232	188	94	31	8	1	(9)	
	CDD10.0	3474	570	474	428	289	146	59	45	83	178	309	397	497	(10)	
	CDD18.3	1298	312	241	173	67	6	0	0	3	22	81	154	239	(11)	
	CDH23.3	16019	4305	3021	1812	573	36	1	0	29	267	941	1898	3137	(12)	
(13)	CDH26.7	8332	2561	1664	814	171	1	0	0	4	72	377	948	1720	(13)	
(14)	Wind	WSAvg	3.3	3.7	3.6	3.3	3.1	2.7	2.9	3.0	3.2	3.5	3.7	3.6	3.8	(14)
(15) Precipitation	PrecAvg	407	42	42	36	26	34	31	29	28	25	35	36	36	(15)	
	PrecMax	764	234	189	218	201	144	112	101	76	107	105	160	152	(16)	
	PrecMin	102	0	0	0	0	0	0	0	0	0	0	0	1	(17)	
	PrecStd	171	53	48	40	37	31	26	26	22	27	26	38	38	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	43.0	41.8	37.5	33.1	26.3	22.5	21.9	27.0	31.6	35.2	39.9	41.2	(19)	
		MCWB	19.4	20.6	18.6	16.7	15.0	13.9	12.1	13.9	13.6	15.1	17.3	18.1	(20)	
	2%	DB	40.4	39.1	34.9	30.5	24.3	19.7	19.8	23.5	28.5	32.9	36.6	38.6	(21)	
		MCWB	19.4	19.3	18.1	16.6	14.1	12.5	11.2	11.8	13.0	15.0	16.9	17.7	(22)	
	5%	DB	38.4	36.9	32.9	28.5	22.5	18.0	17.8	21.0	26.3	30.8	34.3	36.5	(23)	
		MCWB	19.1	18.9	17.4	15.7	13.4	11.7	10.6	11.1	12.7	14.7	16.6	17.4	(24)	
	10%	DB	36.5	34.6	31.0	26.8	20.7	16.5	16.2	19.0	24.2	28.6	32.0	34.6	(25)	
		MCWB	18.8	18.6	17.4	15.2	12.8	11.1	9.7	10.2	12.0	14.3	16.4	17.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.6	24.0	22.4	19.6	17.8	15.4	16.1	15.7	16.5	19.1	21.1	22.5	(27)	
		MCDB	29.5	30.7	27.2	27.2	21.0	18.2	19.0	21.7	23.0	25.2	28.8	27.8	(28)	
	2%	WB	22.4	22.7	21.0	18.2	16.1	14.2	13.1	13.5	15.2	17.8	19.9	21.1	(29)	
		MCDB	29.4	29.8	28.3	24.1	20.4	16.9	16.5	20.1	22.0	25.3	27.8	27.9	(30)	
	5%	WB	21.4	21.7	20.0	17.2	14.9	13.1	11.7	12.0	14.1	16.6	19.1	20.2	(31)	
		MCDB	30.4	28.9	27.3	24.2	19.9	16.3	15.7	19.4	22.5	25.3	26.6	28.2	(32)	
	10%	WB	20.7	20.7	19.0	16.3	13.8	12.2	10.6	10.9	13.0	15.6	18.1	19.1	(33)	
		MCDB	31.0	29.1	26.8	24.6	19.0	15.5	15.0	17.9	22.4	25.4	26.7	28.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.7	11.9	11.8	11.7	10.5	9.3	10.1	11.5	12.6	12.9	12.8	13.1	(35)	
		MCDBR	14.5	14.1	13.7	13.1	12.1	11.0	11.9	13.6	15.2	15.2	15.1	14.9	(36)	
	5% WB	MCWBR	4.7	4.5	4.9	4.9	5.2	5.4	5.9	6.0	5.9	5.5	5.2	5.1	(37)	
		MCWBR	11.4	10.6	11.0	10.9	9.1	8.2	9.1	11.4	12.2	12.2	11.6	11.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.334	0.336	0.315	0.299	0.285	0.281	0.278	0.287	0.321	0.323	0.336	0.328	(40)	
		taud	2.588	2.603	2.647	2.654	2.648	2.652	2.643	2.598	2.485	2.518	2.528	2.571	(41)	
	Ebn at Noon		1006	984	974	940	906	885	905	939	950	986	997	1014	(42)	
		Edh at Noon	105	100	90	80	72	67	71	83	104	108	111	107	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.72	6.88	5.98	4.71	3.55	2.85	3.23	4.18	5.54	6.66	7.27	7.84	(44)	
	RadStd		0.39	0.48	0.42	0.26	0.18	0.17	0.19	0.25	0.30	0.45	0.61	0.36	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page