

MUDGE, Australia

WMO: 947270

Lat: 32.5628S

Lon: 149.6150E

Elev: 472

StdP: 95.79

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-2.6	-1.4	-5.4	2.5	10.8	-3.9	2.9	8.1	10.1	10.8	9.1	11.5	1.2	30	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.5	35.5	19.3	33.5	18.7	31.6	18.3	21.8	29.0	21.1	27.9	20.3	27.1	5.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	15.7	23.2	19.3	14.9	22.9	18.4	14.0	22.4	66.2	29.0	63.2	27.7	60.5	27.1	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	8.2	7.2	DB	-4.8	38.3	1.1	2.2	-5.5	39.9	-6.2	41.3	-6.8	42.5	-7.5	44.1	
			WB	-5.1	23.2	1.1	0.8	-5.9	23.8	-6.5	24.3	-7.1	24.8	-7.9	25.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	23.2	22.4	19.7	15.4	11.3	8.7	7.7	8.8	11.8	15.3	18.7	21.3
	DBStd	6.12	3.13	2.99	2.77	2.86	2.66	2.38	2.18	2.35	2.67	3.18	3.63	3.11
	HDD10.0	214	0	0	0	2	17	53	78	53	11	1	0	0
	HDD18.3	1594	2	3	17	92	218	289	329	297	196	104	38	9
	CDD10.0	2157	409	348	301	165	57	14	6	14	66	165	262	349
	CDD18.3	496	153	118	60	6	0	0	0	0	1	9	49	101
	CDH23.3	5674	1656	1139	594	105	1	0	0	1	35	238	695	1210
	CDH26.7	2356	792	490	188	14	0	0	0	0	3	60	289	521
Wind	WSAvg	3.1	3.5	3.4	3.1	2.7	2.6	2.7	2.8	3.0	3.2	3.2	3.4	3.4
Precipitation	PrecAvg	709	81	66	55	43	54	43	58	59	55	70	65	62
	PrecMax	1274	225	226	195	237	158	117	162	142	186	212	185	153
	PrecMin	302	4	3	0	0	2	2	3	0	2	0	3	0
	PrecStd	199	58	54	48	50	39	31	42	35	38	50	43	40
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.0	37.6	33.2	28.5	22.7	18.7	18.4	21.6	26.6	31.1	36.5	36.4
		MCWB	20.2	20.7	18.4	16.9	14.3	12.4	11.3	12.4	14.2	15.9	17.9	18.4
	2%	DB	35.7	34.4	30.8	26.1	21.0	16.7	16.3	19.3	24.0	28.3	33.0	33.8
		MCWB	19.8	19.6	18.4	15.7	13.9	11.6	10.5	11.4	13.6	15.1	17.0	18.5
	5%	DB	33.5	31.8	28.6	24.2	19.4	15.5	14.8	17.4	21.9	26.0	29.9	31.8
		MCWB	19.4	19.2	17.7	15.0	13.0	11.1	9.9	10.6	12.9	15.0	16.8	17.7
	10%	DB	31.2	29.6	26.6	22.5	17.8	14.3	13.5	15.6	19.7	23.7	27.2	29.7
		MCWB	18.9	18.8	17.4	14.6	12.3	10.6	9.3	9.8	12.2	14.4	16.2	17.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	23.0	21.8	18.7	16.7	14.3	14.2	14.2	16.5	18.6	20.7	21.6
		MCDB	31.0	30.8	27.4	23.6	19.5	15.9	15.7	18.6	22.9	24.8	28.3	28.3
	2%	WB	21.9	21.9	20.5	17.6	15.3	13.1	12.0	12.7	15.2	17.4	19.4	20.5
		MCDB	29.9	28.6	25.4	22.7	18.4	14.9	13.9	16.9	20.4	23.7	26.4	27.6
	5%	WB	21.1	21.0	19.6	16.5	14.1	12.2	10.8	11.6	14.1	16.5	18.6	19.7
		MCDB	28.8	27.1	24.7	21.9	17.8	14.5	13.4	16.0	19.2	22.5	25.3	26.9
	10%	WB	20.4	20.1	18.7	15.6	13.1	11.3	9.9	10.4	13.1	15.5	17.7	19.0
		MCDB	28.0	26.5	24.2	20.6	17.1	13.7	12.8	14.7	18.2	21.5	23.9	25.9
Mean Daily Temperature Range	5% DB	MDBR	13.5	12.6	12.7	13.8	13.3	11.5	12.2	13.7	14.7	14.5	14.0	14.2
		MCDBR	17.9	17.0	16.8	16.8	15.8	13.6	14.9	17.5	19.3	19.1	19.0	18.1
		MCWBR	5.3	5.3	6.3	7.4	8.9	8.7	9.4	10.1	9.7	8.3	6.8	5.9
	5% WB	MCDBR	13.4	12.8	12.4	13.2	11.9	10.6	11.3	14.4	14.6	14.4	14.0	13.8
	MCWBR	4.8	4.8	5.3	6.3	7.1	7.4	7.8	8.9	8.2	7.3	5.9	5.4	
Clear-Sky Solar Irradiance	taub	0.354	0.352	0.325	0.305	0.286	0.279	0.275	0.283	0.313	0.326	0.350	0.344	
	taud	2.503	2.532	2.589	2.609	2.620	2.644	2.644	2.603	2.504	2.498	2.476	2.519	
	Ebn at Noon	984	967	959	928	898	881	904	939	956	981	982	997	
	Edh at Noon	114	107	95	83	72	67	70	81	101	109	116	113	
All-Sky Solar Radiation	RadAvg	7.31	6.39	5.36	4.30	3.29	2.54	2.93	3.86	5.20	6.23	6.77	7.42	
	RadStd	0.41	0.52	0.46	0.33	0.20	0.21	0.19	0.26	0.35	0.54	0.66	0.51	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.69	N/A	N/A	+1.60	+0.63	+0.67	N/A	N/A	+151	N/A
(47)	Regional (32 neighbors)	+0.45	N/A	N/A	+0.98	N/A	N/A	-10	-87	+184	+95

Nomenclature: See separate page