

BATHURST, AustraliaWMO: **947290**Lat: **33.4119S**Lon: **149.6539E**Elev: **2444**StdP: **13.44**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.1	29.3	20.9	17.1	56.3	24.1	20.0	47.4	24.1	48.6	21.6	48.8	2.6	180	0.523

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.1	92.6	64.7	88.8	63.5	85.4	62.7	69.1	81.9	67.6	79.3	66.3	77.5	12.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.1	105.3	70.9	64.4	99.3	70.2	62.9	93.9	69.7	34.7	81.4	33.4	79.6	32.3	77.6	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
22.1	19.4	17.3	DB	23.0	97.6	2.0	4.3	21.5	100.7	20.3	103.2	19.2	105.6	17.7	108.7
			WB	22.6	71.7	2.0	1.5	21.2	72.8	20.0	73.7	18.9	74.6	17.4	75.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.2	70.3	68.4	63.7	56.3	49.1	44.9	43.2	45.1	50.5	55.8	61.8	66.5	(6)
	DBStd	10.72	5.97	5.70	5.11	5.23	4.79	4.19	3.74	4.17	5.09	5.89	6.65	6.05	(7)
	HDD50	694	0	0	0	11	75	162	214	162	54	14	2	0	(8)
	HDD65	3700	20	25	86	263	494	604	677	616	435	288	138	54	(9)
	CDD50	2965	629	515	424	201	46	8	2	11	69	195	355	510	(10)
	CDD65	496	184	120	44	3	0	0	0	0	0	4	42	99	(11)
	CDH74	6082	2088	1211	517	76	0	0	0	0	13	151	693	1333	(12)
	CDH80	2309	942	462	130	9	0	0	0	0	0	18	260	488	(13)
(14) Wind	WSAvg	7.4	8.1	7.8	7.1	6.2	6.2	6.7	7.1	7.6	7.9	7.7	8.0	8.1	(14)
(15) Precipitation	PrecAvg	25.7	3.0	2.5	2.0	1.7	1.9	1.4	1.9	2.2	1.9	2.5	2.4	2.5	(15)
	PrecMax	38.9	8.8	9.3	6.2	6.5	4.5	5.6	4.9	6.4	4.9	8.5	7.7	6.8	(16)
	PrecMin	8.4	0.0	0.0	0.0	0.0	0.3	0.0	0.2	0.1	0.3	0.1	0.3	0.0	(17)
	PrecStd	6.5	2.2	2.2	1.5	1.5	1.1	1.0	1.1	1.4	1.0	1.6	1.5	1.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.7	96.7	88.6	80.9	69.9	61.7	60.9	67.5	75.7	82.4	93.0	94.2	(19)
		MCWB	66.2	66.4	62.7	59.7	55.3	51.9	49.8	52.1	55.3	58.3	62.9	63.3	(20)
	2%	DB	93.5	90.0	83.6	75.7	66.1	58.4	57.1	62.7	71.4	78.2	87.2	89.1	(21)
		MCWB	65.3	64.9	62.5	57.7	53.8	50.6	47.9	49.9	53.9	57.2	60.3	63.0	(22)
	5%	DB	89.2	85.6	79.8	72.2	63.0	56.1	54.6	59.3	67.3	74.5	81.9	85.4	(23)
		MCWB	64.5	63.7	61.4	56.4	52.7	49.5	47.5	48.4	52.9	56.5	60.0	61.9	(24)
	10%	DB	85.4	81.4	76.0	68.8	60.1	53.9	52.1	56.0	63.4	70.4	76.9	81.7	(25)
		MCWB	63.7	63.6	60.9	55.5	51.8	48.7	46.3	47.3	51.4	55.6	59.3	61.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.0	71.4	69.6	63.4	60.0	55.3	54.6	55.3	59.5	63.5	67.0	68.6	(27)
		MCDB	85.1	85.5	76.9	71.5	63.3	57.7	56.7	61.5	68.2	72.5	79.3	80.4	(28)
	2%	WB	69.2	69.0	66.5	60.9	57.1	52.9	50.8	52.3	57.1	61.1	64.7	66.8	(29)
		MCDB	83.4	81.4	74.1	69.2	61.5	55.6	53.8	58.1	65.2	71.1	77.5	78.6	(30)
	5%	WB	67.8	67.3	64.7	59.1	54.8	51.0	48.6	50.2	55.1	59.2	63.0	65.3	(31)
		MCDB	80.7	78.3	73.2	67.8	60.6	54.5	52.4	56.9	62.9	68.7	75.2	77.1	(32)
	10%	WB	66.4	65.8	63.0	57.4	52.8	49.3	46.9	48.1	53.0	57.3	61.2	63.7	(33)
		MCDB	79.0	76.1	72.0	65.8	58.7	53.2	51.0	54.9	60.7	67.0	72.1	75.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	25.1	23.1	23.1	24.2	22.0	17.8	18.3	21.1	23.2	24.4	25.0	25.8	(35)
		MCDBR	32.4	30.2	29.5	29.6	26.8	22.0	23.6	27.8	30.4	31.6	33.8	31.7	(36)
	5% WB	MCWBR	10.4	10.4	12.0	13.4	15.4	14.4	15.4	16.1	15.6	14.5	12.6	11.0	(37)
		MCWBR	25.1	23.0	22.3	23.7	20.6	17.8	18.5	22.9	24.2	24.8	25.5	24.9	(38)
(40) Clear-Sky Solar Irradiance	taub		0.345	0.342	0.319	0.297	0.283	0.273	0.267	0.275	0.304	0.319	0.341	0.333	(40)
		taud	2.502	2.538	2.576	2.609	2.593	2.639	2.646	2.614	2.513	2.496	2.475	2.525	(41)
	Ebn at Noon		315	309	306	296	284	280	288	300	305	313	314	320	(42)
		Edh at Noon	36	34	30	26	23	21	22	25	31	35	37	36	(43)
(44) All-Sky Solar Radiation	RadAvg		2266	1950	1644	1310	991	755	867	1153	1589	1932	2092	2306	(44)
	RadStd		145	174	153	113	68	65	63	82	120	181	201	161	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (36 neighbors)	+1.12	N/A	N/A	+3.19	N/A	N/A	N/A	-232	+371	+191
		+0.79	N/A	N/A	+1.51	N/A	N/A	-4	-158	+340	+178

Nomenclature: See separate page