

MOUNT BOYCE, AustraliaWMO: **947430**Lat: **33.619S**Lon: **150.274E**Elev: **1080**StdP: **89.01**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.5	0.4	-7.3	2.3	11.3	-5.0	2.8	8.8	16.9	4.7	14.0	4.4	5.9	260	0.552

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.0	29.8	17.0	27.7	16.5	25.7	16.1	19.6	24.8	18.7	23.6	17.9	22.4	4.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	15.0	21.0	17.3	14.1	20.1	16.5	13.4	19.3	61.2	24.8	58.0	23.6	55.2	22.5	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	11.2	9.8	-2.2	33.1	0.7	2.0	-2.7	34.5	-3.1	35.7	-3.5	36.9	-4.0	38.4		
(5)			-3.1	21.7	0.7	1.2	-3.6	22.5	-4.0	23.2	-4.4	23.8	-4.8	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	18.3	17.6	15.6	12.6	9.4	6.7	5.7	6.8	9.7	12.3	14.7	16.7
	DBStd	5.42	3.90	3.57	3.13	3.01	2.87	2.63	2.15	2.78	3.43	3.83	4.17	3.87
	HDD10.0	473	0	1	1	9	44	103	134	107	47	20	7	2
	HDD18.3	2393	49	52	97	172	276	348	392	358	258	190	124	77
	CDD10.0	1259	258	213	173	88	27	5	1	7	39	91	147	210
	CDD18.3	137	49	31	11	1	0	0	0	0	0	3	15	28
	CDH23.3	1063	408	214	58	3	0	0	0	0	1	17	128	233
	CDH26.7	288	132	59	7	0	0	0	0	0	0	1	31	59
Wind	WSAvg	4.1	3.4	3.2	3.2	3.4	4.3	4.5	5.2	5.2	5.0	4.4	4.0	3.8
Precipitation	PrecAvg	1184	148	136	133	96	88	83	54	75	62	83	104	104
	PrecMax	1996	381	405	442	412	261	472	264	455	180	244	352	320
	PrecMin	666	35	14	8	4	3	1	0	4	7	7	15	0
	PrecStd	333	95	93	95	103	72	91	49	89	45	58	78	83
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.0	31.6	27.6	23.3	18.8	17.9	13.6	17.2	22.1	25.5	30.3	31.1
		MCWB	17.4	18.1	16.5	14.0	12.7	17.2	8.3	10.2	11.9	13.4	15.4	16.1
	2%	DB	30.3	28.2	24.9	20.7	16.7	13.3	11.8	14.8	19.5	23.1	26.8	28.3
		MCWB	17.7	17.4	16.0	13.3	11.6	9.9	7.7	8.6	10.7	12.5	14.6	16.0
	5%	DB	27.7	25.9	22.7	18.9	15.1	11.7	10.4	13.1	17.4	21.1	24.2	26.0
		MCWB	17.2	17.1	15.8	12.7	10.8	8.8	7.0	7.8	9.8	12.2	14.6	15.2
	10%	DB	25.3	23.7	20.7	17.3	13.7	10.4	9.2	11.4	15.7	19.1	21.9	23.8
		MCWB	16.6	16.9	15.1	12.1	10.3	8.2	6.5	6.9	9.4	11.5	13.9	14.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.0	21.3	19.6	16.2	14.7	17.2	10.5	11.5	13.4	16.7	18.3	19.3
		MCDB	26.7	25.9	23.1	19.9	17.1	18.1	11.9	15.3	18.5	20.1	23.5	24.9
	2%	WB	19.7	19.6	18.1	14.8	13.0	11.1	8.8	9.8	12.2	14.8	17.0	18.0
		MCDB	25.5	24.2	21.5	18.1	14.8	12.2	10.3	12.9	16.4	19.0	22.3	23.1
	5%	WB	18.9	18.6	17.0	14.0	11.8	9.6	7.8	8.7	11.2	13.6	16.0	17.1
		MCDB	24.4	23.2	20.1	16.8	14.0	10.7	9.3	11.6	15.4	18.0	21.3	22.1
	10%	WB	18.0	17.7	16.0	13.1	10.8	8.6	7.0	7.7	10.2	12.6	15.0	16.3
		MCDB	22.7	21.9	19.3	15.9	12.9	9.9	8.6	10.6	14.2	17.1	20.0	21.4
Mean Daily Temperature Range	5% DB	MDBR	10.0	8.9	8.2	7.8	6.6	5.5	6.1	7.5	8.7	9.5	9.7	10.3
		MCDBR	13.8	12.3	11.0	9.6	8.3	7.1	7.8	9.5	10.8	11.8	13.0	13.2
		MCWBR	5.7	5.2	5.2	4.4	4.3	4.3	4.7	5.0	5.0	5.4	5.4	5.4
	5% WB	MCDBR	11.6	10.2	9.3	8.1	6.4	5.4	6.0	8.3	9.2	10.1	10.9	11.2
	MCWBR	5.7	5.3	5.2	4.4	3.9	4.1	4.3	5.0	4.9	5.8	5.7	5.7	
Clear-Sky Solar Irradiance	taub	0.336	0.331	0.310	0.290	0.275	0.265	0.259	0.264	0.291	0.309	0.328	0.327	
	taud	2.528	2.566	2.604	2.636	2.632	2.676	2.681	2.669	2.569	2.535	2.515	2.540	
	Ebn at Noon	1001	986	973	941	906	894	919	959	978	998	1003	1014	
	Edh at Noon	111	103	92	79	70	63	66	75	94	105	112	110	
All-Sky Solar Radiation	RadAvg	6.56	5.58	4.78	3.89	3.09	2.42	2.81	3.71	4.97	5.79	6.13	6.75	
	RadStd	0.51	0.54	0.45	0.34	0.21	0.21	0.20	0.25	0.33	0.61	0.59	0.64	