

BELLAMBI, AustraliaWMO: **947490**Lat: **34.3692S**Lon: **150.9292E**Elev: **10**StdP: **101.20**Time Zone: **10.00 (AUS)**Period: **97-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	9.2	-3.1	2.9	14.9	-1.8	3.3	13.9	16.1	14.5	14.2	13.1	4.5	260	0.489

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.7	28.8	18.2	26.5	19.8	25.2	20.3	22.9	25.1	22.3	24.5	21.7	24.0	6.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	16.9	24.2	21.5	16.2	23.8	20.9	15.6	23.4	67.9	25.2	65.5	24.6	63.5	24.1	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
13.8	11.9	10.6	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			6.5	35.4	1.0	2.6	5.7	37.3	5.2	38.8	4.6	40.3	3.9	42.1
			3.2	24.0	0.8	0.9	2.6	24.6	2.1	25.1	1.6	25.6	1.1	26.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	21.6	21.7	20.9	18.8	16.4	14.3	13.5	14.1	15.9	17.4	18.6	20.4
	DBStd	3.56	1.96	1.90	1.93	2.13	2.07	1.72	1.73	2.04	2.55	2.77	2.39	2.20
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	655	1	1	3	19	67	120	149	133	83	51	24	5
	CDD10.0	2836	361	327	337	263	197	130	110	127	177	228	258	323
	CDD18.3	449	103	94	81	32	6	0	1	1	9	21	32	70
	CDH23.3	1047	239	218	136	47	4	0	1	2	43	102	84	169
	CDH26.7	206	46	22	16	5	0	0	0	0	9	36	26	47
(14) Wind	WSAvg	5.1	5.3	5.2	5.2	4.6	4.6	4.9	4.8	5.2	5.2	5.3	5.3	5.3
(15) Precipitation	PrecAvg	1289	136	137	150	114	104	111	57	89	61	99	122	95
	PrecMax	2033	483	454	494	612	344	539	255	784	206	390	791	365
	PrecMin	644	28	12	2	4	0	0	0	0	1	2	13	11
	PrecStd	404	105	113	108	128	100	114	55	139	52	92	130	85
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	31.6	29.1	28.4	27.1	23.9	20.8	21.3	23.0	27.6	30.9	30.2	32.1	32.1
	0.4% MCWB	19.4	20.6	20.0	17.4	15.1	13.9	12.7	13.0	14.6	15.9	17.0	16.9	16.9
	2% DB	26.7	26.5	25.7	24.5	22.0	19.3	19.0	20.4	23.9	25.9	25.3	26.9	26.9
	2% MCWB	21.6	21.7	21.0	18.4	15.6	14.0	12.2	12.6	13.9	15.5	17.8	18.8	18.8
	5% DB	25.2	25.4	24.6	23.2	20.8	18.3	17.9	18.8	21.5	23.0	23.2	24.6	24.6
	5% MCWB	21.4	21.6	20.4	18.2	15.5	13.3	12.0	12.7	14.0	15.6	18.7	20.0	20.0
	10% DB	24.4	24.6	23.8	22.1	19.8	17.4	16.8	17.7	19.7	21.2	21.9	23.5	23.5
	10% MCWB	21.1	21.1	20.2	18.0	15.2	12.9	11.5	12.5	14.5	16.2	18.3	19.8	19.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	23.9	23.7	23.0	21.1	18.9	16.7	15.6	16.2	17.9	19.3	21.2	23.1	23.1
	0.4% MCDB	25.5	26.2	25.0	24.1	20.5	19.2	18.5	18.7	21.3	22.6	23.7	24.8	24.8
	2% WB	22.7	23.0	22.1	20.1	17.9	15.3	14.4	15.2	16.9	18.5	20.3	21.7	21.7
	2% MCDB	24.9	25.3	24.3	22.7	20.0	17.8	17.0	18.0	19.8	21.5	22.7	24.0	24.0
	5% WB	22.2	22.4	21.4	19.4	16.9	14.7	13.5	14.2	16.2	18.0	19.6	21.0	21.0
	5% MCDB	24.4	24.6	23.7	22.0	19.7	17.1	16.1	17.3	19.2	21.0	21.9	23.3	23.3
	10% WB	21.6	21.7	20.9	18.7	15.9	14.0	12.7	13.4	15.5	17.3	18.9	20.3	20.3
	10% MCDB	23.8	23.9	23.2	21.3	19.1	16.6	15.6	16.6	18.7	20.2	21.2	22.7	22.7
(35) Mean Daily Temperature Range	MDBR	4.7	4.7	4.9	5.5	5.9	5.6	6.0	6.4	6.6	6.3	5.3	5.3	5.3
	5% DB MCDBR	6.3	6.0	6.1	6.7	6.9	6.7	7.5	7.9	9.8	10.3	8.2	8.1	8.1
	5% DB MCWBR	3.7	3.6	4.1	4.3	4.7	4.2	4.5	4.8	5.1	5.2	4.6	4.3	4.3
	5% WB MCDBR	5.1	5.0	5.2	5.6	5.7	5.2	5.7	6.1	6.9	6.9	6.0	5.7	5.7
(40) Clear-Sky Solar Irradiance	taub	0.400	0.392	0.364	0.337	0.318	0.310	0.301	0.309	0.343	0.360	0.387	0.404	0.404
	taud	2.435	2.480	2.539	2.587	2.590	2.610	2.618	2.587	2.494	2.476	2.437	2.400	2.400
	Ebn at Noon	937	924	914	885	849	831	862	903	920	944	943	937	937
	Edh at Noon	122	112	99	84	73	68	70	82	101	111	121	127	127
(44) All-Sky Solar Radiation	RadAvg	6.52	5.54	4.73	3.81	2.98	2.33	2.74	3.63	4.88	5.73	6.12	6.67	6.67
	RadStd	0.48	0.48	0.40	0.32	0.19	0.22	0.22	0.20	0.28	0.47	0.54	0.52	0.52

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (36 neighbors)	+0.43	N/A	N/A	N/A	N/A	-1	-85	+183	+94

Nomenclature: See separate page