

NULLO MOUNTAIN, Australia

WMO: 947540

Lat: 32.7244S

Lon: 150.2289E

Elev: 1130

StdP: 88.47

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.5	0.4	-7.2	2.3	9.8	-5.2	2.8	8.6	9.0	6.7	8.2	5.7	3.8	270	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.6	29.4	17.1	27.5	16.5	25.8	16.1	19.7	24.6	18.7	23.5	18.0	22.5	3.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	15.3	20.9	17.5	14.3	19.9	16.6	13.6	19.2	61.6	24.6	58.2	23.8	55.5	22.5	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.6	7.8	7.1	DB	-2.1	32.4	0.7	2.2	-2.6	33.9	-3.0	35.2	-3.4	36.5	-3.9	38.0
			WB	-3.2	21.5	0.7	1.9	-3.8	22.9	-4.2	24.1	-4.6	25.2	-5.2	26.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	18.6	17.7	15.6	12.4	9.1	6.4	5.6	6.7	9.7	12.2	14.6	17.0	(6)
(7)		DBStd	5.47	3.80	3.56	3.01	2.85	2.56	2.30	2.15	2.80	3.37	3.71	4.12	3.80	(7)
(8)		HDD10.0	484	0	0	1	9	47	109	137	109	46	19	6	1	(8)
(9)		HDD18.3	2414	44	51	96	177	287	357	394	361	259	192	126	71	(9)
(10)		CDD10.0	1254	266	215	174	82	19	2	1	7	37	88	145	219	(10)
(11)		CDD18.3	142	52	32	11	1	0	0	0	0	1	3	14	30	(11)
(12)		CDH23.3	1048	419	222	55	1	0	0	0	0	1	10	113	227	(12)
(13)		CDH26.7	256	120	58	7	0	0	0	0	0	0	0	25	46	(13)
(14)	Wind	WSAvg	3.7	3.9	4.0	3.8	3.4	3.4	3.7	3.7	3.7	3.8	3.8	3.7	(14)	
(15)	Precipitation	PrecAvg	730	79	81	56	47	43	55	53	45	57	58	77	76	(15)
(16)		PrecMax	1168	155	197	196	173	112	207	151	118	197	180	179	175	(16)
(17)		PrecMin	399	14	3	5	0	5	15	5	0	3	2	8	17	(17)
(18)		PrecStd	177	39	53	43	43	26	44	37	32	41	38	47	39	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	31.5	27.6	22.5	17.4	13.9	13.2	17.0	21.5	24.8	29.7	30.5	(19)
(20)			MCWB	18.2	18.2	15.7	14.1	11.4	9.7	8.9	10.3	11.6	12.9	15.5	15.9	(20)
(21)		2%	DB	29.7	28.2	24.7	20.3	15.5	12.2	11.4	14.6	19.2	22.3	26.3	27.9	(21)
(22)			MCWB	17.6	17.5	16.1	13.4	10.8	9.2	7.6	8.4	10.8	12.5	14.7	16.0	(22)
(23)		5%	DB	27.7	26.0	22.7	18.6	14.3	10.9	10.1	12.9	17.2	20.4	23.9	25.9	(23)
(24)			MCWB	17.3	17.0	15.6	12.5	10.4	8.5	7.1	7.9	9.9	12.1	14.7	15.4	(24)
(25)		10%	DB	25.6	23.9	20.9	17.0	13.1	9.8	9.1	11.3	15.6	18.6	21.7	24.0	(25)
(26)			MCWB	16.9	16.6	15.1	12.1	10.0	7.9	6.6	7.1	9.4	11.5	13.7	15.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.0	21.2	19.7	16.2	13.6	11.4	10.9	11.5	13.5	15.9	18.2	19.5	(27)
(28)			MCD B	23.4	26.6	22.6	19.0	14.7	12.2	11.7	14.5	18.2	19.8	23.3	24.3	(28)
(29)		2%	WB	19.9	19.5	18.1	14.8	12.5	10.2	9.2	10.0	12.2	14.6	17.0	18.2	(29)
(30)			MCD B	25.4	24.2	20.8	17.8	14.1	11.2	9.9	12.4	16.5	18.6	21.7	23.3	(30)
(31)		5%	WB	18.9	18.5	17.1	13.9	11.4	9.2	8.0	8.9	11.2	13.7	16.0	17.2	(31)
(32)			MCD B	24.4	22.9	19.7	16.8	13.2	10.3	9.3	11.8	15.2	17.5	20.8	22.2	(32)
(33)		10%	WB	18.1	17.7	16.2	13.0	10.4	8.4	7.1	7.7	10.2	12.8	15.1	16.5	(33)
(34)			MCD B	23.1	21.8	19.4	15.7	12.2	9.4	8.4	10.7	14.0	16.9	19.6	21.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.6	8.6	7.8	7.3	6.2	5.2	5.7	7.1	8.2	8.8	9.1	9.8	(35)
(36)			MCDBR	12.8	11.9	10.6	9.3	7.6	6.5	7.1	8.5	9.8	10.8	12.2	12.1	(36)
(37)			MCWBR	5.6	5.1	5.1	4.7	4.5	4.4	4.7	4.9	5.1	5.4	5.2	5.3	(37)
(38)		5% WB	MCD BR	10.4	9.7	8.4	7.6	5.9	5.2	5.3	7.1	8.1	9.0	9.7	10.0	(38)
(39)			MCWBR	5.9	5.0	4.9	4.4	4.0	4.1	4.3	4.8	5.0	5.5	5.3	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.334	0.328	0.305	0.287	0.268	0.263	0.257	0.264	0.290	0.308	0.332	0.323	(40)	
(41)		taud	2.535	2.576	2.635	2.655	2.675	2.693	2.703	2.668	2.573	2.540	2.501	2.558	(41)	
(42)		Ebn at Noon	1005	990	981	949	921	903	927	962	981	1000	999	1019	(42)	
(43)		Edh at Noon	110	102	90	79	68	63	65	76	94	105	113	109	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.89	5.99	5.04	4.09	3.21	2.52	2.92	3.86	5.14	6.00	6.43	7.04	(44)	
(45)		RadStd	0.45	0.53	0.47	0.34	0.22	0.20	0.20	0.26	0.33	0.58	0.63	0.58	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		+0.43	N/A	N/A	+0.88	N/A	N/A	-2	-85	+191	+103

Nomenclature: See separate page