

SYDNEY CAMDEN, Australia

WMO: 947550

Lat: 34.0392S

Lon: 150.6889E

Elev: 75

StdP: 100.43

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.1	1.3	-2.9	3.0	14.6	-1.7	3.3	12.5	11.0	15.0	9.5	15.2	0.6	150	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.6	35.5	20.5	33.0	20.3	30.8	19.7	22.9	29.6	22.1	28.0	21.5	27.0	5.0	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.4	16.2	24.1	20.7	15.5	23.6	19.9	14.7	23.3	68.3	29.5	65.3	27.9	62.9	27.1	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	7.9	6.8	DB	-2.1	40.3	1.0	2.3	-2.9	42.0	-3.4	43.3	-4.0	44.6	-4.7	46.3	(4)
(5)			WB	-2.3	24.7	1.1	1.0	-3.1	25.4	-3.8	26.0	-4.4	26.6	-5.2	27.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	23.3	22.6	20.8	17.4	13.6	11.2	10.3	11.4	14.4	17.1	19.5	21.6	(6)	
	DBStd	5.20	3.01	2.81	2.48	2.45	2.30	2.09	1.96	2.01	2.58	2.97	3.23	3.04	(7)	
	HDD10.0	42	0	0	0	0	2	12	20	8	1	0	0	0	(8)	
	HDD18.3	1094	1	1	6	46	148	215	251	217	121	61	23	6	(9)	
	CDD10.0	2556	412	353	334	221	112	47	28	51	134	220	284	360	(10)	
	CDD18.3	565	154	121	82	17	1	0	0	0	3	22	58	107	(11)	
	CDH23.3	4770	1242	881	519	156	12	0	1	5	103	345	584	922	(12)	
	CDH26.7	1872	556	348	155	34	0	0	0	0	24	123	243	389	(13)	
(14) Wind	WSAvg	2.5	2.7	2.5	2.3	2.0	2.0	2.1	2.3	2.8	2.8	2.7	2.8	2.8	(14)	
(15) Precipitation	PrecAvg	857	98	103	100	82	59	65	41	34	41	72	76	53	(15)	
	PrecMax	1261	264	422	344	338	154	304	143	164	148	243	166	163	(16)	
	PrecMin	447	10	16	5	2	2	4	0	1	2	0	9	0	(17)	
	PrecStd	234	70	105	82	84	45	72	38	47	35	64	45	43	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.0	37.6	33.5	30.5	24.8	20.8	21.7	23.8	29.6	33.6	36.9	37.7	(19)	
		MCWB	22.1	21.1	20.0	17.8	15.0	13.5	13.0	13.3	15.4	17.1	18.2	20.4	(20)	
	2%	DB	35.1	33.7	30.3	26.9	22.7	19.0	18.9	21.3	26.2	30.1	32.5	33.9	(21)	
		MCWB	21.7	21.4	20.2	17.4	14.5	12.8	11.3	12.5	14.6	16.8	19.2	19.9	(22)	
	5%	DB	32.3	30.5	28.1	24.9	21.1	17.7	17.5	19.4	23.7	27.3	29.1	30.7	(23)	
		MCWB	21.2	20.8	19.6	17.0	14.1	12.1	10.9	11.7	14.3	16.4	18.2	19.3	(24)	
	10%	DB	29.7	28.3	26.2	23.1	19.6	16.5	16.2	17.8	21.4	24.5	26.5	28.4	(25)	
		MCWB	20.5	20.3	19.0	16.5	13.5	11.7	10.4	10.9	13.4	15.6	17.7	19.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.3	24.2	22.6	20.2	18.1	15.5	14.9	15.0	17.7	19.9	22.0	23.1	(27)	
		MCDB	32.8	31.1	27.2	25.8	20.1	17.5	17.4	20.0	23.3	26.2	29.7	30.7	(28)	
	2%	WB	23.1	22.9	21.6	19.0	16.5	14.3	13.2	13.8	16.5	18.6	20.6	21.8	(29)	
		MCDB	30.4	28.8	26.1	23.0	19.4	16.5	15.8	18.4	22.0	24.9	27.8	28.9	(30)	
	5%	WB	22.1	22.0	20.8	18.3	15.5	13.5	12.2	12.8	15.6	17.6	19.6	20.9	(31)	
		MCDB	28.4	27.1	25.2	22.1	19.1	16.0	15.3	17.4	20.8	23.9	26.0	27.6	(32)	
	10%	WB	21.4	21.3	20.1	17.5	14.5	12.7	11.4	11.9	14.5	16.7	18.7	20.1	(33)	
		MCDB	27.1	26.0	24.3	21.4	18.2	15.4	14.9	16.3	19.5	22.6	24.3	25.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	10.7	10.5	11.8	13.0	11.7	13.2	13.9	14.0	13.4	12.1	12.0	(35)	
		MCDBR	17.3	15.7	14.4	15.1	15.4	13.9	15.8	17.4	18.9	19.6	18.4	17.3	(36)	
	5% WB	MCWBR	5.3	4.9	5.3	6.5	7.9	8.1	9.0	9.0	8.2	7.5	6.4	5.7	(37)	
		MCWBR	13.8	12.2	11.5	11.9	11.9	10.5	11.9	14.4	14.9	14.9	14.3	14.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.397	0.392	0.362	0.334	0.316	0.305	0.296	0.304	0.337	0.358	0.385	0.400	(40)	
		taud	2.420	2.456	2.515	2.566	2.567	2.596	2.602	2.573	2.481	2.452	2.419	2.386	(41)	
	Ebn at Noon		941	924	916	889	853	838	868	909	927	947	946	941	(42)	
		Edh at Noon	124	115	101	85	75	69	71	83	102	114	123	129	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.41	5.44	4.67	3.81	3.03	2.38	2.79	3.69	4.92	5.70	6.01	6.59	(44)	
	RadStd		0.50	0.51	0.42	0.33	0.20	0.21	0.21	0.23	0.30	0.54	0.56	0.61	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.49	N/A	N/A	N/A	N/A	N/A	N/A	-73	+207	+117
Regional (37 neighbors)		+0.44	N/A	N/A	+0.77	N/A	N/A	-2	-83	+182	+94

Nomenclature: See separate page