

SYDNEY MOUNT ANNAN, Australia

WMO: 947570

Lat: 34.0614S

Lon: 150.7736E

Elev: 367

StdP: 14.50

Time Zone: 10.00 (AUS)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.6	36.8	22.8	17.4	64.4	26.7	20.9	61.1	18.1	61.4	15.3	60.7	1.2	190	0.370

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	95.7	68.5	91.4	68.3	87.4	67.5	73.4	85.7	71.9	82.7	70.7	80.8	8.6	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.2	112.8	76.4	69.0	107.9	75.4	67.8	103.4	74.6	37.2	85.9	35.8	82.6	34.8	80.6	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.5	12.6	11.2	DB	29.8	105.5	1.6	4.9	28.7	109.0	27.8	111.8	26.9	114.6	25.7	118.1
			WB	29.3	76.6	1.7	1.8	28.1	77.9	27.1	79.0	26.1	80.0	24.9	81.3

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.7	74.0	72.4	69.4	63.7	57.1	53.1	51.2	53.1	58.1	63.0	67.6	70.6
	DBStd	9.08	5.63	4.98	4.47	4.57	3.99	3.39	3.50	3.67	4.53	5.52	5.66	5.63
	HDD50	50	0	0	0	0	2	11	26	10	1	0	0	0
	HDD65	1860	2	1	12	76	245	357	428	370	213	108	36	12
	CDD50	4696	745	626	603	412	223	104	63	106	244	403	528	639
	CDD65	1030	282	207	149	37	2	0	0	7	46	114	186	
	CDH74	8732	2354	1529	933	319	31	0	3	13	196	664	1098	1592
	CDH80	3427	1081	604	265	80	1	0	0	53	238	444	661	
(14) Wind	WSAvg	4.6	5.0	4.8	4.4	4.0	4.0	4.1	4.2	5.0	5.1	5.0	5.1	5.1
(15) Precipitation	PrecAvg	31.6	3.3	3.1	3.1	3.1	2.2	2.9	1.3	2.3	1.6	2.9	3.2	2.5
	PrecMax	52.0	9.2	14.1	11.3	13.8	6.3	14.2	4.9	13.6	6.6	13.0	12.0	7.7
	PrecMin	14.3	0.4	0.2	0.0	0.2	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.0
	PrecStd	9.6	2.6	2.9	2.5	3.1	1.8	3.3	1.1	2.9	1.3	2.8	2.8	1.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.9	101.2	91.4	88.1	77.6	68.0	72.4	75.7	86.1	92.2	98.3	99.3
		MCWB	69.3	68.7	68.1	63.2	58.9	55.4	55.2	55.8	60.3	62.6	65.2	67.5
	2%	DB	95.7	92.4	86.3	81.0	73.6	65.6	66.7	70.8	79.3	86.5	90.1	92.6
		MCWB	70.9	70.8	68.4	63.1	58.2	55.1	52.2	54.3	57.8	61.9	65.8	67.5
	5%	DB	90.6	86.6	82.5	77.1	70.3	63.7	64.0	67.2	74.6	81.6	84.6	87.2
		MCWB	70.6	69.6	67.8	62.9	57.4	54.2	51.7	52.5	56.7	61.6	65.4	66.8
	10%	DB	85.6	82.5	79.1	73.8	67.6	61.7	61.5	64.1	70.3	76.5	80.2	82.6
		MCWB	69.5	68.4	67.0	61.8	56.3	53.5	50.8	51.4	55.5	60.5	64.0	66.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.7	75.5	72.9	68.2	64.8	60.2	60.0	59.7	63.4	67.7	72.1	73.3
		MCDB	92.7	89.6	81.2	78.1	70.0	62.9	65.5	68.8	76.9	80.7	86.9	87.6
	2%	WB	73.8	73.0	71.1	66.3	61.6	58.0	56.5	57.0	61.2	65.5	69.6	71.2
		MCDB	86.7	83.9	79.6	74.9	67.8	61.5	61.8	65.8	72.1	77.1	82.7	83.6
	5%	WB	72.3	71.3	69.7	64.8	59.6	56.7	54.1	55.0	59.3	63.9	67.8	69.7
		MCDB	83.7	80.4	78.1	72.6	67.1	60.6	60.2	62.8	69.0	75.1	79.6	80.7
	10%	WB	70.9	70.1	68.3	63.4	57.9	55.4	52.4	53.3	57.4	62.4	66.1	68.2
		MCDB	81.2	78.8	76.1	70.6	65.3	59.5	58.9	61.0	66.7	73.1	75.1	77.8
(35) Mean Daily Temperature Range	5% DB	MDBR	21.4	19.6	19.2	21.0	22.6	19.0	22.9	23.8	24.7	24.1	22.1	21.3
		MCDBR	31.9	28.3	25.6	26.1	26.4	22.0	27.0	29.6	33.2	34.7	32.3	30.8
	5% WB	MCWBR	9.7	9.2	10.1	10.8	13.1	12.5	14.6	14.7	14.2	13.7	11.7	10.0
		MCWBR	24.2	21.1	21.1	21.9	21.8	16.0	21.6	24.0	26.6	26.5	26.6	23.9
(40) Clear-Sky Solar Irradiance	taub		0.394	0.390	0.360	0.332	0.314	0.305	0.296	0.303	0.336	0.356	0.382	0.399
		taud	2.430	2.465	2.526	2.576	2.578	2.603	2.609	2.581	2.491	2.463	2.429	2.391
	Ebn at Noon		299	294	292	283	271	266	276	289	294	301	301	299
		Edh at Noon	39	36	32	27	23	22	23	26	32	36	39	41
(44) All-Sky Solar Radiation	RadAvg		2041	1736	1486	1208	958	754	883	1168	1559	1809	1915	2095
	RadStd		157	160	132	104	63	68	68	69	93	166	176	187

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)		+0.79	N/A	N/A	+1.39	N/A	N/A	-4	-149	+328

Nomenclature: See separate page