

SYDNEY TERREY HILLS, Australia

WMO: 947590

Lat: 33.6908S

Lon: 151.2253E

Elev: 653

StdP: 14.35

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.9	43.6	26.6	21.0	59.2	29.2	23.7	55.5	19.8	55.8	17.4	54.7	7.9	280	0.377

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.4	90.3	67.5	85.8	68.6	82.4	68.2	74.2	81.6	72.7	79.5	71.4	77.5	8.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.5	123.2	76.3	70.9	116.6	74.9	69.7	111.8	73.8	38.2	82.0	36.8	80.2	35.7	77.7	81.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.5	14.4	12.9	DB	37.8	101.6	1.8	5.1	36.5	105.3	35.4	108.3	34.4	111.1	33.0	114.8	(4)
(5)			WB	34.9	77.2	1.4	1.9	33.9	78.6	33.0	79.8	32.2	80.8	31.2	82.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	71.9	70.9	68.8	64.1	58.7	54.4	53.3	55.0	59.5	63.5	66.5	69.1	(6)
(7)		DBStd	7.94	5.07	4.50	4.25	4.43	4.06	3.30	3.69	4.18	5.53	6.09	5.66	5.19	(7)
(8)		HDD50	16	0	0	0	0	0	4	8	4	0	0	0	0	(8)
(9)		HDD65	1629	3	4	14	67	198	319	361	312	184	103	47	17	(9)
(10)		CDD50	4736	678	585	583	423	271	135	112	158	286	418	494	593	(10)
(11)		CDD65	875	216	169	132	40	4	0	0	1	20	57	91	145	(11)
(12)		CDH74	4380	1207	726	402	130	7	0	0	5	149	399	556	799	(12)
(13)		CDH80	1360	424	207	76	25	0	0	0	0	35	128	199	266	(13)
(14)	Wind	WSAvg	6.7	6.9	6.6	6.4	6.0	6.4	6.8	6.8	7.0	7.0	6.8	6.8	6.8	(14)
(15)	Precipitation	PrecAvg	40.9	3.9	5.5	4.1	3.7	3.3	4.1	2.3	2.4	2.4	3.4	3.4	3.4	(15)
(16)		PrecMax	68.2	14.1	23.0	9.9	15.0	11.3	14.6	7.0	13.7	6.9	8.4	7.9	8.0	(16)
(17)		PrecMin	25.7	0.2	0.3	0.7	0.0	0.2	0.6	0.0	0.0	0.3	0.5	0.8	1.2	(17)
(18)		PrecStd	10.0	2.7	5.0	2.2	3.5	2.8	3.3	1.7	3.0	1.6	1.9	2.1	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.7	95.6	86.6	83.7	75.0	67.2	70.1	73.7	84.5	89.9	93.6	93.7	(19)
(20)			MCWB	70.1	72.8	69.9	63.5	60.0	57.1	56.6	56.2	58.4	62.3	64.5	67.4	(20)
(21)		2%	DB	88.9	85.6	81.4	77.4	71.3	64.0	65.4	69.3	78.3	83.4	85.3	86.7	(21)
(22)			MCWB	70.8	71.6	70.4	64.5	59.6	56.0	53.4	54.5	57.9	61.7	67.0	68.6	(22)
(23)		5%	DB	83.7	81.1	78.2	73.8	68.4	62.1	62.5	65.8	72.7	78.0	80.0	82.1	(23)
(24)			MCWB	71.5	71.1	69.1	63.9	59.0	55.1	52.4	53.2	56.7	61.7	66.0	67.9	(24)
(25)		10%	DB	80.1	78.0	75.4	71.1	66.0	60.3	60.3	63.0	68.9	73.5	75.5	77.8	(25)
(26)			MCWB	70.4	69.4	67.8	63.2	57.9	54.6	51.8	52.2	56.4	61.5	65.6	67.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.9	76.1	74.4	70.2	64.9	61.1	61.1	59.8	63.4	68.6	72.2	75.0	(27)
(28)			MCDWB	83.6	84.6	79.2	74.9	67.8	62.5	65.8	67.1	72.6	75.2	82.2	83.4	(28)
(29)		2%	WB	74.5	73.5	72.0	67.8	63.3	58.8	57.4	57.8	61.8	66.6	69.8	72.2	(29)
(30)			MCDWB	81.3	81.2	76.9	71.9	66.7	61.2	60.9	63.7	69.8	73.4	78.9	79.8	(30)
(31)		5%	WB	73.0	72.0	70.6	66.4	61.2	57.5	55.2	56.2	60.3	64.9	68.2	70.4	(31)
(32)			MCDWB	79.8	78.0	75.2	70.5	65.6	60.0	59.1	61.8	67.1	72.2	75.5	76.7	(32)
(33)		10%	WB	71.5	70.8	69.3	65.0	59.6	56.2	53.5	54.5	58.8	63.5	66.7	69.0	(33)
(34)			MCDWB	77.8	76.1	73.6	68.9	64.7	58.9	57.8	60.2	65.7	70.2	72.9	74.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.4	12.2	12.0	13.0	13.9	11.8	13.7	15.0	15.4	15.4	14.0	14.1	(35)
(36)			MCDBR	22.5	18.3	16.2	16.3	16.3	13.8	16.3	18.6	22.1	24.1	23.0	22.6	(36)
(37)			MCWBR	8.0	7.4	7.5	7.8	8.5	8.1	9.1	9.3	9.4	9.8	9.0	8.6	(37)
(38)		5% WB	MCDBR	17.5	14.8	14.0	12.9	13.7	10.5	12.6	14.6	16.7	17.7	18.1	17.6	(38)
(39)			MCWBR	7.6	6.9	7.2	7.2	8.2	7.4	8.5	8.9	9.5	9.1	8.2	8.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.384	0.386	0.351	0.325	0.312	0.304	0.295	0.303	0.335	0.353	0.376	0.385	(40)	
(41)		taud	2.478	2.490	2.582	2.630	2.612	2.632	2.642	2.612	2.514	2.492	2.466	2.454	(41)	
(42)		Ebn at Noon	302	295	295	286	273	268	277	290	295	302	303	303	(42)	
(43)		Edh at Noon	37	35	30	26	23	21	22	25	31	35	37	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2050	1778	1511	1217	955	757	888	1175	1558	1803	1928	2097	(44)	
(45)		RadStd	147	152	130	102	68	69	70	65	84	152	174	169	165	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)		+0.79	N/A	N/A	+1.39	N/A	N/A	-4	-155	+333	+178

Nomenclature: See separate page