

SYDNEY HOLSWORTHY, Australia

WMO: 947620

Lat: 33.979S

Lon: 150.925E

Elev: 40

StdP: 100.85

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) -0.7	(c) 0.9	(d) -6.0	(e) 2.3	(f) 15.7	(g) -4.1	(h) 2.7	(i) 12.9	(j) 9.6	(k) 13.9	(l) 8.5	(m) 14.1	(n) 1.5	(o) 150	(p) 0.455

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 13.4	(c) 36.8	(d) 19.4	(e) 34.9	(f) 19.1	(g) 33.1	(h) 18.7	(i) 22.5	(j) 28.9	(k) 21.6	(l) 28.2	(m) 20.9	(n) 27.6	(o) 5.0	(p) 310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.1	15.8	23.8	20.0	14.8	23.0	19.1	13.9	22.7	66.3	28.9	63.2	28.2	60.5	27.5	32.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 9.7	(b) 8.5	(c) 7.5	(e) -3.1	(f) 39.8	(g) 2.0	(h) 2.2	(i) -4.6	(j) 41.4	(k) -5.7	(l) 42.7	(m) -6.9	(n) 43.9	(o) -8.3	(p) 45.5		
(4) 9.7	(5) 8.5	(6) 7.5	(7) -3.6	(8) 24.3	(9) 2.2	(10) 2.1	(11) -5.2	(12) 25.8	(13) -6.5	(14) 27.1	(15) -7.7	(16) 28.3	(17) -9.3	(18) 29.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	24.7	23.8	21.7	17.8	13.5	11.0	9.9	11.0	14.4	17.6	20.4	22.7
	DBStd	5.87	3.17	3.08	2.58	2.70	2.47	2.40	2.40	2.53	2.87	3.25	3.67	3.20
	HDD10.0	73	0	0	0	0	4	18	32	18	2	0	0	0
	HDD18.3	1103	1	1	4	41	150	220	262	228	122	52	19	3
	CDD10.0	2748	455	386	362	233	113	48	28	48	133	237	312	394
	CDD18.3	736	197	153	107	23	1	0	0	1	4	30	81	139
	CDH23.3	8086	2151	1579	969	282	15	0	0	6	129	472	988	1495
	CDH26.7	3572	1101	757	352	53	0	0	0	1	26	151	434	698
Wind	WSAvg	3.4	3.9	4.0	3.6	3.3	2.9	2.9	2.9	3.2	3.4	3.6	3.9	3.9
Precipitation	PrecAvg	876	98	95	101	85	69	71	40	57	46	62	77	63
	PrecMax	1369	250	479	318	405	197	320	152	357	179	176	211	237
	PrecMin	458	5	13	3	3	3	0	0	1	1	0	9	3
	PrecStd	252	67	91	78	91	56	77	39	79	39	51	51	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.1	38.8	34.4	30.4	25.1	21.0	21.0	23.7	29.6	33.0	37.5	37.9
		MCWB	20.4	20.0	18.9	16.7	14.5	13.3	12.9	13.5	15.0	17.0	19.1	19.0
	2%	DB	36.7	36.0	32.2	28.1	23.1	19.2	18.9	21.4	26.7	30.3	34.0	35.2
		MCWB	19.8	19.4	18.3	16.6	14.0	12.4	11.8	12.5	14.4	16.3	17.8	18.5
	5%	DB	34.8	33.6	30.4	26.5	21.8	18.1	17.3	19.8	24.6	28.1	31.3	33.1
		MCWB	19.7	19.2	18.1	15.9	13.4	12.0	11.1	11.6	13.8	15.7	17.6	18.2
	10%	DB	32.6	31.2	28.5	24.8	20.1	16.9	15.9	18.0	22.2	26.0	28.9	30.7
		MCWB	19.5	18.8	17.8	15.6	13.2	11.5	10.5	11.0	13.4	15.4	16.8	18.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.6	23.7	22.4	21.2	17.8	15.3	15.7	16.9	17.7	19.8	22.3	23.1
		MCDB	31.3	29.0	27.2	24.3	19.8	17.8	18.3	19.6	23.1	26.7	30.0	27.5
	2%	WB	22.3	22.3	21.0	18.8	16.3	14.1	13.6	14.4	16.5	18.3	20.1	21.5
		MCDB	29.8	28.6	25.6	23.1	19.9	16.7	15.9	17.8	22.2	25.0	27.9	27.9
	5%	WB	21.5	21.4	20.2	17.8	15.2	13.2	12.4	13.0	15.5	17.3	19.1	20.6
		MCDB	28.7	28.0	24.9	22.3	19.2	16.2	15.2	17.4	21.1	24.1	26.7	27.2
	10%	WB	20.8	20.5	19.3	16.9	14.2	12.4	11.3	11.8	14.5	16.4	18.3	19.8
		MCDB	28.1	27.1	24.6	22.0	18.5	15.7	15.0	16.6	19.9	23.1	25.7	26.3
Mean Daily Temperature Range	5% DB	MDBR	13.4	13.2	12.8	13.5	13.5	12.1	12.7	14.1	14.8	14.5	13.9	13.3
		MCDBR	17.1	17.2	15.9	15.9	15.6	13.7	15.1	17.2	19.1	18.5	18.4	17.5
		MCWBR	4.9	5.0	5.4	6.6	7.9	8.0	8.9	9.3	8.9	7.6	6.3	5.4
	5% WB	MCDBR	13.3	12.6	11.4	11.8	11.5	10.6	11.0	13.1	14.2	14.8	14.1	12.8
		MCWBR	4.9	4.8	4.9	5.9	6.5	6.9	7.4	8.2	7.6	7.1	6.1	5.6
Clear-Sky Solar Irradiance	taub	0.397	0.393	0.362	0.335	0.318	0.309	0.299	0.307	0.340	0.360	0.385	0.399	
	taud	2.439	2.468	2.537	2.588	2.585	2.607	2.615	2.585	2.492	2.467	2.436	2.410	
	Ebn at Noon	941	923	917	889	852	835	866	906	924	945	946	943	
	Edh at Noon	121	114	99	84	74	68	71	82	102	112	121	126	
All-Sky Solar Radiation	RadAvg	6.46	5.53	4.72	3.82	3.01	2.37	2.78	3.68	4.91	5.71	6.07	6.62	
	RadStd	0.48	0.49	0.41	0.33	0.20	0.22	0.22	0.21	0.28	0.51	0.55	0.56	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-1.25	+3.19	-0.69	-1.20	N/A	N/A	N/A	N/A
(47) Regional (35 neighbors)	+0.44	N/A	N/A	N/A	N/A	N/A	-2	-85	+184	+98

Nomenclature: See separate page