

SYDNEY CANTERBURY, Australia

WMO: 947660

Lat: 33.9058S

Lon: 151.1133E

Elev: 10

StdP: 14.69

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.6	40.5	26.2	20.2	62.1	28.8	22.8	59.0	22.7	61.5	19.0	59.6	1.6	300	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.7	91.4	68.1	87.3	68.6	83.9	68.2	73.8	83.0	72.5	81.1	71.3	79.3	11.5	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.1	114.7	77.4	69.9	110.0	76.4	68.7	105.4	75.4	37.3	83.3	36.2	81.4	35.1	79.3	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.3	18.6	16.5	DB	34.0	102.5	1.8	4.5	32.7	105.8	31.7	108.4	30.7	111.0	29.4	114.3	(4)
(5)			WB	32.9	76.4	1.7	1.4	31.7	77.4	30.7	78.3	29.7	79.0	28.4	80.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.4	73.0	72.3	69.7	64.4	58.7	54.5	52.9	54.6	59.6	63.6	66.9	70.6	(6)
(7)		DBStd	8.21	4.84	4.44	4.03	4.02	3.78	3.32	3.07	3.63	4.79	5.25	5.45	5.06	(7)
(8)		HDD50	13	0	0	0	0	0	3	7	3	0	0	0	0	(8)
(9)		HDD65	1588	2	1	7	56	199	314	376	323	175	89	38	8	(9)
(10)		CDD50	4888	713	626	611	432	269	139	96	146	289	423	507	637	(10)
(11)		CDD65	988	250	206	153	38	3	0	0	1	13	47	96	181	(11)
(12)		CDH74	6133	1582	1165	677	218	20	0	2	11	203	460	668	1127	(12)
(13)		CDH80	1821	515	310	138	39	0	0	0	0	53	154	238	374	(13)
(14)	Wind	WSAvg	7.0	8.4	8.1	7.3	5.8	5.4	5.3	5.5	6.5	7.2	7.7	8.5	8.2	(14)
(15)	Precipitation	PrecAvg	42.9	3.9	4.3	4.7	4.3	3.5	4.9	2.4	3.1	2.3	2.8	3.4	3.1	(15)
(16)		PrecMax	79.7	15.7	22.9	15.5	18.7	15.3	14.6	9.8	16.2	9.8	10.6	15.6	14.1	(16)
(17)		PrecMin	20.6	0.2	0.3	0.2	0.3	0.1	0.1	0.0	0.0	0.0	0.0	0.4	0.2	(17)
(18)		PrecStd	11.8	3.1	3.8	3.5	3.8	3.0	3.7	2.0	3.6	1.9	2.5	3.0	2.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.1	95.1	88.8	85.2	76.8	70.0	72.1	75.4	86.1	91.2	94.7	95.3	(19)
(20)			MCWB	70.5	70.8	69.0	64.0	59.8	56.9	55.3	56.1	61.3	62.5	66.4	68.3	(20)
(21)		2%	DB	89.8	87.4	83.4	79.2	72.9	66.8	67.1	70.7	79.8	84.5	86.5	88.5	(21)
(22)			MCWB	70.4	71.8	69.9	64.2	60.1	56.0	53.2	54.8	58.6	62.0	66.4	68.2	(22)
(23)		5%	DB	85.2	83.2	80.2	76.1	70.0	64.7	64.1	67.4	74.8	78.9	81.0	83.9	(23)
(24)			MCWB	70.9	70.9	68.5	63.9	59.1	55.2	52.3	54.0	57.8	61.9	65.6	67.7	(24)
(25)		10%	DB	81.7	80.2	77.5	73.2	67.6	62.8	61.8	64.7	70.7	74.5	76.8	79.9	(25)
(26)			MCWB	69.5	69.8	67.3	63.1	58.4	54.6	51.8	52.7	57.2	61.0	65.0	67.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.3	76.2	73.4	69.1	66.1	61.1	60.2	60.3	64.4	68.1	71.6	73.6	(27)
(28)			MCDWB	88.1	85.8	81.2	77.4	69.9	65.0	65.5	68.5	75.3	78.6	85.3	85.1	(28)
(29)		2%	WB	73.5	74.3	71.6	67.4	63.9	59.2	57.2	58.4	62.5	66.0	69.4	71.7	(29)
(30)			MCDWB	83.9	82.1	79.1	74.3	68.1	63.4	61.4	65.3	71.4	75.7	79.7	81.5	(30)
(31)		5%	WB	72.2	72.8	70.3	66.2	61.9	57.7	55.5	56.5	61.0	64.5	67.8	70.1	(31)
(32)			MCDWB	81.2	80.1	77.3	72.2	67.0	62.1	60.5	63.4	69.6	73.5	76.2	78.7	(32)
(33)		10%	WB	71.1	71.4	69.1	64.8	59.9	56.4	53.7	54.8	59.4	63.1	66.4	68.8	(33)
(34)			MCDWB	79.0	78.3	75.6	70.9	65.8	60.8	59.2	61.7	67.8	71.3	74.2	77.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	14.7	13.7	14.6	17.0	18.5	17.4	19.3	20.2	20.3	18.2	15.9	15.5	(35)
(36)			MCDBR	22.8	20.1	19.8	22.5	22.4	20.8	23.9	25.6	28.8	28.4	25.6	24.3	(36)
(37)			MCWBR	8.1	7.5	8.5	9.5	10.9	11.3	12.2	12.3	11.3	10.5	9.3	8.3	(37)
(38)		5% WB	MCDBR	18.2	16.0	16.6	17.1	16.6	15.6	17.8	20.3	21.8	20.5	19.8	18.7	(38)
(39)			MCWBR	7.4	7.2	7.9	8.7	9.7	9.7	11.2	11.8	10.9	9.6	8.7	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.397	0.396	0.362	0.335	0.320	0.312	0.302	0.310	0.344	0.363	0.387	0.398	(40)	
(41)		taud	2.452	2.472	2.554	2.604	2.596	2.615	2.624	2.592	2.495	2.474	2.446	2.426	(41)	
(42)		Ebn at Noon	298	292	291	282	270	264	274	286	292	299	300	299	(42)	
(43)		Edh at Noon	38	36	31	26	23	22	22	26	32	36	38	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2059	1772	1508	1215	952	751	882	1168	1556	1810	1935	2107	(44)	
(45)		RadStd	149	153	129	102	65	69	70	63	86	152	173	168	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	-2	-155	+337	+176

Nomenclature: See separate page