

SYDNEY AP, Australia

WMO: 947670

Lat: 33.9464S

Lon: 151.1731E

Elev: 5

StdP: 101.26

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.7	7.6	-3.9	2.7	18.1	-2.1	3.2	16.3	14.5	14.5	13.0	14.5	4.3	330	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	33.3	19.5	30.9	20.1	29.0	20.1	23.4	27.7	22.7	26.7	22.1	26.0	7.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.2	16.9	24.8	21.5	16.1	24.4	20.9	15.6	24.0	69.7	27.8	67.1	26.8	64.9	26.1	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.2	11.9	10.7	DB	4.9	39.5	0.9	2.9	4.2	41.6	3.7	43.3	3.2	45.0	2.5	47.1	(4)
(5)			WB	2.7	24.5	0.7	0.8	2.2	25.0	1.8	25.5	1.4	25.9	1.0	26.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	23.5	23.2	22.0	19.1	16.3	13.9	13.1	14.1	16.7	18.7	20.3	22.2	(6)	
	DBStd	4.41	2.69	2.48	2.33	2.38	2.22	1.87	1.92	2.35	2.88	3.16	3.12	2.86	(7)	
	HDD10.0	1	0	0	0	0	0	0	1	0	0	0	0	0	(8)	
	HDD18.3	636	0	0	2	17	71	134	164	133	67	33	13	3	(9)	
	CDD10.0	3124	417	371	371	274	194	116	96	128	200	271	310	378	(10)	
	CDD18.3	717	159	137	113	41	7	0	1	2	17	45	73	122	(11)	
	CDH23.3	3788	907	717	461	153	25	1	3	19	129	308	414	652	(12)	
(13)	CDH26.7	1103	287	182	92	28	1	0	0	2	38	113	148	211	(13)	
(14)	Wind	WSAvg	5.4	6.0	5.7	5.4	4.8	4.8	4.9	5.3	5.5	5.7	6.0	6.1	(14)	
(15) Precipitation	PrecAvg	1090	98	110	120	109	89	125	62	79	58	70	87	78	(15)	
	PrecMax	2025	400	581	393	476	388	372	250	411	248	268	396	359	(16)	
	PrecMin	523	6	7	6	8	3	2	0	1	0	0	11	5	(17)	
	PrecStd	299	80	96	89	96	77	94	50	91	49	63	75	64	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.9	35.8	32.2	29.7	25.9	22.1	23.1	25.6	30.9	34.0	35.8	35.8	(19)	
		MCWB	20.3	21.5	20.6	17.6	15.4	14.1	13.3	13.9	16.2	16.8	18.8	19.7	(20)	
	2%	DB	32.1	30.7	28.9	26.8	23.7	20.2	20.2	22.8	27.0	29.8	30.6	31.3	(21)	
		MCWB	21.6	22.0	20.9	17.8	15.7	13.7	12.1	12.8	14.9	16.5	19.0	19.8	(22)	
	5%	DB	29.4	28.6	27.2	25.0	21.9	19.0	18.8	20.7	24.0	26.4	27.5	28.8	(23)	
		MCWB	21.5	21.5	20.3	18.1	15.4	13.3	11.7	12.5	14.6	16.5	18.7	20.2	(24)	
	10%	DB	27.6	27.0	25.8	23.3	20.6	17.9	17.2	19.0	22.0	24.0	25.2	26.7	(25)	
		MCWB	21.0	20.9	19.8	17.6	15.2	13.0	11.4	12.2	14.1	16.3	18.4	19.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.4	24.2	23.2	21.1	19.0	16.7	16.0	16.5	18.3	20.2	22.0	23.3	(27)	
		MCDB	28.8	28.5	26.6	24.8	21.1	19.4	19.4	20.8	23.5	25.2	28.4	28.2	(28)	
	2%	WB	23.4	23.4	22.3	20.1	18.2	15.7	14.5	15.2	17.2	19.2	21.0	22.4	(29)	
		MCDB	28.1	27.2	25.7	23.5	21.0	17.9	17.0	19.3	21.6	23.9	25.9	26.7	(30)	
	5%	WB	22.7	22.7	21.7	19.4	17.2	15.0	13.5	14.4	16.5	18.4	20.2	21.6	(31)	
		MCDB	27.0	26.3	25.0	22.7	20.1	17.2	16.2	18.3	20.9	23.0	24.6	25.7	(32)	
	10%	WB	22.1	22.0	21.0	18.7	16.3	14.2	12.7	13.4	15.7	17.7	19.4	20.8	(33)	
		MCDB	25.9	25.7	24.3	22.0	19.3	16.7	15.7	17.2	20.1	22.0	23.5	24.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	6.4	6.5	7.5	7.9	7.6	8.5	9.0	9.0	8.5	7.4	7.3	(35)	
		MCDBR	10.9	9.4	9.1	10.2	10.1	9.5	10.8	11.9	13.3	13.7	12.5	11.8	(36)	
	5% WB	MCWBR	3.7	3.3	3.8	4.4	4.8	5.1	5.3	5.5	5.4	5.3	4.5	4.0	(37)	
		MCWBR	8.6	7.8	7.3	7.9	7.5	6.9	8.0	9.5	10.1	10.1	9.6	9.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.396	0.395	0.362	0.335	0.320	0.312	0.303	0.311	0.345	0.362	0.386	0.397	(40)	
		taud	2.458	2.479	2.561	2.610	2.601	2.618	2.627	2.595	2.498	2.480	2.453	2.433	(41)	
	Ebn at Noon	Ebn at Noon	941	921	918	890	851	832	863	903	919	943	945	944	(42)	
		Edh at Noon	119	112	97	82	73	68	70	81	101	111	119	123	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.51	5.61	4.77	3.83	2.99	2.36	2.77	3.67	4.90	5.71	6.12	6.66	(44)	
(45)		RadStd	0.47	0.48	0.40	0.32	0.20	0.22	0.22	0.19	0.27	0.47	0.54	0.51	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.53	+0.54	-0.69	+0.85	N/A	N/A	N/A	-92	+227	+128
(47)	Regional (33 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	-1	-86	+187	+98

Nomenclature: See separate page