

TOTAL, Australia

WMO: 947750

Lat: 32.6297S

Lon: 151.5919E

Elev: 98

StdP: 14.64

Time Zone: 10.00 (AUS)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.7	40.7	24.6	18.8	67.0	28.1	22.2	63.2	24.8	61.1	21.8	59.1	1.7	280	0.378

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.7	98.2	70.0	93.6	69.4	90.0	68.9	74.9	87.8	73.6	85.2	72.4	82.7	11.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.8	117.9	78.0	70.6	113.1	76.8	69.5	108.9	75.8	38.4	87.9	37.2	85.7	36.1	82.4	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	17.2	14.8	34.7	106.1	1.4	4.2	33.7	109.2	32.9	111.7	32.2	114.1	31.2	117.1
			34.0	77.2	1.6	1.4	32.9	78.2	31.9	79.1	31.1	79.9	29.9	80.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.6	75.6	74.0	70.8	65.0	58.9	55.0	53.7	55.6	60.8	65.2	69.5	72.3	(6)
(7)		DBStd	8.87	5.43	5.27	4.62	4.00	3.87	3.42	3.48	4.07	4.95	5.68	6.04	5.62	(7)
(8)		HDD50	10	0	0	0	0	0	3	5	2	0	0	0	0	(8)
(9)		HDD65	1432	0	1	5	47	192	301	350	293	146	69	21	7	(9)
(10)		CDD50	5353	793	672	643	450	277	152	120	175	324	472	585	690	(10)
(11)		CDD65	1301	329	253	184	47	4	0	0	1	20	75	156	232	(11)
(12)		CDH74	11917	3161	2083	1222	323	35	1	2	28	325	926	1619	2192	(12)
(13)		CDH80	4958	1536	870	373	68	1	0	0	2	86	353	708	961	(13)
(14)	Wind	WSAvg	5.8	6.6	5.9	5.1	4.2	4.9	5.4	5.9	6.3	6.3	6.1	6.3	6.5	(14)
(15)	Precipitation	PrecAvg	34.8	3.0	4.6	3.6	3.3	2.7	3.3	2.0	1.8	2.2	1.9	3.3	3.2	(15)
(16)		PrecMax	52.3	14.4	18.8	12.5	13.1	9.3	14.8	5.6	5.8	6.1	6.3	9.8	7.8	(16)
(17)		PrecMin	24.4	0.0	0.0	0.6	0.2	0.0	0.2	0.2	0.0	0.2	0.0	0.5	0.7	(17)
(18)		PrecStd	6.9	2.7	3.8	2.4	2.8	2.4	2.7	1.2	1.4	1.6	1.4	2.0	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.5	101.6	93.0	86.8	77.8	69.8	72.1	77.7	87.7	93.5	100.1	101.5	(19)
(20)			MCWB	72.0	72.3	69.7	65.2	61.7	57.8	56.6	57.6	59.7	63.0	67.8	68.2	(20)
(21)		2%	DB	98.4	94.4	87.9	81.2	73.9	66.3	67.8	72.7	82.1	88.5	93.0	94.8	(21)
(22)			MCWB	71.4	72.1	70.2	65.2	59.9	56.0	54.2	55.9	59.3	62.5	66.7	68.7	(22)
(23)		5%	DB	93.5	89.3	84.2	77.5	70.9	64.4	64.7	69.3	77.6	83.6	88.1	89.6	(23)
(24)			MCWB	70.8	70.9	69.8	64.5	59.4	55.8	53.1	54.5	58.0	62.5	67.0	68.4	(24)
(25)		10%	DB	88.8	84.8	80.7	74.5	68.2	62.5	62.3	66.2	73.2	78.8	83.0	85.3	(25)
(26)			MCWB	71.1	70.4	68.7	63.7	58.1	54.8	52.8	53.3	57.0	62.0	66.2	67.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.9	77.2	74.5	69.7	65.7	61.5	62.3	62.7	64.7	69.6	73.5	75.0	(27)
(28)			MCD B	91.5	89.4	84.2	76.0	70.6	65.3	68.0	70.8	74.8	80.2	87.5	89.4	(28)
(29)		2%	WB	75.0	75.0	72.6	67.8	63.6	59.8	58.3	59.2	62.8	67.4	71.1	72.8	(29)
(30)			MCD B	89.2	86.1	81.7	75.2	69.7	63.4	62.8	65.8	72.7	78.0	83.4	85.0	(30)
(31)		5%	WB	73.8	73.4	71.2	66.6	61.9	58.5	55.9	57.4	61.2	65.7	69.3	71.3	(31)
(32)			MCD B	86.5	82.8	79.5	74.0	67.9	61.7	60.8	65.4	71.5	76.3	80.9	82.5	(32)
(33)		10%	WB	72.6	71.8	69.9	65.3	60.2	57.1	54.4	55.5	59.4	64.1	67.8	69.9	(33)
(34)			MCD B	83.5	80.6	77.6	72.3	66.0	60.4	59.6	63.4	69.5	74.1	78.5	80.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	20.7	19.0	18.3	19.1	19.3	15.6	17.9	21.3	23.0	23.2	21.6	21.1	(35)
(36)			MCD BR	32.4	28.4	24.5	25.1	23.4	18.9	22.3	27.5	32.0	33.7	32.7	31.2	(36)
(37)			MCWBR	9.0	8.9	8.8	10.6	11.4	10.6	11.9	12.9	12.2	12.1	10.4	9.5	(37)
(38)		5% WB	MCD BR	24.1	20.8	19.9	19.7	19.3	14.4	17.8	22.7	25.1	25.3	24.4	23.6	(38)
(39)			MCWBR	8.0	7.9	8.1	9.4	10.7	9.5	11.4	12.7	11.7	11.2	9.6	8.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.396	0.387	0.356	0.335	0.315	0.309	0.300	0.308	0.344	0.363	0.391	0.385	(40)	
(41)		taud	2.432	2.480	2.557	2.588	2.595	2.609	2.614	2.578	2.470	2.449	2.413	2.452	(41)	
(42)		Ebn at Noon	299	295	294	284	274	268	277	289	293	300	299	304	(42)	
(43)		Edh at Noon	39	36	31	27	24	22	23	27	33	36	39	38	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2085	1826	1542	1243	989	789	920	1217	1595	1820	1950	2097	(44)	
(45)		RadStd	136	161	137	102	78	64	73	81	89	161	185	178	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (30 neighbors)	+0.81	N/A	N/A	+1.46	N/A	N/A	-4	-151	+338	+184

Nomenclature: See separate page