

ALBANY, Australia

WMO: 948020

Lat: 34.941S

Lon: 117.802E

Elev: 226

StdP: 14.58

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.9	41.9	34.4	29.3	53.7	36.5	31.9	51.4	25.1	57.3	23.0	57.4	4.4	0	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.1	86.1	65.8	81.3	65.1	77.5	64.3	68.7	79.0	67.1	76.1	65.9	73.7	12.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	95.7	70.3	64.3	91.1	69.3	63.1	87.0	68.7	33.0	79.7	31.7	76.1	30.8	73.7	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.1	20.9	18.9	DB	35.3	99.3	1.1	4.5	34.5	102.5	33.8	105.1	33.2	107.6	32.4	110.9	(4)
(5)			WB	35.0	72.6	1.1	1.7	34.2	73.9	33.5	74.9	32.9	75.8	32.0	77.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.3	65.6	66.4	64.8	61.8	57.7	54.3	52.8	53.3	54.6	56.9	60.3	63.0	(6)	
	DBStd	6.39	4.76	4.77	5.22	4.71	3.70	3.24	3.16	3.38	3.68	4.41	4.78	4.68	(7)	
	HDD50	24	0	0	0	0	0	3	9	7	4	1	0	0	(8)	
	HDD65	2374	47	32	67	122	227	321	377	361	313	256	156	95	(9)	
	CDD50	3406	482	460	459	353	241	133	97	111	141	215	310	404	(10)	
	CDD65	279	64	72	61	24	2	0	0	0	0	5	17	34	(11)	
	CDH74	1798	390	407	361	177	20	0	0	1	12	54	138	238	(12)	
	CDH80	569	121	131	132	50	2	0	0	0	1	15	44	73	(13)	
(14) Wind	WSAvg	9.8	11.1	11.1	10.0	8.5	8.2	9.1	9.5	9.5	9.9	9.6	10.2	10.4	(14)	
(15) Precipitation	PrecAvg	31.7	0.9	0.9	1.4	2.5	3.5	4.0	4.7	4.3	3.5	2.8	1.8	1.2	(15)	
	PrecMax	38.7	5.6	2.4	3.9	9.3	10.2	8.8	8.5	8.7	6.1	6.8	5.4	5.0	(16)	
	PrecMin	24.1	0.1	0.0	0.2	0.4	1.6	1.7	2.2	1.7	1.7	0.9	0.2	0.2	(17)	
	PrecStd	4.1	1.1	0.7	0.9	1.6	1.6	1.5	1.4	1.3	1.3	1.2	1.0	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.0	91.7	92.4	86.7	76.6	69.0	66.6	70.8	75.0	81.2	85.8	87.8	(19)	
		MCWB	68.5	67.0	64.9	62.1	60.5	57.2	55.6	57.0	59.6	60.4	64.2	65.8	(20)	
	2%	DB	82.4	83.4	82.6	78.8	71.8	66.0	63.9	66.2	68.7	72.7	77.1	80.1	(21)	
		MCWB	66.8	66.9	65.1	62.8	59.5	56.0	55.0	56.3	57.9	60.9	63.2	65.2	(22)	
	5%	DB	77.6	78.4	76.9	74.1	68.5	63.7	61.9	63.4	65.4	68.5	72.4	75.2	(23)	
		MCWB	65.1	65.3	64.5	62.2	59.1	55.2	54.2	54.9	56.5	58.9	61.6	63.4	(24)	
	10%	DB	74.2	74.7	72.9	70.4	65.9	61.5	59.8	60.9	62.6	65.2	68.9	71.6	(25)	
		MCWB	63.3	63.9	63.0	61.2	58.0	54.5	53.4	53.7	55.0	57.5	59.7	61.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.6	71.5	69.1	67.2	64.0	60.3	58.9	59.9	62.1	64.6	67.2	68.9	(27)	
		MCDB	82.4	84.9	79.4	74.8	69.6	65.5	62.8	66.4	70.4	72.9	78.4	81.1	(28)	
	2%	WB	68.3	68.4	67.3	65.4	62.0	58.3	56.8	57.7	59.0	62.0	64.4	66.3	(29)	
		MCDB	79.0	77.7	75.8	72.4	67.5	63.0	61.2	63.3	66.3	69.9	73.7	77.1	(30)	
	5%	WB	66.3	66.8	66.0	64.0	60.5	57.0	55.5	56.2	57.2	60.0	62.5	64.2	(31)	
		MCDB	75.5	74.4	72.9	70.2	65.4	61.3	60.0	61.1	63.6	66.1	70.2	72.9	(32)	
	10%	WB	64.6	65.4	64.6	62.6	59.1	55.6	54.2	54.8	55.7	58.4	60.7	62.6	(33)	
		MCDB	71.5	72.1	70.8	67.9	64.1	59.7	58.6	59.4	61.3	64.0	67.4	69.8	(34)	
(35) Mean Daily Temperature Range	MDBR		16.4	16.1	16.3	17.0	16.4	14.5	13.9	14.8	15.6	16.0	16.4	16.2	(35)	
	5% DB	MCDBR	24.2	23.9	24.0	24.0	21.4	18.3	17.3	19.5	21.4	22.8	23.7	23.9	(36)	
		MCWBR	10.1	9.5	9.3	10.5	11.0	10.4	10.2	10.9	11.6	11.9	11.1	10.6	(37)	
	5% WB	MCDBR	21.5	19.8	19.3	19.2	16.8	15.0	14.5	16.5	19.3	19.8	21.3	21.2	(38)	
		MCWBR	9.5	8.8	8.5	9.6	10.1	9.7	9.6	10.3	11.2	10.8	10.6	10.1	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.343	0.347	0.332	0.320	0.306	0.305	0.301	0.308	0.330	0.333	0.336	0.338	(40)	
	taud		2.563	2.556	2.601	2.629	2.636	2.611	2.621	2.596	2.513	2.525	2.546	2.554	(41)	
	Ebn at Noon		315	307	300	286	273	264	272	286	296	308	315	318	(42)	
	Edh at Noon		34	33	29	25	22	21	22	25	31	34	34	35	(43)	
(44) All-Sky Solar Radiation	RadAvg		2290	1995	1585	1165	868	710	772	1033	1392	1777	2101	2330	(44)	
	RadStd		161	121	101	67	55	41	37	47	50	97	127	126	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	+0.77	N/A	N/A	N/A	+160	N/A	(46)
(47)	Regional (7 neighbors)	N/A	N/A	-0.95	N/A	N/A	N/A	N/A	N/A	+160	N/A	(47)

Nomenclature: See separate page