

NEPTUNE ISLANDS, Australia

WMO: 948040

Lat: 35.336S

Lon: 136.118E

Elev: 105

StdP: 14.64

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	50.6	51.5	38.6	34.6	53.9	40.0	36.5	54.3	47.1	55.1	44.2	55.0	21.3	230	0.768

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.2	78.1	67.4	75.1	66.7	72.9	65.9	69.4	74.5	68.1	72.9	66.9	71.6	13.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	102.1	71.7	66.3	97.2	70.5	65.0	92.8	69.6	33.6	74.7	32.5	73.2	31.5	71.6	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 41.1	36.4	32.5	DB	47.2	87.7	1.7	4.6	46.0	91.0	45.0	93.7	44.1	96.2	42.9	99.5	(4)
(5)			WB	43.3	71.7	2.0	2.0	41.9	73.2	40.7	74.4	39.5	75.6	38.1	77.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	61.3	66.6	66.8	65.5	63.3	60.8	57.8	56.5	56.5	57.4	59.1	61.6	64.0	(6)	
	DBStd	4.79	3.72	3.29	3.33	2.82	2.68	2.34	2.45	2.59	2.73	3.06	3.61	3.58	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	1597	19	13	31	66	134	215	264	264	227	185	116	63	(9)	
	CDD50	4118	514	470	479	398	334	235	201	201	223	282	348	433	(10)	
	CDD65	242	68	63	45	15	3	0	0	0	0	3	14	31	(11)	
	CDH74	399	156	91	57	2	0	0	0	0	0	2	28	63	(12)	
	CDH80	58	28	13	6	0	0	0	0	0	0	0	3	8	(13)	
(14) Wind	WSAvg	18.1	17.6	17.2	16.5	15.8	17.6	19.1	21.2	20.1	19.5	17.9	17.4	17.4	(14)	
(15) Precipitation	PrecAvg	18.4	0.6	0.5	0.7	1.4	2.2	2.8	3.2	2.6	1.9	1.0	0.7	0.6	(15)	
	PrecMax	25.3	5.7	2.9	3.5	5.9	4.3	6.1	6.2	5.2	5.6	2.9	2.8	2.5	(16)	
	PrecMin	11.8	0.0	0.0	0.0	0.2	0.7	0.7	1.1	0.9	0.4	0.0	0.0	0.0	(17)	
	PrecStd	3.5	0.9	0.6	0.8	1.3	0.9	1.4	1.4	0.9	1.1	0.7	0.6	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.4	81.6	79.2	73.4	69.7	64.6	63.8	65.7	67.5	71.4	77.7	80.3	(19)	
		MCWB	67.7	69.0	68.2	65.1	62.1	59.0	57.1	57.9	59.1	60.5	65.6	64.8	(20)	
	2%	DB	78.0	76.4	74.9	70.6	67.5	63.2	62.1	63.2	64.8	67.6	72.1	74.8	(21)	
		MCWB	67.9	67.6	66.7	64.0	61.3	57.8	56.4	57.2	58.6	60.2	63.6	65.3	(22)	
	5%	DB	74.4	73.8	72.2	68.9	65.8	62.1	61.0	61.6	63.1	65.5	69.1	71.6	(23)	
		MCWB	67.2	67.0	66.0	63.0	60.6	57.0	55.8	56.4	57.8	59.6	62.6	64.5	(24)	
	10%	DB	71.8	71.7	70.2	67.4	64.5	61.1	60.0	60.3	61.7	63.8	67.0	69.2	(25)	
		MCWB	66.0	65.6	64.8	62.2	59.7	56.4	55.1	55.5	56.9	58.5	61.4	63.2	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.8	71.3	70.3	67.4	63.9	60.9	59.2	59.8	61.0	63.2	67.1	68.4	(27)	
		MCDB	76.8	77.1	75.0	70.2	66.8	62.9	61.5	62.8	64.6	67.0	73.0	73.5	(28)	
	2%	WB	69.6	69.0	68.4	65.3	62.8	59.4	57.7	58.3	59.8	61.3	65.0	66.6	(29)	
		MCDB	74.8	74.3	72.7	68.5	66.0	61.8	60.5	61.7	63.5	65.3	70.4	71.7	(30)	
	5%	WB	68.0	67.5	67.0	64.1	61.7	58.3	56.8	57.3	58.6	60.1	63.4	65.2	(31)	
		MCDB	73.2	72.4	71.1	67.2	64.9	61.1	59.9	60.7	62.3	64.3	68.2	70.2	(32)	
	10%	WB	66.5	66.4	65.6	63.0	60.6	57.3	55.9	56.3	57.5	59.1	61.9	63.8	(33)	
		MCDB	71.5	71.0	69.7	66.4	63.8	60.4	59.2	59.9	61.2	63.3	66.5	68.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	8.2	7.6	6.4	5.3	4.6	5.0	5.7	6.4	7.5	8.3	8.7	(35)	
		MCDBR	13.2	11.4	10.4	7.8	6.4	5.2	5.8	7.0	8.4	10.1	11.7	12.7	(36)	
	5% WB	MCWBR	6.7	6.3	6.2	5.3	4.8	4.6	5.0	5.1	5.8	6.4	6.3	6.7	(37)	
		MCWBR	11.9	10.3	9.7	6.9	6.0	4.8	5.5	6.7	8.0	9.2	11.0	11.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.342	0.340	0.328	0.320	0.313	0.307	0.302	0.309	0.336	0.340	0.339	0.335	(40)	
		taud	2.591	2.609	2.630	2.644	2.638	2.634	2.650	2.625	2.533	2.526	2.557	2.595	(41)	
	Ebn at Noon		315	309	301	286	270	263	272	285	293	305	314	318	(42)	
		Edh at Noon	33	31	28	25	22	21	21	25	31	33	34	33	(43)	
(44) All-Sky Solar Radiation	RadAvg		2361	2043	1637	1176	825	676	741	1029	1432	1832	2161	2329	(44)	
	RadStd		104	88	69	70	41	36	36	66	98	110	129	113	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.74	N/A	N/A	+1.57	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (12 neighbors)		+0.59	N/A	N/A	N/A	N/A	N/A	N/A	-155	+230	+94

Nomenclature: See separate page