

NEPTUNE ISLANDS, Australia

WMO: 948040

Lat: 35.336S

Lon: 136.118E

Elev: 32

StdP: 100.94

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.4	10.8	3.7	4.9	12.1	4.4	5.2	12.4	21.1	12.8	19.7	12.8	9.5	230	0.768

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.6	25.6	19.6	24.0	19.3	22.7	18.8	20.8	23.6	20.0	22.7	19.4	22.0	6.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.6	22.1	19.0	13.9	21.4	18.3	13.3	20.9	60.3	23.7	57.7	22.9	55.4	22.0	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.4	16.3	14.5	DB	8.4	30.9	0.9	2.5	7.8	32.8	7.2	34.3	6.7	35.7	6.1	37.5	(4)
(5)			WB	6.3	22.1	1.1	1.1	5.5	22.9	4.8	23.6	4.2	24.2	3.4	25.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	19.2	19.3	18.6	17.4	16.0	14.3	13.6	13.6	14.1	15.1	16.4	17.8
	DBStd	2.66	2.06	1.83	1.85	1.57	1.49	1.30	1.36	1.44	1.52	1.70	2.01	1.99
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	887	11	7	17	37	74	119	147	147	126	103	64	35
	CDD10.0	2288	286	261	266	221	186	131	112	112	124	157	193	241
	CDD18.3	134	38	35	25	8	2	0	0	0	0	2	8	17
	CDH23.3	222	87	51	32	1	0	0	0	0	0	1	16	35
CDH26.7	32	16	7	3	0	0	0	0	0	0	0	2	4	
Wind	WSAvg	8.1	7.9	7.7	7.4	7.1	7.9	8.5	9.5	9.0	8.7	8.0	7.8	7.8
Precipitation	PrecAvg	467	14	12	19	36	57	71	82	67	48	26	18	16
	PrecMax	643	144	74	88	151	108	155	157	131	143	74	71	64
	PrecMin	299	0	0	0	4	18	17	28	23	10	0	1	1
	PrecStd	90	23	16	21	32	22	36	35	24	27	18	14	14
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.5	27.5	26.2	23.0	20.9	18.1	17.7	18.7	19.7	21.9	25.4	26.8
		MCWB	19.8	20.5	20.1	18.4	16.7	15.0	13.9	14.4	15.0	15.8	18.6	18.2
	2%	DB	25.5	24.7	23.8	21.4	19.7	17.3	16.7	17.3	18.2	19.8	22.3	23.8
		MCWB	20.0	19.8	19.3	17.8	16.3	14.3	13.6	14.0	14.8	15.7	17.5	18.5
	5%	DB	23.5	23.2	22.4	20.5	18.8	16.7	16.1	16.4	17.3	18.6	20.6	22.0
		MCWB	19.6	19.4	18.9	17.2	15.9	13.9	13.2	13.5	14.3	15.3	17.0	18.0
	10%	DB	22.1	22.1	21.2	19.7	18.1	16.2	15.5	15.7	16.5	17.7	19.4	20.7
		MCWB	18.9	18.7	18.2	16.8	15.4	13.5	12.8	13.1	13.8	14.7	16.3	17.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	21.8	21.3	19.7	17.7	16.0	15.1	15.4	16.1	17.4	19.5	20.2
		MCDB	24.9	25.1	23.9	21.2	19.4	17.2	16.4	17.1	18.1	19.4	22.8	23.0
	2%	WB	20.9	20.5	20.2	18.5	17.1	15.2	14.3	14.6	15.5	16.3	18.3	19.2
		MCDB	23.8	23.5	22.6	20.3	18.9	16.6	15.8	16.5	17.5	18.5	21.3	22.0
	5%	WB	20.0	19.7	19.4	17.8	16.5	14.6	13.8	14.0	14.8	15.6	17.5	18.5
		MCDB	22.9	22.5	21.7	19.6	18.3	16.2	15.5	16.0	16.8	17.9	20.1	21.2
	10%	WB	19.2	19.1	18.7	17.2	15.9	14.1	13.3	13.5	14.2	15.0	16.6	17.7
		MCDB	21.9	21.7	20.9	19.1	17.7	15.8	15.1	15.5	16.2	17.4	19.2	20.4
Mean Daily Temperature Range	5% DB	MDBR	5.0	4.6	4.2	3.5	3.0	2.5	2.8	3.2	3.6	4.2	4.6	4.8
		MCDBR	7.3	6.3	5.8	4.4	3.6	2.9	3.2	3.9	4.6	5.6	6.5	7.1
		MCWBR	3.7	3.5	3.4	2.9	2.6	2.6	2.8	2.8	3.2	3.6	3.5	3.7
	5% WB	MCDBR	6.6	5.7	5.4	3.8	3.3	2.7	3.1	3.7	4.4	5.1	6.1	6.4
		MCWBR	3.8	3.5	3.4	3.0	2.7	2.6	3.0	3.0	3.3	3.6	3.6	3.8
Clear-Sky Solar Irradiance	taub	0.342	0.340	0.328	0.320	0.313	0.307	0.302	0.309	0.336	0.340	0.339	0.335	
	taud	2.591	2.609	2.630	2.644	2.638	2.634	2.650	2.625	2.533	2.526	2.557	2.595	
	Ebn at Noon	994	974	950	902	852	829	857	900	925	963	990	1004	
	Edh at Noon	104	98	89	78	69	65	67	78	97	105	107	104	
All-Sky Solar Radiation	RadAvg	7.44	6.44	5.16	3.71	2.60	2.13	2.33	3.25	4.51	5.78	6.81	7.34	
	RadStd	0.33	0.28	0.22	0.22	0.13	0.11	0.11	0.21	0.31	0.35	0.41	0.36	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.41	N/A	N/A	+0.87	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	+0.33	N/A	N/A	N/A	N/A	N/A	N/A	-86	+128	+52

Nomenclature: See separate page