

EDITHBURGH, Australia

WMO: 948090

Lat: 35.1122S

Lon: 137.7394E

Elev: 23

StdP: 14.68

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	40.4	42.8	32.9	27.5	58.8	35.2	30.1	54.6	31.8	56.8	29.0	57.0	6.4	0	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.4	89.8	66.1	84.4	65.6	80.3	65.3	70.5	78.9	68.8	77.6	67.4	76.1	15.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.2	103.8	73.0	66.0	96.0	72.5	64.4	90.5	70.9	34.5	78.5	33.1	77.8	31.9	76.2	95.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.8	24.9	22.6	DB	36.1	103.8	1.5	4.5	35.0	107.1	34.1	109.7	33.2	112.3	32.1	115.6	(4)
(5)			WB	35.3	77.0	1.6	7.1	34.1	82.1	33.2	86.3	32.3	90.3	31.1	95.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.6	69.0	69.1	66.7	62.7	58.1	54.1	52.2	52.6	55.1	59.2	63.2	66.0	(6)	
	DBStd	7.58	5.59	5.06	4.82	4.36	3.62	3.08	2.92	3.32	4.38	5.52	5.64	5.66	(7)	
	HDD50	30	0	0	0	0	0	5	12	10	3	0	0	0	(8)	
	HDD65	2117	10	7	29	94	218	328	397	386	299	199	102	48	(9)	
	CDD50	3908	589	536	518	382	251	127	80	90	157	286	395	497	(10)	
	CDD65	519	134	123	82	27	4	0	0	3	20	47	79		(11)	
	CDH74	2926	803	602	380	113	16	0	0	3	27	158	307	517	(12)	
	CDH80	1071	329	204	108	35	2	0	0	1	5	61	113	213	(13)	
(14) Wind	WSAvg	12.2	14.6	14.1	12.8	11.1	10.7	10.8	11.2	11.1	11.3	12.2	13.1	13.7	(14)	
(15) Precipitation	PrecAvg	15.4	0.6	0.6	0.6	1.2	1.8	2.0	2.3	2.0	1.7	1.3	0.7	0.7	(15)	
	PrecMax	23.3	3.3	3.7	2.0	4.8	4.0	4.4	3.9	4.1	4.6	2.8	3.3	2.4	(16)	
	PrecMin	10.4	0.0	0.0	0.0	0.0	0.4	0.4	0.9	0.6	0.2	0.1	0.0	0.1	(17)	
	PrecStd	3.2	0.6	0.8	0.6	1.1	0.9	0.9	0.9	0.8	0.9	0.8	0.7	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.3	93.6	90.0	84.3	75.6	65.6	64.8	70.1	77.9	88.1	90.5	95.7	(19)	
		MCWB	67.9	68.5	65.6	61.5	58.0	56.1	53.7	55.8	57.0	63.4	62.5	66.5	(20)	
	2%	DB	88.0	86.0	82.2	76.1	69.2	62.6	61.5	63.8	69.3	77.4	82.1	85.5	(21)	
		MCWB	67.1	67.0	66.1	61.6	58.7	55.8	53.4	54.7	56.3	59.5	63.8	64.7	(22)	
	5%	DB	81.9	80.7	77.9	72.1	66.2	60.9	59.4	60.8	65.3	71.2	76.0	79.0	(23)	
		MCWB	67.1	66.8	65.7	61.7	58.4	55.0	53.3	53.8	56.5	59.5	62.2	64.3	(24)	
	10%	DB	77.2	76.6	74.1	69.4	64.1	59.4	57.8	58.7	62.3	67.2	71.7	74.2	(25)	
		MCWB	66.1	66.5	64.8	60.9	57.7	54.1	52.6	52.9	55.5	58.5	61.3	63.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.4	73.4	71.5	66.5	63.8	59.4	58.2	59.5	61.4	67.2	68.3	70.0	(27)	
		MCDB	80.0	81.0	77.7	73.3	65.3	62.4	60.2	63.1	67.1	71.9	80.2	81.8	(28)	
	2%	WB	70.1	70.4	68.9	64.7	61.5	57.5	56.1	56.5	59.2	62.9	65.4	67.2	(29)	
		MCDB	79.4	78.7	76.2	71.1	65.4	60.9	58.7	60.7	65.0	71.3	75.6	77.7	(30)	
	5%	WB	68.3	68.7	67.1	63.4	59.9	56.2	54.6	55.0	57.6	60.7	63.7	65.5	(31)	
		MCDB	78.5	76.9	74.6	69.6	64.3	59.7	57.7	59.2	63.1	67.6	72.8	74.9	(32)	
	10%	WB	66.6	67.3	65.6	62.1	58.4	55.0	53.3	53.8	56.1	59.1	62.1	64.0	(33)	
		MCDB	76.0	75.2	72.8	68.2	62.8	58.5	56.7	57.8	61.3	65.6	70.3	72.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	11.4	11.1	11.7	11.2	10.5	11.4	12.7	13.9	14.6	13.6	13.6	(35)	
		MCDBR	23.4	20.2	19.3	18.1	15.6	12.6	13.7	16.6	19.7	23.6	23.1	24.3	(36)	
	5% WB	MCWBR	7.2	6.7	7.5	8.3	8.9	8.1	9.0	9.9	10.3	8.3	8.2		(37)	
		MCWBR	18.7	15.8	15.9	14.8	13.4	11.7	12.6	14.9	16.7	19.5	19.1	19.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.348	0.342	0.323	0.317	0.314	0.301	0.301	0.307	0.335	0.341	0.344	0.338	(40)	
		taud	2.546	2.582	2.634	2.635	2.617	2.641	2.636	2.607	2.514	2.501	2.522	2.562	(41)	
	Ebn at Noon		313	308	303	287	270	266	272	286	294	305	313	318	(42)	
		Edh at Noon	35	32	28	25	23	21	22	25	31	34	35	34	(43)	
(44) All-Sky Solar Radiation	RadAvg		2392	2081	1680	1223	846	700	762	1046	1436	1849	2193	2342	(44)	
	RadStd		118	96	65	70	36	39	33	62	109	117	105	94	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (26 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-176	+290	+126	(47)

Nomenclature: See separate page