

THE LIMESTONE, Australia

WMO: 948130

Lat: 36.9656S

Lon: 139.7164E

Elev: 59

StdP: 14.66

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 39.3	(c) 41.4	(d) 33.6	(e) 28.3	(f) 50.2	(g) 35.6	(h) 30.6	(i) 49.0	(j) 35.0	(k) 52.6	(l) 32.3	(m) 52.3	(n) 8.7	(o) 70	(p) 0.675

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 17.0	(c) 89.8	(d) 64.3	(e) 84.6	(f) 63.8	(g) 79.7	(h) 62.6	(i) 67.8	(j) 80.9	(k) 66.0	(l) 77.8	(m) 64.6	(n) 75.0	(o) 13.6	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.2	89.9	70.4	62.4	84.6	68.4	61.1	80.5	67.3	32.2	80.9	30.8	77.8	29.7	75.0	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 30.5	(b) 27.8	(c) 25.5	(e) 35.7	(f) 98.6	(g) 1.5	(h) 3.9	(i) 34.7	(j) 101.4	(k) 33.8	(l) 103.7	(m) 33.0	(n) 105.9	(o) 31.9	(p) 108.8		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.9	64.9	65.2	62.7	58.9	55.4	52.1	51.3	51.9	53.8	56.3	59.7	62.6
	DBStd	6.76	6.07	5.83	5.47	4.28	3.69	3.36	3.12	3.06	3.46	4.58	5.52	5.66
	HDD50	65	0	0	0	0	3	17	23	16	5	1	0	0
	HDD65	2866	72	59	114	191	299	386	425	408	337	274	183	118
	CDD50	2935	463	426	394	267	169	81	64	74	118	198	291	390
	CDD65	260	70	65	43	8	1	0	0	0	0	6	24	43
	CDH74	2550	727	561	359	61	3	0	0	0	2	80	273	484
	CDH80	1006	330	225	126	10	0	0	0	0	0	18	91	206
Wind	WSAvg	13.6	14.8	14.1	12.9	11.9	12.3	12.7	13.9	13.9	14.0	13.8	14.0	14.2
Precipitation	PrecAvg	21.7	0.7	0.7	0.8	1.5	2.4	3.2	3.7	2.9	2.2	1.3	1.0	1.0
	PrecMax	30.6	2.3	2.3	2.7	2.7	5.0	4.9	6.1	5.2	4.3	2.7	2.9	4.0
	PrecMin	13.7	0.0	0.0	0.1	0.4	0.6	1.1	1.7	0.9	1.2	0.2	0.1	0.2
	PrecStd	4.2	0.6	0.7	0.6	0.6	1.1	1.1	1.4	1.3	0.9	0.8	0.6	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.4	94.1	90.0	80.5	70.6	62.3	60.7	64.7	70.6	82.2	88.9	93.8
		MCWB	66.3	66.9	63.4	61.1	58.1	57.0	55.7	55.5	58.3	61.1	63.4	64.7
	2%	DB	89.2	87.1	83.2	74.3	65.7	60.1	58.5	60.8	65.6	74.9	81.8	85.8
		MCWB	64.6	65.2	63.3	59.4	57.9	55.6	54.0	54.8	56.9	59.3	62.1	62.9
	5%	DB	82.1	80.5	77.1	69.7	63.2	58.8	57.3	58.7	62.6	69.3	75.8	78.8
		MCWB	63.9	64.2	61.8	59.3	57.6	54.8	53.2	54.1	56.2	57.8	60.8	61.6
	10%	DB	75.7	75.4	71.8	66.2	61.5	57.6	56.3	57.2	60.0	65.0	70.1	72.7
		MCWB	62.9	63.4	61.0	58.6	56.8	53.9	52.5	52.8	54.9	56.9	59.4	61.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.2	71.0	67.5	64.1	61.3	59.1	56.9	57.6	61.8	63.0	66.9	68.5
		MCDB	83.2	81.4	80.3	71.4	64.3	60.6	59.3	60.7	65.8	74.9	80.6	80.9
	2%	WB	67.4	67.8	65.2	62.5	59.9	56.9	55.3	56.0	58.6	60.8	64.1	65.5
		MCDB	81.5	79.6	75.8	68.4	63.0	58.8	57.4	59.1	63.4	70.1	75.8	78.1
	5%	WB	65.7	65.8	63.7	61.0	58.7	55.7	54.1	54.7	57.0	59.1	62.0	63.7
		MCDB	77.0	76.7	73.0	66.5	62.1	58.0	56.5	57.8	61.2	67.1	72.5	74.6
	10%	WB	63.9	64.1	62.2	59.6	57.5	54.5	53.1	53.5	55.5	57.4	60.2	62.0
		MCDB	73.8	73.3	70.2	65.1	61.0	57.1	55.7	56.6	59.3	64.1	69.3	71.5
Mean Daily Temperature Range	5% DB	MDBR	17.0	16.3	15.4	14.2	11.1	10.0	9.1	9.9	11.6	15.0	16.5	16.5
		MCDBR	28.9	25.7	24.9	20.9	14.2	10.9	9.3	12.2	17.1	25.4	28.1	29.1
		MCWBR	10.3	9.9	10.2	10.4	9.4	8.6	7.5	8.9	11.0	13.3	12.0	11.2
	5% WB	MCDBR	21.3	20.5	18.6	15.0	11.3	9.3	8.6	11.1	13.6	20.2	23.0	21.8
		MCWBR	10.0	9.4	9.3	9.6	8.7	8.2	7.7	8.7	9.9	11.7	11.2	10.3
Clear-Sky Solar Irradiance	taub		0.340	0.337	0.323	0.317	0.307	0.304	0.308	0.317	0.337	0.355	0.338	0.336
	taud		2.538	2.558	2.597	2.602	2.612	2.601	2.585	2.550	2.484	2.429	2.512	2.539
	Ebn at Noon		315	309	301	284	269	260	265	279	292	299	314	318
	Edh at Noon		35	32	29	25	22	21	22	26	32	36	35	35
All-Sky Solar Radiation	RadAvg		2397	2081	1654	1152	770	626	678	968	1371	1807	2146	2366
	RadStd		115	103	67	73	41	39	35	52	111	116	85	127

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.63	N/A	N/A	N/A	N/A	N/A	N/A	-200	+238	N/A
(47) Regional (14 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-205	+245	+65

Nomenclature: See separate page