

STRATHALBYN, Australia

WMO: 948140

Lat: 35.2836S

Lon: 138.8933E

Elev: 192

StdP: 14.59

Time Zone: 9.50 (AUA)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.0	39.9	27.8	21.9	75.4	30.8	25.2	67.6	30.7	57.6	27.3	57.6	6.2	330	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.6	98.8	65.4	94.0	64.1	89.0	63.2	69.2	86.2	67.4	83.9	65.8	82.0	15.1	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	93.5	72.1	62.4	85.0	70.7	60.5	79.4	70.1	33.4	86.2	31.9	83.5	30.6	82.4	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
25.5	22.7	20.3	DB	34.1	106.9	1.9	3.5	32.7	109.4	31.6	111.5	30.5	113.5	29.1	116.1	
			WB	32.7	73.1	1.8	3.3	31.4	75.4	30.4	77.3	29.4	79.2	28.1	81.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.1	69.3	68.5	65.8	61.5	56.6	52.6	51.6	52.3	54.9	58.7	63.2	66.2	(6)
		DBStd	8.48	7.43	6.80	6.57	5.85	4.34	3.66	3.38	4.05	4.79	6.30	7.00	6.94	(7)
		HDD50	61	0	0	0	0	2	15	21	18	4	1	0	0	(8)
		HDD65	2415	26	30	68	138	263	372	414	395	305	219	120	65	(9)
		CDD50	3733	600	517	489	346	207	94	71	88	153	271	395	502	(10)
		CDD65	611	161	127	92	34	3	0	0	3	24	65	102		(11)
		CDH74	7508	1907	1325	1054	410	33	1	0	6	56	439	924	1353	(12)
		CDH80	3738	1086	680	516	141	4	0	0	1	5	162	441	702	(13)
(14)	Wind	WSAvg	10.0	10.9	10.4	10.0	8.5	8.7	8.8	10.0	10.4	10.2	10.3	10.5	10.8	(14)
(15)	Precipitation	PrecAvg	18.9	0.8	1.0	0.9	1.5	1.9	2.2	2.5	2.0	1.7	1.1	0.9		(15)
(16)		PrecMax	25.6	3.0	5.8	3.4	4.5	5.6	5.3	5.2	5.0	3.9	3.9	3.5		(16)
(17)		PrecMin	9.5	0.1	0.0	0.0	0.0	0.2	0.5	0.4	0.6	0.7	0.2	0.0	0.0	(17)
(18)		PrecStd	3.7	0.7	1.2	0.8	1.0	1.0	1.1	1.1	0.8	1.1	0.7	0.7		(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	106.4	101.6	98.9	91.1	78.1	68.0	67.0	73.9	80.3	91.8	97.2	102.3		(19)
(20)		0.4% MCWB	67.2	68.1	65.3	62.0	57.6	55.9	54.3	55.7	58.4	60.5	64.1	64.4		(20)
(21)		2% DB	99.7	95.5	91.9	83.7	72.6	63.4	62.9	68.0	74.9	84.3	90.8	94.9		(21)
(22)		2% MCWB	65.6	65.2	63.8	59.7	56.1	53.5	52.2	53.5	56.5	58.9	62.5	63.2		(22)
(23)		5% DB	92.6	88.9	86.1	78.2	68.4	61.1	60.4	63.9	70.2	78.5	85.0	88.0		(23)
(24)		5% MCWB	65.0	65.0	62.5	58.7	55.8	53.4	51.9	52.6	55.8	57.9	61.0	63.0		(24)
(25)		10% DB	84.4	82.0	78.8	73.3	64.9	59.2	58.3	60.5	65.8	72.6	78.2	81.3		(25)
(26)		10% MCWB	63.9	63.9	61.2	57.9	55.2	52.5	51.2	51.6	54.9	56.3	59.8	61.4		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	71.8	72.9	69.2	65.4	60.6	57.8	56.5	58.1	63.5	64.3	68.0	69.6		(27)
(28)		0.4% MCDB	84.2	89.2	85.9	77.2	69.5	63.1	62.1	68.2	71.8	78.7	87.1	86.5		(28)
(29)		2% WB	68.9	69.1	66.5	63.0	58.8	55.8	54.4	55.5	59.4	61.2	65.2	66.8		(29)
(30)		2% MCDB	88.5	83.8	81.6	74.4	66.7	61.3	59.7	64.7	70.3	76.8	82.6	83.5		(30)
(31)		5% WB	67.0	67.0	64.8	61.3	57.6	54.5	53.1	53.8	57.2	59.2	63.1	64.6		(31)
(32)		5% MCDB	85.7	81.9	79.1	72.6	65.0	59.6	58.4	61.5	67.2	74.1	78.2	81.4		(32)
(33)		10% WB	65.1	65.2	63.1	59.5	56.3	53.3	52.0	52.4	55.3	57.5	60.9	62.7		(33)
(34)		10% MCDB	82.3	79.5	76.3	70.0	63.3	58.0	57.1	59.2	63.9	69.6	75.5	78.5		(34)
(35)	Mean Daily Temperature Range	MDBR	21.6	20.2	20.1	19.4	14.8	12.7	12.6	15.0	18.3	21.0	21.3	21.7		(35)
(36)		5% DB MCDBR	37.3	34.0	32.9	28.8	21.6	16.0	16.4	21.8	27.4	33.3	35.0	35.7		(36)
(37)		5% DB MCWBR	11.7	11.7	11.3	11.3	10.4	9.6	9.9	11.7	13.6	13.3	12.2	12.0		(37)
(38)		5% WB MCDBR	28.5	26.1	24.5	22.0	16.4	12.5	13.3	18.2	23.4	27.3	28.0	27.2		(38)
(39)		5% WB MCWBR	11.1	10.6	10.2	10.3	9.2	8.2	9.1	10.9	13.2	12.4	11.1	11.2		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.343	0.341	0.322	0.314	0.306	0.299	0.298	0.311	0.331	0.344	0.347	0.337		(40)
(41)		taud	2.523	2.541	2.589	2.598	2.602	2.604	2.597	2.544	2.483	2.449	2.473	2.523		(41)
(42)		Ebn at Noon	315	309	303	287	272	266	272	284	295	304	312	318		(42)
(43)		Edh at Noon	35	33	30	26	23	21	22	27	32	36	37	36		(43)
(44)	All-Sky Solar Radiation	RadAvg	2453	2144	1738	1254	853	707	766	1057	1450	1885	2233	2413		(44)
(45)		RadStd	124	109	77	72	36	45	33	63	112	116	99	94		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (25 neighbors)	+0.79	N/A	N/A	N/A	N/A	N/A	N/A	-176	+290	+126	(47)

Nomenclature: See separate page