

STRATHALBYN, Australia

WMO: 948140

Lat: 35.2836S

Lon: 138.8933E

Elev: 59

StdP: 100.62

Time Zone: 9.50 (AUA)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.3	4.4	-2.3	3.1	24.1	-0.7	3.6	19.8	13.7	14.2	12.2	14.2	2.8	330	0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	37.1	18.6	34.4	17.8	31.7	17.3	20.7	30.1	19.6	28.8	18.8	27.8	6.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.4	13.4	22.3	16.9	12.1	21.5	15.9	11.3	21.2	59.8	30.1	56.3	28.6	53.4	28.0	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	10.1	9.1	DB	1.2	41.6	1.1	2.0	0.4	43.0	-0.2	44.2	-0.8	45.3	-1.6	46.7	(4)
(5)			WB	0.4	22.8	1.0	1.8	-0.3	24.1	-0.9	25.2	-1.5	26.2	-2.2	27.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	20.7	20.3	18.8	16.4	13.7	11.4	10.9	11.3	12.7	14.8	17.3	19.0		
	DBStd	4.71	4.13	3.78	3.65	3.25	2.41	2.03	1.88	2.25	2.66	3.50	3.89	3.86		
	HDD10.0	34	0	0	0	0	1	8	12	10	2	1	0	0		
	HDD18.3	1342	14	17	38	77	146	207	230	219	169	122	67	36		
	CDD10.0	2074	333	287	272	192	115	52	39	49	85	151	219	279		
	CDD18.3	339	89	71	51	19	2	0	0	0	2	13	36	57		
	CDH23.3	4171	1059	736	586	228	18	1	0	3	31	244	513	752		
	CDH26.7	2077	603	378	287	78	2	0	0	1	3	90	245	390		
(14) Wind	WSAvg	4.5	4.9	4.7	4.5	3.8	3.9	3.9	4.5	4.6	4.6	4.6	4.7	4.8		
(15) Precipitation	PrecAvg	480	20	25	23	38	48	56	63	64	51	44	28	24		
	PrecMax	650	76	147	87	115	141	134	133	132	128	100	99	88		
	PrecMin	241	3	0	0	1	6	13	11	16	17	4	1	1		
	PrecStd	93	17	30	20	26	25	29	29	29	21	28	19	18		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.3	38.7	37.2	32.9	25.6	20.0	19.4	23.3	26.9	33.2	36.2	39.1		
		MCWB	19.5	20.1	18.5	16.7	14.2	13.3	12.4	13.2	14.7	15.8	17.8	18.0		
	2%	DB	37.6	35.3	33.3	28.7	22.6	17.4	17.2	20.0	23.8	29.1	32.7	35.0		
		MCWB	18.6	18.5	17.7	15.4	13.4	11.9	11.2	11.9	13.6	14.9	17.0	17.4		
	5%	DB	33.7	31.6	30.1	25.6	20.2	16.2	15.8	17.7	21.2	25.9	29.4	31.1		
		MCWB	18.3	18.4	17.0	14.8	13.2	11.9	11.0	11.4	13.2	14.4	16.1	17.2		
	10%	DB	29.1	27.8	26.0	23.0	18.3	15.1	14.6	15.8	18.8	22.6	25.7	27.4		
		MCWB	17.7	17.7	16.2	14.4	12.9	11.4	10.7	10.9	12.7	13.5	15.4	16.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.1	22.7	20.7	18.5	15.9	14.3	13.6	14.5	17.5	18.0	20.0	20.9		
		MCDB	29.0	31.8	30.0	25.1	20.8	17.3	16.7	20.1	22.1	26.0	30.6	30.3		
	2%	WB	20.5	20.6	19.2	17.2	14.9	13.2	12.4	13.1	15.2	16.2	18.4	19.3		
		MCDB	31.4	28.8	27.5	23.5	19.3	16.3	15.4	18.2	21.3	24.9	28.1	28.6		
	5%	WB	19.5	19.5	18.2	16.3	14.2	12.5	11.7	12.1	14.0	15.1	17.3	18.1		
		MCDB	29.9	27.7	26.2	22.6	18.3	15.3	14.7	16.4	19.6	23.4	25.7	27.5		
	10%	WB	18.4	18.4	17.3	15.3	13.5	11.8	11.1	11.3	12.9	14.2	16.1	17.1		
		MCDB	27.9	26.4	24.6	21.1	17.4	14.4	13.9	15.1	17.7	20.9	24.2	25.8		
(35) Mean Daily Temperature Range	MDBR		12.0	11.2	11.2	10.8	8.2	7.0	7.0	8.3	10.2	11.7	11.8	12.0		
	5% DB	MCDBR	20.7	18.9	18.3	16.0	12.0	8.9	9.1	12.1	15.2	18.5	19.4	19.8		
		MCWBR	6.5	6.5	6.3	6.3	5.8	5.3	5.5	6.5	7.6	7.4	6.8	6.7		
	5% WB	MCDBR	15.8	14.5	13.6	12.2	9.1	6.9	7.4	10.1	13.0	15.2	15.6	15.1		
		MCWBR	6.1	5.9	5.7	5.7	5.1	4.6	5.0	6.1	7.4	6.9	6.2	6.2		
(40) Clear-Sky Solar Irradiance	taub		0.343	0.341	0.322	0.314	0.306	0.299	0.298	0.311	0.331	0.344	0.347	0.337		
	taud		2.523	2.541	2.589	2.598	2.602	2.604	2.597	2.544	2.483	2.449	2.473	2.523		
	Ebn at Noon		993	973	955	906	858	838	858	895	930	958	982	1002		
	Edh at Noon		111	105	93	81	71	66	70	84	101	114	116	112		
(44) All-Sky Solar Radiation	RadAvg		7.73	6.76	5.48	3.95	2.69	2.23	2.41	3.33	4.57	5.94	7.04	7.61		
	RadStd		0.39	0.34	0.24	0.23	0.12	0.14	0.10	0.20	0.35	0.37	0.31	0.30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.40	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)		+0.44	N/A	N/A	N/A	N/A	N/A	N/A	-98	+161	+70

Nomenclature: See separate page