

NARACOORTE, Australia

WMO: 948200

Lat: 36.9814S

Lon: 140.7269E

Elev: 165

StdP: 14.61

Time Zone: 9.50 (AUA)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.0	35.4	29.0	23.2	57.3	31.2	25.7	53.4	27.5	53.7	25.4	54.2	3.6	160	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.4	98.5	65.7	94.1	64.7	89.7	63.6	69.1	86.4	67.3	85.2	65.6	83.5	13.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	92.3	72.9	62.1	83.8	70.4	59.9	77.5	69.1	33.3	86.1	31.8	84.7	30.5	84.0	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.2	23.3	21.0	DB	28.6	107.2	1.9	3.6	27.2	109.8	26.1	111.9	25.1	113.9	23.7	116.6	(4)
(5)			WB	28.5	72.4	2.1	2.1	26.9	73.9	25.7	75.1	24.5	76.3	23.0	77.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.9	68.1	67.9	63.8	58.6	54.1	50.1	49.4	50.0	52.8	56.1	60.6	64.5	(6)	
	DBStd	9.19	8.08	7.82	7.54	6.38	5.12	4.00	3.61	4.29	5.16	6.86	7.65	7.67	(7)	
	HDD50	213	0	0	0	3	16	48	57	53	23	12	1	0	(8)	
	HDD65	3123	53	50	118	214	341	448	485	464	369	294	182	105	(9)	
	CDD50	3105	560	502	428	261	142	50	37	54	105	200	318	448	(10)	
	CDD65	541	148	132	80	22	2	0	0	0	2	17	49	89	(11)	
	CDH74	8465	2383	1912	1174	266	14	0	0	1	19	278	846	1572	(12)	
	CDH80	4140	1275	966	546	74	1	0	0	0	1	99	376	802	(13)	
(14) Wind	WSAvg	10.5	11.5	11.3	10.3	9.1	9.4	9.2	10.5	10.5	10.9	10.9	10.9	11.4	(14)	
(15) Precipitation	PrecAvg	22.7	1.1	0.7	1.0	1.6	2.3	2.6	3.3	3.0	2.6	1.9	1.5	1.1	(15)	
	PrecMax	34.8	6.5	2.5	3.7	4.2	5.2	5.4	8.0	6.2	5.2	5.6	3.7	3.8	(16)	
	PrecMin	13.1	0.1	0.0	0.0	0.1	0.3	0.2	1.1	0.8	0.6	0.1	0.3	0.0	(17)	
	PrecStd	4.8	1.1	0.6	0.9	1.1	1.2	1.1	1.4	1.3	1.1	1.1	0.9	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	106.4	101.1	98.8	87.9	75.4	64.7	62.7	69.8	76.8	89.5	95.4	102.9	(19)	
		MCWB	67.5	67.4	65.2	62.1	56.8	54.4	54.0	55.4	59.7	61.4	64.5	65.2	(20)	
	2%	DB	99.0	96.2	91.9	80.9	69.5	61.2	59.6	64.8	70.5	81.6	89.8	95.7	(21)	
		MCWB	65.9	65.5	63.9	59.8	56.5	53.6	52.5	54.0	56.7	59.3	62.6	63.5	(22)	
	5%	DB	93.2	91.4	86.3	76.0	65.8	59.1	57.6	60.7	66.1	75.1	84.0	89.2	(23)	
		MCWB	64.6	65.3	62.4	58.5	55.8	53.2	51.7	52.8	55.7	57.6	62.0	62.3	(24)	
	10%	DB	87.0	85.8	80.1	71.2	62.6	57.2	56.0	57.9	62.6	70.2	77.7	82.9	(25)	
		MCWB	63.3	63.8	61.5	57.4	55.4	52.2	50.9	51.6	54.7	57.1	60.3	60.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.0	72.6	68.7	64.0	60.8	57.4	56.2	57.7	61.6	64.6	68.8	69.3	(27)	
		MCDB	86.3	90.4	84.2	77.6	66.6	60.8	59.5	65.5	71.2	78.1	84.0	86.2	(28)	
	2%	WB	68.9	69.3	66.1	62.2	58.9	55.3	54.1	55.2	58.8	61.6	65.8	66.3	(29)	
		MCDB	88.4	85.5	84.6	74.2	65.0	59.2	57.7	61.3	67.0	74.6	81.4	83.9	(30)	
	5%	WB	66.9	67.1	64.5	60.5	57.5	53.9	52.8	53.7	56.8	59.7	63.7	64.3	(31)	
		MCDB	87.3	84.1	80.1	71.4	63.5	57.7	56.3	59.4	64.1	72.5	78.4	83.9	(32)	
	10%	WB	64.8	65.1	62.8	58.9	56.1	52.7	51.6	52.2	55.0	57.7	61.5	62.5	(33)	
		MCDB	84.4	82.1	77.6	68.7	61.6	56.4	55.1	57.2	61.5	68.4	75.6	80.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	30.4	29.1	26.7	23.4	16.9	14.8	13.6	15.8	18.1	23.4	27.0	29.0	(35)	
		MCDBR	39.5	36.2	34.7	29.5	20.8	16.4	14.5	19.0	23.3	32.0	36.2	40.3	(36)	
	5% WB	MCWBR	12.4	12.1	12.3	12.5	11.1	11.0	9.8	11.5	12.8	14.9	13.9	13.6	(37)	
		MCWBR	31.3	29.3	28.8	24.2	16.8	13.9	13.2	16.9	20.0	26.9	30.1	31.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.339	0.334	0.319	0.313	0.303	0.300	0.300	0.315	0.332	0.355	0.336	0.333	(40)	
		taud	2.487	2.516	2.557	2.555	2.568	2.564	2.558	2.498	2.441	2.374	2.466	2.496	(41)	
	Ebn at Noon	Ebn at Noon	315	310	303	285	269	260	267	279	292	299	314	319	(42)	
		Edh at Noon	36	34	30	26	23	21	23	27	33	39	37	36	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2396	2094	1648	1152	771	630	678	955	1321	1757	2098	2343	(44)	
	RadStd	RadStd	129	105	69	71	38	46	33	49	105	131	128	132	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only			+0.97	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)			+0.67	N/A	N/A	N/A	N/A	N/A	-166	+238	+72

Nomenclature: See separate page