

CAPE WILLOUGHBY, Australia

WMO: 948220

Lat: 35.8425S

Lon: 138.1328E

Elev: 56

StdP: 100.65

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.1	8.9	1.9	4.4	12.5	2.8	4.7	12.3	21.0	14.8	18.7	13.6	7.3	290	0.694

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.1	29.8	17.8	27.0	17.2	24.8	17.1	19.9	24.9	19.1	23.4	18.4	22.4	7.9	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.4	21.2	17.6	12.7	20.7	16.9	12.2	20.0	57.3	25.3	54.6	23.4	52.4	22.6	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.4	15.0	13.3	6.6	35.8	0.7	2.4	6.1	37.5	5.7	38.9	5.3	40.3	4.8	42.0
			5.0	21.4	0.6	1.0	4.6	22.1	4.3	22.7	3.9	23.3	3.5	24.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	18.7	18.8	18.2	16.5	14.9	13.1	12.2	12.1	13.2	14.5	16.1	17.3	(6)
	DBStd	3.32	2.98	2.74	2.57	2.17	1.87	1.43	1.34	1.62	2.08	2.56	2.89	2.81	(7)
	HDD10.0	3	0	0	0	0	0	0	1	1	1	0	0	0	(8)
	HDD18.3	1204	26	19	33	63	109	158	190	192	154	123	83	54	(9)
	CDD10.0	1994	271	247	253	197	152	92	69	68	97	141	182	226	(10)
	CDD18.3	154	39	33	28	9	2	0	0	0	1	6	15	22	(11)
	CDH23.3	852	250	177	147	21	1	0	0	0	0	28	83	146	(12)
	CDH26.7	283	99	64	44	1	0	0	0	0	0	3	19	52	(13)
(14) Wind	WSAvg	7.1	7.0	6.9	6.6	6.2	7.0	7.7	7.9	7.6	7.3	7.0	7.0	6.8	(14)
(15) Precipitation	PrecAvg	559	18	13	24	41	63	76	86	85	60	41	25	23	(15)
	PrecMax	754	94	57	89	127	132	123	172	155	110	122	67	69	(16)
	PrecMin	388	1	0	0	2	19	28	36	23	21	8	4	1	(17)
	PrecStd	95	20	13	21	30	26	23	33	32	25	27	16	16	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	32.7	31.3	25.9	22.3	18.2	16.8	18.7	21.8	26.5	29.2	32.5	(19)
		MCWB	18.5	19.4	18.0	16.5	14.7	13.7	12.8	12.8	14.2	15.2	16.5	17.5	(20)
	2%	DB	29.1	28.3	27.0	23.2	20.2	16.7	15.7	16.8	19.9	23.2	25.8	27.0	(21)
		MCWB	18.2	18.6	17.3	16.1	14.8	13.3	12.1	12.2	13.4	14.4	15.8	16.8	(22)
	5%	DB	25.7	24.8	24.3	21.2	18.7	15.9	15.0	15.7	18.2	20.7	23.0	23.7	(23)
		MCWB	17.8	18.3	17.4	16.0	14.8	12.9	11.8	12.0	13.1	14.1	16.1	16.9	(24)
	10%	DB	22.5	22.2	21.8	19.6	17.5	15.2	14.3	14.7	16.7	18.5	20.3	20.9	(25)
		MCWB	18.2	18.2	17.2	15.7	14.4	12.4	11.5	11.6	12.8	13.8	15.5	16.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.8	21.2	20.1	18.2	16.8	15.0	14.1	14.0	15.6	17.1	18.7	19.4	(27)
		MCDB	27.3	26.6	25.1	21.9	18.7	16.4	15.5	16.2	18.9	21.4	23.3	24.9	(28)
	2%	WB	19.8	19.9	19.1	17.4	16.0	14.1	13.1	13.2	14.5	15.7	17.6	18.2	(29)
		MCDB	25.1	24.8	23.3	20.6	18.3	16.0	14.6	15.4	17.7	20.0	22.4	23.1	(30)
	5%	WB	18.9	19.1	18.2	16.8	15.3	13.4	12.5	12.6	13.8	14.8	16.7	17.4	(31)
		MCDB	23.3	23.0	22.1	19.8	17.6	15.3	14.2	14.8	16.9	18.6	20.9	21.8	(32)
	10%	WB	18.1	18.4	17.5	16.2	14.7	12.9	12.0	12.0	13.1	14.2	15.9	16.7	(33)
		MCDB	22.1	21.8	21.2	19.2	17.1	14.7	13.8	14.2	16.0	17.6	19.6	20.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.7	4.1	4.2	3.7	3.3	3.0	3.3	3.8	4.6	5.0	4.8	4.8	(35)
		MCDBR	11.6	9.9	9.4	6.7	4.8	3.8	4.1	5.0	6.8	9.3	10.3	11.0	(36)
	5% WB	MCWBR	3.5	3.5	3.5	3.3	3.0	2.8	3.1	3.2	3.4	4.0	3.6	3.6	(37)
		MCWBR	8.0	7.1	7.0	5.2	4.3	3.5	3.8	4.6	6.0	7.3	7.9	7.9	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.339	0.338	0.321	0.317	0.310	0.303	0.302	0.313	0.333	0.343	0.339	0.335	(40)
		taud	2.587	2.603	2.647	2.641	2.637	2.638	2.636	2.594	2.530	2.506	2.548	2.581	(41)
	Ebn at Noon	Ebn at Noon	996	976	956	902	853	831	853	892	926	959	990	1004	(42)
		Edh at Noon	104	98	87	78	69	64	68	80	97	107	107	105	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.42	6.40	5.16	3.70	2.53	2.08	2.26	3.16	4.40	5.70	6.79	7.31	(44)
	RadStd	RadStd	0.36	0.32	0.22	0.23	0.12	0.12	0.12	0.18	0.34	0.36	0.27	0.33	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (22 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-99	+158	+66

Nomenclature: See separate page