

CAPE NELSON, Australia

WMO: 948260

Lat: 38.4306S

Lon: 141.5436E

Elev: 47

StdP: 100.77

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.1	7.1	1.8	4.3	10.4	2.6	4.6	10.4	16.3	11.5	14.6	11.7	4.0	0	0.651

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.9	29.3	18.4	26.3	17.2	23.6	16.9	20.1	25.2	19.0	23.1	18.2	21.6	6.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	20.8	17.9	12.9	19.8	17.1	12.3	19.3	57.7	25.1	54.4	23.1	51.8	21.8	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.9	12.4	11.1	DB	3.8	37.5	0.8	2.5	3.2	39.2	2.7	40.7	2.3	42.1	1.7	43.9	(4)
			WB	2.9	22.6	0.9	2.2	2.2	24.2	1.7	25.5	1.2	26.7	0.5	28.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	17.6	17.9	16.9	15.1	13.4	11.6	11.1	11.5	12.5	13.7	14.8	16.1	(6)
(7)		DBStd	3.30	2.79	2.70	2.72	2.32	1.94	1.54	1.45	1.70	2.18	2.79	2.77	2.73	(7)
(8)		HDD10.0	16	0	0	0	0	1	3	6	4	1	1	0	0	(8)
(9)		HDD18.3	1561	47	36	61	102	153	201	224	213	177	151	114	83	(9)
(10)		CDD10.0	1596	235	220	215	154	107	52	41	49	76	114	146	188	(10)
(11)		CDD18.3	98	23	22	18	6	1	0	0	0	1	6	9	13	(11)
(12)		CDH23.3	665	159	122	119	32	2	0	0	0	4	54	71	100	(12)
(13)	CDH26.7	244	62	49	47	8	0	0	0	0	0	16	23	40	(13)	
(14)	Wind	WSAvg	6.1	5.9	5.9	5.7	5.4	6.0	6.0	6.6	6.5	6.4	6.5	6.2	6.1	(14)
(15)	Precipitation	PrecAvg	774	36	27	44	59	77	98	112	98	81	61	48	44	(15)
(16)		PrecMax	965	110	108	171	161	193	187	226	204	142	122	121	104	(16)
(17)		PrecMin	511	6	2	5	8	21	23	53	18	29	6	14	6	(17)
(18)		PrecStd	115	27	22	29	32	41	35	37	38	30	32	24	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	32.7	32.0	27.2	21.9	17.5	16.5	20.0	23.6	28.7	29.9	31.8	(19)
(20)		MCWB	19.1	19.5	18.5	16.5	14.6	13.2	12.2	13.3	15.4	16.1	17.6	19.8	(20)	
(21)		2%	DB	27.5	26.9	26.4	22.9	19.3	15.6	14.9	17.0	20.4	24.0	25.0	25.8	(21)
(22)		MCWB	18.7	17.9	17.0	15.4	13.9	12.7	11.8	12.2	13.7	14.8	16.6	17.2	(22)	
(23)		5%	DB	23.7	23.3	22.5	19.9	17.4	14.7	14.0	15.4	17.7	20.5	21.3	21.9	(23)
(24)		MCWB	18.3	18.2	17.0	14.9	13.6	12.3	11.4	11.8	13.2	14.2	16.2	17.3	(24)	
(25)	10%	DB	21.0	21.1	20.0	18.1	16.1	14.1	13.3	14.0	15.7	17.4	18.6	19.3	(25)	
(26)		MCWB	17.7	17.8	16.7	14.9	13.5	11.8	10.9	11.4	12.3	13.6	15.6	16.2	(26)	
(27)		0.4%	WB	22.2	21.5	19.9	18.0	16.1	14.5	14.0	14.6	16.7	17.2	19.5	21.3	(27)
(28)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	MADB	24.6	26.7	25.8	22.9	18.4	15.7	15.2	17.0	20.0	24.7	25.1	25.9	(28)	
(29)		2%	WB	20.0	19.9	18.6	16.9	15.2	13.5	12.7	13.2	14.9	15.8	17.8	18.7	(29)
(30)		MADB	24.6	24.6	23.0	19.5	17.2	15.0	13.9	15.4	18.5	21.7	22.1	23.0	(30)	
(31)		5%	WB	18.9	18.8	17.8	16.1	14.6	12.8	12.0	12.5	13.6	14.8	16.7	17.5	(31)
(32)		MADB	22.5	21.9	21.0	18.5	16.4	14.2	13.4	14.5	16.7	18.9	20.4	21.0	(32)	
(33)		10%	WB	17.8	18.1	17.0	15.3	13.9	12.2	11.4	11.8	12.8	13.9	15.7	16.5	(33)
(34)	MADB	20.8	20.5	19.5	17.7	15.8	13.7	12.9	13.7	15.3	17.0	18.5	19.2	(34)		
(35)	Mean Daily Temperature Range	MDBR	5.5	4.9	5.0	5.0	4.3	4.2	4.2	4.7	5.4	5.9	5.3	5.4	(35)	
(36)		5% DB	MCDBR	11.9	10.4	11.1	9.6	6.9	5.3	5.4	7.2	9.7	12.7	11.9	11.9	(36)
(37)		MCWBR	5.1	4.5	4.5	4.8	4.2	4.0	3.8	4.4	5.3	5.8	5.3	5.4	(37)	
(38)		5% WB	MCDBR	9.0	7.9	8.1	6.9	5.4	4.6	4.6	6.1	8.2	10.1	9.4	9.2	(38)
(39)		MCWBR	4.8	4.1	4.1	4.3	3.9	3.8	3.7	4.3	5.0	5.4	5.0	4.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.341	0.340	0.328	0.321	0.309	0.309	0.304	0.317	0.342	0.340	0.338	0.339	(40)	
(41)		taud	2.554	2.565	2.601	2.603	2.617	2.595	2.612	2.573	2.486	2.500	2.533	2.549	(41)	
(42)		Ebn at Noon	991	968	940	884	835	800	831	875	909	957	987	998	(42)	
(43)		Edh at Noon	107	101	90	78	67	63	66	79	99	107	108	108	(43)	
(44)	All-Sky Solar Radiation	RadAvg	7.06	6.00	4.71	3.31	2.22	1.75	1.93	2.79	4.06	5.42	6.33	7.02	(44)	
(45)		RadStd	0.36	0.34	0.24	0.22	0.12	0.11	0.11	0.14	0.27	0.36	0.39	0.46	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.34	N/A	N/A	+1.28	+0.54	+0.76	N/A	-118	+151	+34	(46)	
(47)	Regional (19 neighbors)	+0.42	N/A	N/A	+0.96	+0.42	+0.50	N/A	-93	+126	+35	(47)	

Nomenclature: See separate page