

NHILL, Australia

WMO: 948270

Lat: 36.3092S

Lon: 141.6486E

Elev: 140

StdP: 99.66

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.2	2.3	-4.6	2.6	25.2	-2.8	3.0	24.4	12.3	11.1	11.3	11.8	1.9	160	0.574

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.2	38.3	18.5	35.8	17.8	33.6	17.2	20.6	30.2	19.7	29.5	18.7	28.9	6.3	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.3	13.4	22.3	16.9	12.2	22.0	15.4	11.1	21.6	60.0	30.3	56.6	29.6	53.7	28.6	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	10.2	9.2	DB	-0.6	42.8	1.0	1.5	-1.4	43.8	-2.0	44.7	-2.6	45.6	-3.3	46.6	(4)
(5)			WB	-1.1	22.4	1.0	1.4	-1.8	23.4	-2.4	24.2	-2.9	25.0	-3.6	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.3	22.3	21.7	19.4	15.9	12.3	9.7	9.2	9.8	11.6	14.6	17.8	20.2	(6)	
	DBStd	5.88	4.51	4.33	4.36	3.57	2.63	1.99	1.96	2.34	2.93	4.10	4.56	4.50	(7)	
	HDD10.0	123	0	0	0	1	7	30	38	32	12	3	0	0	(8)	
	HDD18.3	1577	9	13	38	92	189	260	282	264	202	133	66	28	(9)	
	CDD10.0	2069	381	327	292	176	77	20	15	26	62	146	234	315	(10)	
	CDD18.3	482	132	107	72	18	1	0	0	0	1	17	49	86	(11)	
	CDH23.3	6929	1943	1416	903	218	4	0	0	1	30	313	784	1317	(12)	
(13)	CDH26.7	3463	1071	727	413	68	0	0	0	0	4	119	374	687	(13)	
(14)	Wind	WSAvg	4.6	5.2	5.1	4.7	4.1	4.1	3.8	4.2	4.3	4.4	4.8	5.0	5.2	(14)
(15) Precipitation	PrecAvg	413	23	20	20	26	39	42	47	49	46	41	32	23	(15)	
	PrecMax	746	146	103	101	86	111	121	103	97	112	149	96	78	(16)	
	PrecMin	194	2	0	0	0	6	8	10	8	7	5	2	0	(17)	
	PrecStd	108	27	22	21	23	25	24	23	23	27	32	22	18	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.8	39.6	37.3	32.4	23.6	18.1	17.4	22.0	26.7	33.5	37.4	40.4	(19)	
		MCWB	19.3	20.5	17.9	16.7	13.7	11.8	11.4	12.1	13.9	15.7	17.9	18.3	(20)	
	2%	DB	39.0	36.4	34.1	28.4	21.0	16.0	15.5	18.7	23.1	30.0	33.9	36.7	(21)	
		MCWB	19.0	18.6	17.5	15.2	13.1	11.4	10.7	11.3	13.0	14.6	16.6	17.5	(22)	
	5%	DB	35.5	34.1	31.4	25.8	18.8	14.9	14.2	16.1	20.2	26.8	31.2	33.6	(23)	
		MCWB	17.9	18.0	16.8	14.4	12.7	11.1	10.4	10.8	12.2	14.0	15.9	16.5	(24)	
(25) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	32.6	31.3	28.3	23.0	17.1	13.8	13.0	14.5	17.7	23.6	28.0	30.5	(25)	
		MCWB	17.2	17.2	16.2	13.5	12.1	10.6	9.9	10.2	11.4	13.2	15.1	15.8	(26)	
	0.4%	WB	21.9	22.4	20.2	17.4	15.6	13.6	12.7	13.6	15.4	18.0	19.9	20.8	(27)	
		MCDB	29.7	34.3	27.7	25.7	19.4	15.7	15.5	17.7	22.3	25.2	29.9	30.1	(28)	
	2%	WB	20.7	20.5	19.2	16.5	14.4	12.4	11.6	12.2	14.0	16.2	18.4	19.1	(29)	
		MCDB	30.5	30.3	27.3	23.8	18.2	15.0	14.1	16.8	20.1	24.9	28.2	28.5	(30)	
(31) Mean Daily Temperature Range	5%	WB	19.6	19.5	18.2	15.6	13.6	11.6	11.0	11.3	12.9	15.0	17.4	18.0	(31)	
		MCDB	31.0	29.0	28.0	22.8	17.2	14.1	13.3	15.3	18.9	24.6	27.0	29.0	(32)	
	10%	WB	18.5	18.5	17.1	14.6	12.7	10.9	10.2	10.6	11.9	13.8	16.2	17.0	(33)	
		MCDB	30.3	28.3	26.9	21.4	16.2	13.1	12.5	14.0	16.9	22.1	26.2	28.4	(34)	
(35) Clear-Sky Solar Irradiance	5% DB	MDBR	16.2	15.5	14.1	12.5	9.7	8.6	8.0	9.5	11.6	14.4	15.2	15.7	(35)	
		MCDBR	19.7	18.8	17.1	16.0	11.8	9.8	9.1	12.2	15.5	19.2	19.4	19.9	(36)	
	5% WB	MCWBR	6.2	5.8	5.8	6.5	6.0	6.0	5.6	6.7	7.3	7.5	6.3	6.4	(37)	
		MCWBR	15.3	15.0	14.2	12.7	9.0	8.5	8.0	10.4	12.9	15.6	16.0	15.0	(38)	
(40) All-Sky Solar Radiation	5% WB	MCWBR	6.1	5.5	5.8	5.8	5.2	5.6	5.4	6.3	6.8	7.0	6.0	5.9	(39)	
		taub	0.337	0.333	0.316	0.307	0.299	0.292	0.291	0.303	0.322	0.334	0.338	0.327	(40)	
	Edn at Noon	taud	2.493	2.520	2.565	2.569	2.578	2.593	2.593	2.538	2.472	2.448	2.469	2.522	(41)	
		Edn at Noon	997	979	959	908	858	838	860	899	935	967	990	1012	(42)	
(43)	RadAvg	114	107	94	82	71	66	69	83	102	113	116	116	112	(43)	
		RadStd	7.74	6.89	5.49	3.91	2.64	2.13	2.29	3.21	4.41	5.85	6.88	7.61	(44)	
(45)			0.39	0.33	0.25	0.21	0.13	0.15	0.12	0.19	0.33	0.40	0.43	0.36	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (24 neighbors)	+0.41	N/A	N/A	+0.83	N/A	N/A	N/A	-82	+133	+55

Nomenclature: See separate page