

HAMILTON, Australia

WMO: 948290

Lat: 37.6486S

Lon: 142.0636E

Elev: 793

StdP: 14.28

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.5	36.2	30.4	25.2	55.2	32.4	27.6	48.2	29.7	50.4	27.6	50.5	6.6	0	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	24.7	94.4	64.6	89.9	63.7	85.4	62.7	68.3	82.7	66.4	81.8	64.7	80.0	15.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.4	93.1	71.0	61.8	84.9	69.5	59.7	78.8	67.9	33.0	82.6	31.5	81.7	30.1	79.6	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.7	23.9	21.8	DB	31.4	102.9	1.6	3.7	30.2	105.6	29.3	107.7	28.4	109.8	27.2	112.4	(4)
(5)			WB	30.7	71.6	1.5	1.7	29.6	72.8	28.7	73.8	27.8	74.7	26.7	75.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	55.5	65.5	65.9	62.1	56.6	51.7	47.9	46.6	47.5	50.2	53.7	57.8	61.6	(6)
(7)		DBStd	8.95	7.90	7.46	7.05	5.83	4.52	3.43	3.14	3.90	4.64	6.14	7.25	7.34	(7)
(8)		HDD50	406	0	0	0	5	32	81	111	96	51	23	6	1	(8)
(9)		HDD65	3812	89	73	145	262	414	513	569	541	446	357	244	159	(9)
(10)		CDD50	2428	481	444	377	204	84	18	7	20	55	139	239	360	(10)
(11)		CDD65	358	105	98	56	11	0	0	0	0	0	7	27	54	(11)
(12)		CDH74	5175	1555	1263	745	127	1	0	0	0	2	126	436	920	(12)
(13)		CDH80	2319	799	583	305	24	0	0	0	0	0	30	157	421	(13)
(14)	Wind	WSAvg	11.6	12.4	12.3	11.5	10.4	10.9	10.7	11.8	11.6	11.8	11.8	11.7	12.1	(14)
(15)	Precipitation	PrecAvg	24.1	1.5	1.3	1.3	1.9	1.9	2.6	2.7	2.9	2.7	2.0	1.7	1.5	(15)
(16)		PrecMax	33.9	4.4	2.6	2.6	4.6	3.6	4.6	4.7	5.1	6.0	4.0	4.4	4.4	(16)
(17)		PrecMin	16.4	0.2	0.2	0.2	0.4	0.2	0.5	1.2	0.8	1.1	0.3	0.7	0.1	(17)
(18)		PrecStd	4.1	1.1	0.7	0.6	1.0	0.9	1.1	0.8	1.3	1.1	1.1	0.8	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	103.0	98.0	95.0	83.4	70.9	61.1	59.0	65.5	72.1	83.8	90.7	98.1	(19)
(20)			MCWB	66.3	66.1	62.9	59.0	55.6	54.0	51.4	55.1	59.0	60.6	62.7	64.0	(20)
(21)		2%	DB	94.9	92.5	87.8	77.4	65.9	58.0	55.8	60.6	66.8	77.0	84.7	90.7	(21)
(22)			MCWB	64.9	65.1	62.7	58.2	55.1	52.3	50.0	52.0	56.3	59.0	62.6	62.5	(22)
(23)		5%	DB	89.2	87.6	82.4	73.0	62.0	55.8	53.9	57.4	62.5	71.3	79.0	84.3	(23)
(24)			MCWB	64.2	64.1	61.4	56.7	54.2	51.2	49.1	50.6	54.4	57.7	61.0	61.8	(24)
(25)		10%	DB	82.7	82.2	76.9	68.1	59.3	53.9	52.4	54.9	59.3	66.4	72.8	78.1	(25)
(26)			MCWB	62.2	62.9	60.3	55.6	53.3	50.2	48.5	49.4	52.4	55.7	59.6	60.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.5	71.7	67.1	61.9	59.4	56.0	53.7	56.1	61.6	64.1	68.1	68.4	(27)
(28)			MCDWB	84.9	87.1	81.8	75.0	63.5	58.7	57.2	62.5	67.6	75.9	80.5	81.0	(28)
(29)		2%	WB	68.1	68.3	64.7	60.0	57.2	53.5	51.4	53.3	57.4	60.9	65.0	65.7	(29)
(30)			MCDWB	84.5	82.0	79.6	70.7	62.4	56.3	53.9	58.4	64.3	72.2	77.9	81.0	(30)
(31)		5%	WB	66.1	66.2	63.0	58.3	55.4	52.0	50.2	51.5	55.1	58.7	62.6	63.6	(31)
(32)			MCDWB	83.4	81.1	77.2	68.8	60.8	54.7	52.7	56.1	61.6	69.6	74.8	79.1	(32)
(33)		10%	WB	63.9	64.2	61.3	56.7	53.8	50.7	49.1	50.0	53.0	56.6	60.3	61.5	(33)
(34)			MCDWB	80.3	79.3	74.2	65.8	58.3	53.3	51.8	54.2	58.4	65.6	71.8	77.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	26.3	24.7	22.1	18.8	13.8	11.7	11.6	13.6	15.7	19.7	21.9	25.0	(35)
(36)			MCDBR	37.3	34.0	31.4	27.0	18.2	13.9	13.2	17.6	20.8	29.2	32.7	36.9	(36)
(37)			MCWBR	12.0	11.3	11.1	11.3	10.4	9.4	9.1	11.1	12.7	14.8	13.7	13.3	(37)
(38)		5% WB	MCDWB	30.2	27.9	26.0	22.0	15.3	11.5	11.5	15.6	18.6	25.6	27.5	29.7	(38)
(39)			MCWBR	11.9	11.4	10.7	10.8	9.7	8.4	8.6	10.6	12.2	14.3	13.2	12.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.337	0.333	0.318	0.307	0.300	0.293	0.290	0.305	0.326	0.332	0.332	0.327	(40)	
(41)		taud	2.492	2.520	2.559	2.573	2.569	2.576	2.581	2.522	2.449	2.441	2.477	2.516	(41)	
(42)		Ebn at Noon	316	310	302	286	269	262	270	282	294	306	316	320	(42)	
(43)		Edh at Noon	36	34	30	26	22	21	22	26	33	36	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2314	2008	1569	1090	725	584	637	906	1269	1683	2000	2245	(44)	
(45)		RadStd	141	100	77	73	36	46	38	51	91	143	140	135	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.77	N/A	N/A	+1.58	N/A	N/A	N/A	-187	+248	+70

Nomenclature: See separate page