

HAMILTON, Australia

WMO: 948290

Lat: 37.6486S

Lon: 142.0636E

Elev: 242

StdP: 98.45

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.4	2.3	-0.9	3.6	12.9	0.2	3.9	9.0	13.3	10.2	12.4	10.3	2.9	0	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.7	34.7	18.1	32.2	17.6	29.6	17.1	20.1	28.2	19.1	27.7	18.1	26.6	6.8	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.3	21.6	16.6	12.1	20.8	15.4	11.3	19.9	58.9	28.1	55.3	27.6	52.1	26.5	27.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.9	10.7	9.7	DB	-0.3	39.4	0.9	2.0	-1.0	40.9	-1.5	42.1	-2.0	43.2	-2.7	44.7	(4)
(5)			WB	-0.7	22.0	0.9	0.9	-1.4	22.6	-1.9	23.2	-2.3	23.7	-3.0	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.1	18.6	18.8	16.7	13.7	10.9	8.8	8.1	8.6	10.1	12.1	14.3	16.4	(6)	
	DBStd	4.97	4.39	4.14	3.91	3.24	2.51	1.91	1.75	2.16	2.58	3.41	4.03	4.08	(7)	
	HDD10.0	226	0	0	0	3	18	45	62	53	28	13	3	1	(8)	
	HDD18.3	2118	49	41	81	146	230	285	316	301	248	198	136	88	(9)	
	CDD10.0	1349	267	247	209	113	47	10	4	11	31	77	133	200	(10)	
	CDD18.3	199	58	54	31	6	0	0	0	0	4	15	30	30	(11)	
	CDH23.3	2875	864	702	414	71	1	0	0	0	1	70	242	511	(12)	
	CDH26.7	1288	444	324	169	13	0	0	0	0	0	17	87	234	(13)	
(14) Wind	WSAvg	5.2	5.6	5.5	5.2	4.7	4.9	4.8	5.3	5.2	5.3	5.3	5.2	5.4	(14)	
(15) Precipitation	PrecAvg	611	38	32	33	48	47	65	68	74	68	52	44	39	(15)	
	PrecMax	860	111	65	66	118	91	118	119	130	153	102	111	112	(16)	
	PrecMin	417	4	4	6	9	6	12	30	20	28	8	17	3	(17)	
	PrecStd	104	29	17	16	25	24	27	21	33	29	29	20	25	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.4	36.7	35.0	28.5	21.6	16.2	15.0	18.6	22.3	28.8	32.6	36.7	(19)	
		MCWB	19.1	18.9	17.1	15.0	13.1	12.2	10.8	12.8	15.0	15.9	17.1	17.8	(20)	
	2%	DB	34.9	33.6	31.0	25.2	18.8	14.4	13.2	15.9	19.3	25.0	29.3	32.6	(21)	
		MCWB	18.3	18.4	17.0	14.5	12.8	11.3	10.0	11.1	13.5	15.0	17.0	16.9	(22)	
	5%	DB	31.8	30.9	28.0	22.8	16.7	13.2	12.2	14.1	17.0	21.8	26.1	29.1	(23)	
		MCWB	17.9	17.8	16.3	13.7	12.3	10.7	9.5	10.3	12.4	14.3	16.1	16.6	(24)	
	10%	DB	28.2	27.9	25.0	20.0	15.2	12.2	11.3	12.7	15.1	19.1	22.7	25.6	(25)	
		MCWB	16.8	17.2	15.7	13.1	11.9	10.1	9.2	9.7	11.3	13.2	15.3	15.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	22.1	19.5	16.6	15.2	13.3	12.0	13.4	16.5	17.8	20.1	20.2	(27)	
		MCDB	29.4	30.6	27.7	23.9	17.5	14.8	14.0	16.9	19.8	24.4	26.9	27.2	(28)	
	2%	WB	20.1	20.1	18.2	15.5	14.0	12.0	10.8	11.8	14.1	16.1	18.3	18.7	(29)	
		MCDB	29.2	27.8	26.4	21.5	16.9	13.5	12.2	14.7	17.9	22.3	25.5	27.2	(30)	
	5%	WB	18.9	19.0	17.2	14.6	13.0	11.1	10.1	10.8	12.8	14.8	17.0	17.6	(31)	
		MCDB	28.6	27.3	25.1	20.5	16.0	12.6	11.5	13.4	16.4	20.9	23.8	26.2	(32)	
	10%	WB	17.7	17.9	16.3	13.7	12.1	10.4	9.5	10.0	11.7	13.7	15.7	16.4	(33)	
		MCDB	26.9	26.3	23.4	18.8	14.6	11.8	11.0	12.3	14.7	18.7	22.1	25.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.6	13.7	12.3	10.4	7.7	6.5	6.4	7.6	8.7	10.9	12.1	13.9	(35)	
		MCDBR	20.7	18.9	17.4	15.0	10.1	7.7	7.3	9.8	11.6	16.2	18.2	20.5	(36)	
	5% WB	MCWBR	6.7	6.3	6.2	6.3	5.8	5.2	5.0	6.2	7.1	8.2	7.6	7.4	(37)	
		MCWBR	16.8	15.5	14.5	12.2	8.5	6.4	6.4	8.6	10.3	14.2	15.3	16.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.337	0.333	0.318	0.307	0.300	0.293	0.290	0.305	0.326	0.332	0.332	0.327	(40)	
		taud	2.492	2.520	2.559	2.573	2.569	2.576	2.581	2.522	2.449	2.441	2.477	2.516	(41)	
	Ebn at Noon	Ebn at Noon	996	977	953	903	848	825	852	890	926	966	995	1010	(42)	
		Edh at Noon	114	106	94	81	70	65	68	83	103	113	115	112	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.29	6.33	4.95	3.44	2.29	1.84	2.01	2.86	4.00	5.30	6.30	7.08	(44)	
	RadStd	RadStd	0.45	0.31	0.24	0.23	0.11	0.14	0.12	0.16	0.29	0.45	0.44	0.43	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.43	N/A	N/A	+0.88	N/A	N/A	N/A	-104	+138	+39

Nomenclature: See separate page