

PORT FAIRY, Australia

WMO: 948300

Lat: 38.3906S

Lon: 142.2347E

Elev: 10

StdP: 101.20

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.8	4.9	1.8	4.3	7.5	2.7	4.6	8.1	14.7	10.0	13.4	11.0	3.0	0	0.604

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.6	30.5	18.8	26.7	18.0	24.0	17.7	20.4	26.2	19.4	24.2	18.6	22.6	6.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.8	13.6	21.5	17.9	12.9	20.8	17.2	12.3	20.1	58.7	26.4	55.5	24.4	52.9	22.8	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.0	11.6	10.3	1.2	39.0	0.9	2.8	0.5	41.0	0.0	42.6	-0.5	44.2	-1.2	46.3
			0.9	22.7	0.9	1.5	0.2	23.8	-0.3	24.7	-0.8	25.6	-1.5	26.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	18.0	18.2	17.0	14.9	12.8	11.0	10.4	10.9	12.1	13.5	15.1	16.5	(6)
	DBStd	3.60	2.90	2.71	2.67	2.47	2.01	1.73	1.55	1.75	2.10	2.66	2.79	2.90	(7)
	HDD10.0	37	0	0	0	0	2	9	13	9	3	1	0	0	(8)
	HDD18.3	1622	38	28	58	108	171	221	245	230	188	153	107	74	(9)
	CDD10.0	1563	247	231	217	147	90	38	27	38	65	111	153	201	(10)
	CDD18.3	106	27	25	17	6	1	0	0	0	1	4	9	17	(11)
	CDH23.3	803	184	154	121	49	3	0	0	0	5	56	88	142	(12)
	CDH26.7	341	87	72	53	14	0	0	0	0	0	15	32	68	(13)
(14) Wind	WSAvg	5.2	5.5	5.4	5.0	4.7	4.7	4.8	5.1	5.3	5.3	5.4	5.7	5.6	(14)
(15) Precipitation	PrecAvg	702	39	36	46	51	65	83	90	89	74	57	48	40	(15)
	PrecMax	890	133	77	74	107	129	161	133	170	126	122	100	113	(16)
	PrecMin	481	7	6	19	9	14	20	39	34	30	13	18	9	(17)
	PrecStd	108	33	20	15	28	33	31	25	41	25	28	21	23	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.2	35.1	32.8	28.5	22.7	18.0	16.7	20.0	23.7	29.1	30.9	34.0	(19)
		MCWB	20.3	20.2	18.8	16.6	14.8	13.9	12.6	13.7	15.5	17.3	18.8	19.4	(20)
	2%	DB	27.8	27.6	26.4	23.8	19.3	15.9	15.1	17.3	20.2	24.3	25.6	27.0	(21)
		MCWB	19.2	19.1	17.6	15.8	14.1	12.8	12.0	12.5	14.4	16.0	17.9	18.3	(22)
	5%	DB	23.9	23.7	22.3	20.3	17.5	14.8	14.1	15.5	17.8	20.7	21.8	22.5	(23)
		MCWB	18.9	18.8	17.6	15.4	13.7	12.3	11.4	12.0	13.2	14.8	17.0	17.5	(24)
	10%	DB	21.7	21.7	20.4	18.5	16.2	13.9	13.3	14.2	15.9	17.8	19.2	20.4	(25)
		MCWB	17.9	18.2	16.8	15.0	13.3	11.7	10.9	11.3	12.5	14.1	16.0	16.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	21.6	19.9	18.2	16.2	14.6	13.6	14.6	16.5	18.4	20.6	21.2	(27)
		MCDB	27.7	28.7	26.4	24.0	19.1	16.3	15.2	18.4	21.2	25.2	25.0	28.4	(28)
	2%	WB	20.3	20.1	18.9	17.1	15.2	13.5	12.6	13.3	15.0	16.7	18.7	19.1	(29)
		MCDB	25.9	25.2	23.2	20.4	17.7	15.2	14.3	16.1	19.0	22.7	23.6	24.4	(30)
	5%	WB	19.2	19.2	18.1	16.2	14.4	12.7	11.9	12.4	13.8	15.4	17.4	18.0	(31)
		MCDB	23.6	23.2	21.4	19.1	16.7	14.3	13.6	14.9	17.0	19.7	21.4	22.1	(32)
	10%	WB	18.2	18.4	17.3	15.4	13.7	12.0	11.2	11.6	12.8	14.3	16.2	17.1	(33)
		MCDB	21.6	21.6	20.1	18.2	15.8	13.6	12.9	13.8	15.5	17.5	19.2	20.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.3	6.6	6.8	7.4	6.4	6.1	6.0	6.6	7.4	7.9	7.3	7.5	(35)
		MCDBR	13.1	12.0	11.8	11.9	9.2	7.6	7.3	9.3	11.2	14.6	13.7	13.5	(36)
	5% WB	MCWBR	5.8	5.5	5.5	6.2	5.8	5.4	5.1	5.8	6.6	7.5	6.8	6.2	(37)
		MCWBR	10.9	9.7	9.4	9.4	7.8	6.8	6.4	8.4	10.1	12.2	11.5	11.1	(38)
(40) Clear-Sky Solar Irradiance	taub		0.348	0.342	0.332	0.321	0.313	0.309	0.303	0.317	0.342	0.344	0.344	0.340	(40)
		taud	2.510	2.542	2.572	2.585	2.584	2.580	2.597	2.549	2.462	2.464	2.492	2.524	(41)
	Ebn at Noon		984	966	936	884	828	800	832	874	908	953	982	997	(42)
		Edh at Noon	111	103	92	80	69	64	67	81	101	110	113	111	(43)
(44) All-Sky Solar Radiation	RadAvg		7.10	6.08	4.78	3.33	2.22	1.76	1.94	2.79	4.03	5.40	6.29	7.05	(44)
	RadStd		0.39	0.34	0.24	0.22	0.11	0.13	0.12	0.14	0.25	0.37	0.37	0.44	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.31	N/A	N/A	N/A	+0.40	+0.44	N/A	-130	+150	+32
Regional (24 neighbors)		+0.44	N/A	N/A	+0.88	+0.41	N/A	N/A	-117	+150	+40

Nomenclature: See separate page