

MOUNT WILLIAM, AustraliaWMO: **948330**Lat: **37.295S**Lon: **142.604E**Elev: **1150**StdP: **88.25**Time Zone: **10.00 (AUS)**Period: **07-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.5	-0.9	-11.8	1.6	10.3	-7.1	2.4	11.7	20.7	3.6	18.4	4.2	6.2	250	0.847

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.2	28.7	14.9	26.5	14.4	24.6	13.8	17.1	23.3	16.1	22.2	15.3	21.6	5.2	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.5	12.7	18.2	14.3	11.7	17.3	13.1	10.8	16.7	52.6	23.1	49.4	22.1	46.7	21.7	21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.7	15.3	13.7	DB	-2.7	32.7	0.5	2.1	-3.1	34.2	-3.4	35.4	-3.7	36.6	-4.1	38.1	(4)
(5)			WB	-2.9	19.2	0.6	1.0	-3.4	19.9	-3.7	20.5	-4.1	21.1	-4.5	21.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	15.3	14.6	12.8	9.5	6.0	3.7	2.9	3.2	5.2	8.2	10.9	12.9	(6)	
	DBStd	6.09	5.76	5.29	5.25	3.97	2.71	2.01	1.79	2.50	3.17	4.86	5.36	5.52	(7)	
	HDD10.0	1188	12	13	29	58	128	188	221	211	149	97	54	29	(8)	
	HDD18.3	3606	132	127	188	266	382	438	479	468	394	315	229	186	(9)	
	CDD10.0	732	177	143	115	43	4	0	0	1	5	41	82	121	(10)	
	CDD18.3	107	39	24	16	1	0	0	0	0	0	1	8	19	(11)	
	CDH23.3	704	338	144	73	1	0	0	0	0	0	3	31	115	(12)	
	CDH26.7	178	107	29	13	0	0	0	0	0	0	0	2	27	(13)	
(14) Wind	WSAvg	7.2	7.1	7.1	6.6	6.7	7.8	7.6	8.1	7.8	7.5	7.0	7.0	6.6	(14)	
(15) Precipitation	PrecAvg	637	38	34	26	40	52	75	74	80	70	55	50	42	(15)	
	PrecMax	933	168	85	60	103	117	146	117	175	188	113	103	120	(16)	
	PrecMin	397	0	4	5	5	12	27	30	23	30	5	18	5	(17)	
	PrecStd	131	36	20	15	27	24	30	23	39	34	30	22	29	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.6	30.3	28.4	22.1	14.4	9.9	9.1	13.0	17.3	23.4	26.2	30.0	(19)	
		MCWB	15.6	16.4	14.9	12.1	9.4	5.6	5.9	8.0	10.1	12.1	14.4	14.6	(20)	
	2%	DB	29.6	27.0	25.3	18.9	12.6	8.3	7.4	10.4	14.3	20.5	23.9	26.6	(21)	
		MCWB	15.4	14.8	14.0	11.6	8.6	6.2	5.1	6.7	8.9	11.2	13.1	13.9	(22)	
	5%	DB	27.0	25.0	22.9	16.9	11.3	7.2	6.3	8.5	12.4	18.2	21.8	23.9	(23)	
		MCWB	14.6	14.9	13.4	10.6	8.3	5.9	5.1	6.1	7.8	10.0	12.9	13.0	(24)	
	10%	DB	24.7	22.8	20.6	15.2	9.9	6.4	5.4	6.8	10.3	16.1	19.6	21.6	(25)	
		MCWB	13.7	14.0	13.0	10.0	8.0	5.5	4.6	5.3	6.9	9.2	11.9	12.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.5	19.0	16.4	13.8	11.0	8.0	7.6	8.7	11.0	14.0	16.6	17.4	(27)	
		MCDB	24.0	24.3	22.1	19.0	12.3	8.4	8.0	10.6	15.2	19.3	22.4	21.3	(28)	
	2%	WB	17.1	17.1	15.5	12.5	9.9	7.1	6.3	7.4	9.6	12.4	15.0	15.7	(29)	
		MCDB	24.5	22.5	21.2	16.8	11.1	7.6	6.7	9.5	13.0	17.7	20.5	22.0	(30)	
	5%	WB	16.1	16.0	14.6	11.6	9.1	6.4	5.6	6.4	8.5	11.1	13.8	14.5	(31)	
		MCDB	22.6	22.1	20.1	15.2	10.5	6.8	5.9	8.1	11.6	16.0	19.6	21.1	(32)	
	10%	WB	15.1	14.9	13.9	10.7	8.4	5.8	4.9	5.5	7.4	10.1	12.7	13.4	(33)	
		MCDB	22.1	21.3	19.1	14.1	9.6	6.2	5.2	6.6	9.7	15.1	18.1	19.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.2	9.5	7.8	5.8	3.8	3.2	3.1	4.0	5.9	7.8	8.4	9.2	(35)	
		MCDBR	12.0	11.4	9.5	7.7	5.4	4.6	4.1	6.4	8.5	10.3	10.3	11.0	(36)	
	5% WB	MCWBR	5.4	5.5	4.7	4.3	3.9	3.7	3.4	4.5	5.4	5.7	5.7	6.1	(37)	
		MCWBR	10.5	10.1	8.6	7.0	4.6	3.8	3.4	5.5	7.5	9.3	9.1	9.7	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.298	0.291	0.278	0.271	0.265	0.258	0.256	0.268	0.283	0.287	0.291	0.287	(40)	
		taud	2.577	2.621	2.661	2.657	2.645	2.659	2.672	2.613	2.554	2.556	2.584	2.620	(41)	
	Ebn at Noon	Ebn at Noon	1037	1023	999	949	897	877	901	938	977	1015	1038	1053	(42)	
		Edh at Noon	105	96	85	74	65	59	62	76	92	101	103	101	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.45	6.52	5.13	3.58	2.39	1.91	2.08	2.94	4.10	5.43	6.45	7.23	(44)	
	RadStd	RadStd	0.44	0.32	0.25	0.23	0.12	0.15	0.13	0.18	0.29	0.45	0.44	0.40	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	+0.46	N/A	N/A	+0.90	+0.40	N/A	N/A	-124	+163	+47

Nomenclature: See separate page