

BEN NEVIS, AustraliaWMO: **948350**Lat: **37.228S**Lon: **143.201E**Elev: **2871**StdP: **13.23**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.1	32.3	16.0	13.7	58.4	22.6	18.9	57.6	33.9	39.4	30.0	41.6	13.3	210	0.678

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.5	87.1	60.5	82.8	59.4	79.1	58.1	64.5	76.1	62.5	75.4	60.8	73.6	9.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
61.2	89.9	66.8	58.6	81.7	65.6	56.2	75.0	64.0	31.1	75.6	29.6	75.2	28.3	73.8	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.8	25.3	22.7	DB	29.6	94.8	1.5	4.9	28.5	98.4	27.6	101.2	26.8	103.9	25.7	107.5	(4)
(5)			WB	28.9	67.7	1.6	2.8	27.7	69.8	26.8	71.4	25.8	73.0	24.7	75.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.4	62.3	62.1	57.3	51.8	45.3	41.4	39.7	40.8	44.6	48.8	53.7	57.7	(6)	
	DBStd	10.79	9.87	9.21	8.81	7.12	5.06	3.63	3.27	4.32	5.81	8.19	9.30	9.75	(7)	
	HDD50	1521	7	6	23	61	164	258	319	288	185	123	60	27	(8)	
	HDD65	5610	176	154	274	398	610	708	784	751	612	506	361	276	(9)	
	CDD50	1665	388	345	249	116	19	0	0	2	23	88	170	265	(10)	
	CDD65	279	91	73	35	3	0	0	0	0	6	22	49		(11)	
	CDH74	2261	889	551	220	11	0	0	0	0	0	27	149	414	(12)	
	CDH80	718	346	159	52	2	0	0	0	0	0	2	27	130	(13)	
(14) Wind	WSAvg	12.2	12.0	11.8	11.7	11.1	12.0	12.5	12.7	12.5	12.9	12.4	12.2	12.1	(14)	
(15) Precipitation	PrecAvg	22.5	1.5	1.3	1.0	1.5	1.9	2.7	2.6	2.6	2.6	1.7	1.7	1.7	(15)	
	PrecMax	34.3	6.3	3.2	2.4	3.9	4.2	6.1	4.7	5.7	6.2	3.8	3.8	4.9	(16)	
	PrecMin	14.4	0.0	0.0	0.2	0.1	0.4	0.9	1.2	0.7	0.8	0.0	0.5	0.1	(17)	
	PrecStd	5.1	1.4	0.9	0.6	1.0	1.0	1.3	0.9	1.3	1.3	1.1	0.9	1.2	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.9	90.6	86.4	74.8	61.5	52.8	50.8	56.8	66.8	77.8	83.8	90.2	(19)	
		MCWB	62.5	61.6	59.6	56.4	50.4	47.0	45.6	48.1	52.2	55.5	59.2	60.0	(20)	
	2%	DB	88.3	84.3	79.6	69.2	58.1	50.1	47.7	52.8	61.2	71.5	78.2	83.4	(21)	
		MCWB	61.1	60.5	58.1	53.5	49.4	46.2	44.0	45.4	50.4	53.8	56.8	58.9	(22)	
	5%	DB	83.1	80.4	75.3	65.5	55.4	48.0	45.8	49.7	57.3	66.6	73.7	78.3	(23)	
		MCWB	59.7	59.9	57.3	52.6	48.4	45.2	43.4	44.2	48.2	51.3	55.2	56.5	(24)	
	10%	DB	78.3	76.6	71.1	62.2	52.5	46.3	44.2	47.0	53.7	62.6	69.2	73.7	(25)	
		MCWB	58.2	58.7	55.8	51.5	47.5	44.4	42.4	42.9	47.2	50.2	54.3	55.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.1	68.0	62.8	58.5	53.1	49.3	47.9	49.7	54.3	58.9	63.2	64.0	(27)	
		MCDB	79.9	78.4	74.4	70.2	57.6	50.4	49.0	54.7	61.7	71.1	75.0	78.0	(28)	
	2%	WB	64.4	64.8	60.9	55.8	51.2	47.4	45.4	46.8	51.8	55.6	60.1	61.2	(29)	
		MCDB	78.4	73.9	73.4	64.3	55.1	48.8	46.3	50.7	58.3	65.8	71.1	75.4	(30)	
	5%	WB	62.4	62.7	59.2	54.4	49.8	45.9	44.0	45.2	49.7	53.3	57.9	59.0	(31)	
		MCDB	76.6	74.2	70.3	62.1	53.3	47.2	45.0	48.3	56.0	63.4	68.4	73.6	(32)	
	10%	WB	60.4	60.5	57.5	52.9	48.4	44.8	42.7	43.6	47.8	51.2	55.7	57.1	(33)	
		MCDB	74.9	71.9	68.7	60.2	51.7	46.0	43.8	46.2	52.9	60.8	67.0	70.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	20.5	19.0	16.1	12.3	8.0	6.2	6.3	8.3	11.6	14.9	17.2	19.4	(35)	
		MCDBR	24.6	21.9	19.1	15.9	10.9	8.4	8.3	12.0	15.9	19.8	21.5	22.7	(36)	
		MCWBR	10.0	8.9	8.5	7.6	6.8	6.5	6.3	8.0	9.4	10.1	10.3	10.1	(37)	
	5% WB	MCDBR	20.6	19.3	17.1	14.1	9.3	7.4	7.2	10.5	14.4	18.2	19.1	20.3	(38)	
		MCWBR	10.3	10.0	9.0	7.7	6.7	6.3	6.1	7.8	9.5	10.6	10.5	10.7	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.311	0.304	0.293	0.285	0.274	0.267	0.268	0.277	0.299	0.303	0.307	0.302	(40)	
	taud		2.534	2.576	2.599	2.599	2.608	2.623	2.615	2.577	2.493	2.499	2.524	2.560	(41)	
	Ebn at Noon		325	320	312	296	280	274	280	294	304	317	324	329	(42)	
	Edh at Noon		35	32	29	25	22	20	21	25	31	34	35	34	(43)	
(44) All-Sky Solar Radiation	RadAvg		2371	2082	1647	1151	771	608	665	940	1313	1748	2063	2317	(44)	
(45)	RadStd		135	103	87	69	39	50	42	63	90	143	133	125	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+2.41	+1.37	N/A	+4.01	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		+0.86	N/A	N/A	+1.53	N/A	N/A	-22	-218	+301	+101

Nomenclature: See separate page