

STAWELL, Australia

WMO: 948360

Lat: 37.0719S

Lon: 142.7400E

Elev: 773

StdP: 14.29

Time Zone: 10.00 (AUS)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.4	35.6	24.5	19.1	78.3	28.2	22.8	70.4	20.7	52.5	18.7	52.4	2.5	110	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.3	96.8	63.3	92.4	62.5	88.5	61.8	68.3	81.1	66.5	81.7	64.8	81.1	11.5	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.1	95.7	71.3	62.0	85.5	69.9	59.6	78.3	68.6	33.1	79.9	31.6	80.8	30.2	81.2	75.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	18.3	16.5	30.0	105.6	1.5	3.4	29.0	108.0	28.1	110.0	27.2	111.9	26.2	114.4		
(5)			29.6	71.2	1.5	2.3	28.5	72.8	27.6	74.2	26.8	75.4	25.6	77.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.7	69.7	69.3	65.1	58.4	52.3	48.1	47.0	48.3	51.8	56.4	61.8	65.6		
	DBStd	9.86	7.37	6.82	6.70	5.52	4.34	3.41	3.24	3.72	4.80	6.23	7.16	7.24		
	HDD50	321	0	0	0	3	25	76	101	78	29	8	1	0		
	HDD65	3235	31	30	81	210	395	508	557	519	396	281	147	80		
	CDD50	3149	609	541	468	255	95	18	9	24	84	206	356	484		
	CDD65	587	175	151	85	12	0	0	0	0	1	13	52	98		
	CDH74	8194	2456	1813	1051	164	2	0	0	0	14	260	836	1598		
	CDH80	3744	1268	830	423	32	0	0	0	0	1	77	338	775		
(14) Wind	WSAvg	7.7	9.3	9.0	8.4	6.8	6.3	6.3	6.6	7.1	7.3	8.1	8.5	8.9		
(15) Precipitation	PrecAvg	22.2	1.4	1.1	1.3	1.6	2.2	2.4	2.6	2.6	2.5	2.3	1.4	1.0		
	PrecMax	34.6	3.5	7.5	4.6	6.6	5.2	6.6	5.8	5.1	5.6	7.3	3.4	2.9		
	PrecMin	8.8	0.1	0.0	0.0	0.1	0.2	0.3	0.4	0.4	0.6	0.3	0.3	0.0		
	PrecStd	5.7	0.9	1.5	1.2	1.5	1.3	1.7	1.3	1.2	1.4	1.6	0.8	0.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	104.8	99.0	95.7	84.3	71.5	61.4	59.4	66.7	75.8	87.4	94.0	101.3		
		MCWB	65.4	65.9	63.1	59.8	55.0	52.0	51.4	53.7	56.2	59.1	61.9	62.6		
	2%	DB	98.1	93.7	89.4	78.6	66.6	58.1	56.5	61.7	70.1	81.1	88.6	94.4		
		MCWB	64.2	63.8	62.5	58.0	54.4	51.3	49.9	51.0	55.5	56.6	60.5	62.0		
	5%	DB	92.1	89.6	84.6	74.5	63.4	56.3	54.7	58.5	65.5	75.6	83.6	88.7		
		MCWB	62.7	63.4	61.2	56.8	54.0	50.7	49.1	50.2	53.5	55.9	59.9	60.6		
	10%	DB	87.0	85.0	79.7	70.6	60.5	54.6	53.2	55.8	61.8	70.2	78.1	83.2		
		MCWB	61.9	62.4	60.3	55.8	53.0	50.0	48.4	49.1	52.4	54.6	58.5	59.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.9	71.2	67.5	62.5	59.2	55.3	53.7	55.6	60.2	62.9	66.7	69.1		
		MCDB	80.5	84.0	79.4	73.7	62.2	57.0	56.1	61.7	69.1	73.5	82.3	78.8		
	2%	WB	68.2	68.8	65.1	60.6	56.7	53.0	51.7	52.9	57.0	59.9	64.4	65.5		
		MCDB	83.4	80.4	79.5	70.1	62.3	55.9	54.5	59.0	65.5	71.4	78.4	80.3		
	5%	WB	66.2	66.6	63.4	59.0	55.3	51.8	50.3	51.2	54.9	57.7	62.4	63.4		
		MCDB	85.0	80.2	78.5	70.0	61.1	54.9	53.1	56.7	63.7	70.6	75.3	81.2		
	10%	WB	64.1	64.5	61.7	57.3	54.0	50.6	49.2	49.8	53.0	55.8	60.2	61.5		
		MCDB	83.0	80.3	76.7	68.4	59.7	53.7	52.2	54.9	60.7	68.7	74.3	79.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	26.3	24.4	22.3	20.0	15.7	13.0	12.3	14.5	17.4	21.0	23.2	25.2		
		MCDBR	36.1	32.7	31.2	28.2	20.7	15.9	14.5	19.8	24.0	31.8	34.0	36.5		
		MCWBR	10.3	9.6	10.3	11.7	11.0	10.1	9.2	11.1	11.7	12.0	10.7	10.7		
	5% WB	MCDBR	27.5	24.1	24.1	21.4	16.5	12.7	12.0	16.8	20.6	24.0	25.3	26.0		
		MCWBR	10.6	9.3	9.5	10.2	9.7	8.9	8.4	10.2	11.2	11.5	10.0	10.5		
(40) Clear-Sky Solar Irradiance	taub		0.340	0.331	0.315	0.306	0.299	0.290	0.288	0.302	0.324	0.328	0.333	0.327		
	taud		2.486	2.533	2.570	2.575	2.572	2.592	2.598	2.536	2.464	2.466	2.486	2.525		
	Ebn at Noon		315	311	304	288	271	265	272	285	295	308	315	321		
	Edh at Noon		36	33	30	26	23	21	22	26	32	35	36	35		
(44) All-Sky Solar Radiation	RadAvg		2393	2108	1666	1170	784	623	676	956	1331	1770	2092	2337		
	RadStd		133	102	82	68	38	50	42	62	93	140	136	121		

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	+187	+122
(47)	Regional (34 neighbors)	+0.85	N/A	N/A	+1.64	N/A	N/A	-229	+295	+94

Nomenclature: See separate page