

CAPE OTWAY LH, Australia

WMO: 948420

Lat: 38.8551S

Lon: 143.5140E

Elev: 83

StdP: 100.33

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.2	6.9	-0.5	3.7	14.0	0.9	4.1	12.3	16.5	9.9	14.9	10.3	5.0	0	0.673

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.6	30.2	17.5	27.4	16.7	24.6	16.2	19.5	24.9	18.7	23.4	17.9	21.8	6.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.2	20.5	17.3	12.5	19.9	16.6	11.9	19.2	56.2	24.9	53.3	23.6	50.9	21.9	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	12.8	11.6	DB	4.4	37.2	0.7	2.7	3.9	39.2	3.5	40.7	3.1	42.3	2.6	44.3	(4)
(5)			WB	3.2	22.9	0.7	2.4	2.7	24.5	2.2	25.9	1.8	27.3	1.3	29.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.9	17.4	17.9	16.7	14.8	13.0	11.3	10.6	10.9	11.9	13.1	14.3	15.8
	DBStd	3.59	3.23	3.19	3.04	2.60	2.08	1.59	1.53	1.85	2.39	2.99	2.98	3.12
	HDD10.0	31	0	0	0	0	1	5	11	9	4	1	0	0
	HDD18.3	1715	57	39	71	113	166	212	240	231	195	168	128	94
	CDD10.0	1473	229	222	207	144	94	43	29	37	61	97	131	180
	CDD18.3	115	28	28	19	7	1	0	0	0	1	6	9	16
	CDH23.3	872	221	194	138	33	1	0	0	0	4	54	77	148
	CDH26.7	324	94	80	51	7	0	0	0	0	0	13	19	61
Wind	WSAvg	6.3	5.8	5.8	5.8	5.7	6.2	6.2	6.8	6.9	6.9	6.5	6.2	6.3
Precipitation	PrecAvg	954	46	41	58	73	91	100	118	118	95	85	70	56
	PrecMax	1292	123	155	140	190	224	195	205	206	175	170	139	122
	PrecMin	635	7	2	13	15	24	34	45	37	31	8	15	8
	PrecStd	142	24	32	28	41	44	35	42	39	36	39	31	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.1	33.2	31.9	27.2	21.2	17.6	16.3	19.8	23.6	28.5	29.5	33.1
		MCWB	19.2	18.4	17.9	16.3	13.4	12.5	11.4	12.1	14.5	15.1	16.8	17.9
	2%	DB	29.0	29.0	27.2	23.4	19.3	15.7	14.8	17.0	20.6	24.4	25.4	27.6
		MCWB	17.7	17.3	17.2	14.8	12.8	11.7	10.5	11.1	12.8	14.3	15.8	16.3
	5%	DB	25.1	25.0	23.6	20.6	17.7	14.5	13.8	15.2	17.9	21.2	22.1	23.2
		MCWB	17.8	17.7	16.3	14.3	12.9	11.3	10.1	10.3	12.0	13.2	15.3	16.0
	10%	DB	21.3	21.6	20.5	18.3	16.1	13.6	13.0	13.8	15.6	17.6	18.6	19.6
		MCWB	17.2	17.4	16.6	14.3	12.7	11.0	10.0	10.2	11.0	12.7	15.1	15.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.0	20.6	19.6	18.1	15.5	13.8	12.8	13.8	15.4	17.0	18.9	19.5
		MCDB	27.2	26.1	25.0	24.8	17.9	15.2	14.4	18.0	20.4	23.5	24.7	26.5
	2%	WB	19.5	19.4	18.6	16.5	14.5	12.7	11.7	12.2	13.7	15.2	17.2	18.1
		MCDB	25.4	23.8	23.2	19.6	16.9	14.5	13.4	14.9	18.5	21.1	21.9	24.0
	5%	WB	18.4	18.6	17.7	15.7	13.8	12.1	11.1	11.5	12.7	14.2	16.2	16.9
		MCDB	23.3	22.2	21.2	18.4	16.3	13.8	12.8	13.8	16.1	18.9	20.2	21.2
	10%	WB	17.4	17.9	16.9	14.9	13.1	11.4	10.5	10.7	11.8	13.2	15.1	16.0
		MCDB	21.0	20.8	20.0	17.5	15.5	13.3	12.4	13.0	14.8	16.7	18.3	19.3
Mean Daily Temperature Range	5% DB	MDBR	6.2	5.6	5.2	4.9	4.2	3.8	3.9	4.5	5.2	5.9	5.6	5.9
		MCDBR	13.5	11.9	11.2	8.9	6.5	4.7	4.8	6.9	9.3	12.4	12.4	13.1
		MCWBR	5.2	4.7	4.8	4.6	3.8	3.3	3.1	3.8	4.8	5.6	5.6	5.5
	5% WB	MCDBR	10.7	7.7	8.3	6.5	5.1	4.0	3.8	5.5	7.5	9.8	9.8	9.9
		MCWBR	5.0	4.2	4.4	4.2	3.5	3.2	3.2	3.8	4.5	5.2	5.1	5.0
Clear-Sky Solar Irradiance	taub	0.349	0.348	0.334	0.326	0.311	0.309	0.303	0.320	0.337	0.340	0.345	0.342	
	taud	2.531	2.544	2.585	2.583	2.606	2.591	2.610	2.561	2.503	2.509	2.516	2.543	
	Ebn at Noon	982	959	932	875	829	796	829	869	912	956	980	994	
	Edh at Noon	109	103	91	79	67	63	66	80	97	105	110	109	
All-Sky Solar Radiation	RadAvg	6.94	5.98	4.63	3.21	2.14	1.68	1.85	2.67	3.87	5.25	6.16	6.93	
	RadStd	0.45	0.28	0.24	0.18	0.10	0.12	0.12	0.15	0.23	0.37	0.37	0.45	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.46	N/A	N/A	N/A	N/A	+0.62	N/A	N/A	N/A	N/A
(47)	Regional (31 neighbors)	+0.49	N/A	N/A	+0.88	+0.39	N/A	-11	-136	+176	+48

Nomenclature: See separate page