

AIREYS INLET, Australia

WMO: 948460

Lat: 38.458S

Lon: 144.088E

Elev: 95

StdP: 100.19

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	5.8	1.1	4.1	11.8	2.1	4.4	10.0	16.0	12.2	14.0	11.2	5.6	310	0.575

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.2	31.9	18.3	28.4	17.6	25.6	17.2	20.3	26.3	19.4	24.9	18.6	23.4	7.2	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	13.7	21.6	17.9	13.0	20.7	17.1	12.3	20.0	58.6	26.5	55.7	25.0	53.1	23.4	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.0	11.3	9.9	3.2	38.8	1.2	2.6	2.4	40.7	1.6	42.2	0.9	43.7	0.0	45.6		
(5)			2.5	22.4	1.3	1.1	1.5	23.2	0.7	23.8	0.0	24.4	-1.0	25.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.0	18.0	18.3	17.2	14.9	12.8	10.8	10.1	10.5	11.7	13.3	14.8	16.3
	DBStd	3.95	3.40	3.17	3.22	2.83	2.21	1.64	1.57	1.98	2.47	3.14	3.20	3.37
	HDD10.0	54	0	0	0	1	2	9	17	16	7	2	1	0
	HDD18.3	1709	46	33	60	109	173	226	256	243	200	162	117	84
	CDD10.0	1529	247	234	223	149	88	34	20	31	58	104	146	194
	CDD18.3	141	34	33	26	8	1	0	0	0	1	6	12	21
	CDH23.3	1194	296	238	193	51	1	0	0	0	7	77	119	213
CDH26.7	493	139	101	79	12	0	0	0	0	1	22	43	97	
Wind	WSAvg	4.9	4.9	4.7	4.5	4.4	4.9	5.0	5.4	5.4	5.1	4.9	4.8	4.7
Precipitation	PrecAvg	659	41	41	34	50	52	65	69	74	69	63	59	42
	PrecMax	889	139	120	82	174	96	126	125	119	146	121	126	105
	PrecMin	448	5	9	9	12	13	23	28	31	36	18	20	9
	PrecStd	105	33	24	19	34	22	24	23	26	25	31	26	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.4	34.8	34.0	28.2	21.7	17.3	16.5	19.8	24.1	29.6	31.2	35.4
		MCWB	19.5	19.2	18.2	16.2	13.9	13.1	11.6	12.8	14.8	15.8	18.0	18.8
	2%	DB	30.3	29.8	28.3	24.3	19.3	15.4	14.7	16.9	20.5	25.2	26.8	28.9
		MCWB	18.6	18.6	17.7	15.2	13.7	12.2	10.9	11.5	13.5	14.9	16.8	17.3
	5%	DB	26.1	25.7	24.6	21.3	17.6	14.2	13.5	15.1	18.1	21.9	23.1	24.5
		MCWB	18.4	18.3	17.4	14.8	13.1	11.6	10.4	10.9	12.4	14.1	16.0	17.1
	10%	DB	22.8	23.0	21.8	19.1	16.2	13.4	12.7	13.7	16.1	18.7	20.0	21.2
		MCWB	18.1	18.3	16.7	14.5	12.9	11.1	10.0	10.3	11.7	13.3	15.4	16.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	21.3	20.3	17.7	16.3	14.4	12.7	13.7	15.7	17.2	19.6	20.2
		MCDB	28.5	26.9	26.3	23.3	18.5	15.6	14.6	17.9	21.2	24.1	25.9	28.3
	2%	WB	20.3	20.2	19.1	16.7	14.8	13.0	11.7	12.4	14.2	15.8	18.0	18.8
		MCDB	26.8	25.3	24.6	20.4	17.2	14.5	13.5	15.6	19.0	22.4	23.3	25.4
	5%	WB	19.2	19.4	18.2	15.9	13.9	12.1	11.0	11.5	13.1	14.7	16.8	17.7
		MCDB	25.0	23.9	22.4	19.2	16.6	13.8	12.8	14.1	17.0	20.4	21.8	23.4
	10%	WB	18.2	18.6	17.4	15.1	13.1	11.3	10.4	10.7	12.1	13.7	15.7	16.7
		MCDB	22.5	22.3	21.0	18.4	15.6	13.1	12.2	13.1	15.5	18.1	19.5	20.7
Mean Daily Temperature Range	5% DB	MDBR	7.8	7.2	7.0	6.5	5.5	4.8	5.1	5.9	7.1	8.0	7.7	8.1
		MCDBR	15.0	13.4	13.0	10.8	7.7	5.9	6.1	8.0	10.8	14.2	14.2	15.2
		MCWBR	5.5	5.1	5.2	4.6	4.3	3.8	3.8	4.3	5.5	6.0	5.9	5.9
	5% WB	MCDBR	11.4	9.5	9.6	8.1	6.4	5.2	5.4	6.9	9.2	11.6	11.2	12.0
		MCWBR	5.4	4.6	4.6	4.3	4.3	3.8	3.7	4.2	5.2	5.7	5.5	5.6
Clear-Sky Solar Irradiance	taub	0.348	0.348	0.331	0.323	0.311	0.302	0.301	0.313	0.331	0.335	0.343	0.339	
	taud	2.528	2.535	2.585	2.583	2.593	2.604	2.602	2.563	2.509	2.510	2.513	2.546	
	Ebn at Noon	984	959	937	881	831	809	834	878	921	962	982	998	
	Edh at Noon	109	104	91	80	68	63	66	80	97	106	110	109	
All-Sky Solar Radiation	RadAvg	7.01	6.11	4.76	3.32	2.22	1.76	1.96	2.76	3.97	5.33	6.20	6.99	
	RadStd	0.42	0.26	0.27	0.18	0.10	0.13	0.10	0.14	0.23	0.39	0.36	0.44	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	-152	+180	+40
(47) Regional (35 neighbors)		+0.50	N/A	N/A	+0.85	N/A	N/A	-15	-129	+173	+54

Nomenclature: See separate page