

POINT WILSON, Australia

WMO: 948470

Lat: 38.096S

Lon: 144.536E

Elev: 18

StdP: 101.11

Time Zone: 10.00 (AUS)

Period: 94-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.0	6.8	2.0	4.4	11.6	2.8	4.6	10.8	15.8	11.0	14.7	12.2	5.0	290	0.673

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.5	30.1	19.1	27.5	18.6	25.4	18.2	21.1	25.9	20.1	24.9	19.3	23.8	8.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.4	23.1	18.5	13.4	22.1	17.7	12.7	21.5	61.2	26.0	57.7	24.8	55.1	24.1	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.7	13.5	12.2	DB	4.4	35.2	0.8	2.2	3.8	36.7	3.3	38.0	2.9	39.2	2.3	40.8	(4)
(5)			WB	3.6	22.8	0.7	2.8	3.1	24.9	2.7	26.5	2.3	28.1	1.8	30.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	19.2	19.6	18.1	15.4	13.4	11.4	10.4	11.1	12.6	14.0	15.9	17.3
	DBStd	3.99	3.03	3.20	2.69	2.41	2.05	1.85	1.58	1.90	2.29	2.75	3.06	3.25
	HDD10.0	33	0	0	0	0	1	7	14	9	2	1	0	0
	HDD18.3	1464	24	18	37	94	153	209	247	224	172	139	87	59
	CDD10.0	1798	284	269	251	163	106	47	26	43	81	124	178	228
	CDD18.3	187	50	53	29	6	1	0	0	0	1	4	14	29
	CDH23.3	1005	273	280	125	23	0	0	0	0	3	30	82	190
	CDH26.7	313	94	86	34	3	0	0	0	0	8	23	64	
Wind	WSAvg	6.4	7.2	6.5	6.4	5.8	5.7	6.0	6.1	6.2	6.7	7.0	7.0	6.8
Precipitation	PrecAvg	531	39	41	35	44	42	49	46	46	50	49	51	41
	PrecMax	736	112	137	104	141	98	98	94	83	95	109	121	97
	PrecMin	316	1	5	13	8	14	21	14	19	15	6	15	5
	PrecStd	113	28	31	19	29	21	20	21	17	23	28	29	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.5	32.7	30.9	26.5	20.6	17.6	16.1	18.6	22.7	26.6	29.7	32.2
		MCWB	20.3	20.0	19.4	15.7	13.4	13.4	11.3	12.5	14.1	15.5	19.3	18.0
	2%	DB	29.1	29.2	26.5	22.6	18.7	16.1	14.5	16.6	19.6	23.1	25.5	27.9
		MCWB	19.4	19.5	18.2	15.5	13.7	13.1	11.0	12.0	14.0	15.2	17.5	17.7
	5%	DB	26.1	26.8	24.0	20.5	17.2	15.1	13.7	15.2	17.9	20.4	22.5	24.9
		MCWB	18.9	19.4	18.1	15.5	13.2	12.6	10.7	11.4	13.3	14.9	17.1	17.7
	10%	DB	23.7	24.4	21.7	18.7	16.3	14.2	12.9	14.1	16.4	18.4	20.4	21.9
		MCWB	18.7	18.9	17.2	15.0	13.0	11.8	10.4	11.0	12.6	14.1	16.5	16.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.6	22.4	20.5	17.4	15.2	14.7	13.3	14.2	16.2	18.9	22.3	19.7
		MCDB	27.0	27.1	26.5	21.7	17.6	16.1	14.8	16.8	18.9	23.3	27.1	26.2
	2%	WB	21.0	21.2	19.4	16.7	14.5	13.9	12.2	13.0	15.1	16.9	19.8	18.9
		MCDB	26.0	26.2	24.0	20.5	16.9	15.4	13.5	15.3	17.9	20.1	22.4	25.2
	5%	WB	20.0	20.2	18.5	16.0	13.9	13.1	11.5	12.1	14.2	15.5	18.1	18.1
		MCDB	24.9	24.9	22.5	19.6	16.3	14.9	13.0	14.4	16.9	19.0	20.8	23.5
	10%	WB	18.9	19.4	17.7	15.3	13.4	12.0	10.6	11.2	13.2	14.3	16.6	17.3
		MCDB	23.1	23.9	21.4	18.7	15.8	14.0	12.4	13.6	16.1	17.9	20.2	22.0
Mean Daily Temperature Range	5% DB	MDBR	5.7	5.5	5.2	4.9	4.4	4.0	4.0	4.7	5.3	5.8	5.4	5.9
		MCDBR	11.1	10.6	10.1	8.2	5.6	4.9	5.0	6.4	8.1	10.2	10.1	12.2
		MCWBR	4.1	3.8	3.9	3.7	3.0	2.8	2.9	3.1	4.0	4.2	4.5	4.1
	5% WB	MCDBR	9.0	8.4	8.0	6.9	4.7	4.2	4.1	6.0	6.6	7.6	8.0	9.7
		MCWBR	4.5	3.8	3.7	3.7	2.9	2.7	2.9	3.3	3.9	3.9	4.4	4.2
Clear-Sky Solar Irradiance	taub	0.352	0.356	0.334	0.327	0.314	0.302	0.303	0.313	0.334	0.340	0.347	0.344	
	taud	2.506	2.503	2.566	2.558	2.576	2.599	2.584	2.550	2.485	2.483	2.491	2.517	
	Ebn at Noon	980	952	934	877	829	812	833	880	918	958	978	992	
	Edh at Noon	112	108	93	82	70	63	68	81	99	109	113	112	
All-Sky Solar Radiation	RadAvg	7.10	6.21	4.90	3.42	2.29	1.79	2.01	2.82	4.04	5.39	6.27	7.05	
	RadStd	0.43	0.29	0.28	0.18	0.11	0.13	0.11	0.16	0.26	0.40	0.36	0.40	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (37 neighbors)	+0.50	N/A	N/A	+0.87	N/A	N/A	-17	-130	+175	+58

Nomenclature: See separate page