

KING ISLAND AP, Australia

WMO: 948500

Lat: 39.880S

Lon: 143.883E

Elev: 125

StdP: 14.63

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.6	41.6	33.4	28.1	47.0	35.0	29.9	47.4	38.7	53.2	35.0	52.7	4.3	120	0.703

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.2	79.6	65.1	74.6	64.0	71.4	62.9	67.1	74.3	65.6	71.8	64.2	69.5	14.3	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	92.2	68.7	63.5	87.9	67.6	62.1	83.8	66.4	31.6	74.4	30.5	72.1	29.5	69.5	77.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 32.5	29.3	26.5	DB	34.8	91.7	1.6	4.3	33.6	94.8	32.7	97.4	31.8	99.8	30.6	103.0	(4)
(5)			WB	34.1	71.1	1.6	2.7	32.9	73.0	32.0	74.5	31.0	76.0	29.8	78.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.8	61.4	62.3	60.4	57.1	54.2	51.7	50.8	50.9	52.3	53.9	56.1	58.6
	DBStd	5.60	4.95	4.72	4.78	4.05	3.39	3.04	2.80	3.01	3.35	4.15	4.33	4.43
	HDD50	92	0	0	0	1	5	17	24	24	12	7	2	0
	HDD65	3454	139	102	160	239	334	398	440	436	382	346	269	209
	CDD50	2203	352	344	324	215	136	69	49	54	81	127	186	266
	CDD65	86	26	26	18	2	0	0	0	0	0	1	3	10
	CDH74	500	163	120	94	13	0	0	0	0	0	11	26	73
	CDH80	153	59	37	29	2	0	0	0	0	0	1	4	21
Wind	WSAvg	14.1	13.7	14.1	13.3	12.7	13.7	13.6	15.1	15.0	15.0	14.3	13.9	14.3
Precipitation	PrecAvg	35.0	1.3	1.4	2.2	2.6	3.9	3.9	5.1	4.5	3.3	2.9	2.4	1.8
	PrecMax	50.6	3.8	4.1	6.4	6.6	8.7	6.5	9.5	7.6	7.2	6.3	5.9	5.1
	PrecMin	21.9	0.3	0.2	0.4	0.7	1.2	1.3	1.5	1.0	1.0	0.8	0.6	0.3
	PrecStd	6.7	0.7	1.0	1.3	1.5	1.8	1.3	2.0	1.7	1.4	1.5	1.3	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.3	85.9	83.0	75.5	66.4	61.1	59.3	62.9	67.4	74.9	77.7	82.7
		MCWB	66.8	67.5	63.7	60.8	58.3	55.7	54.0	54.4	57.5	60.1	63.5	64.1
	2%	DB	78.0	76.7	74.9	69.4	63.4	59.1	57.6	59.6	63.0	68.1	70.6	73.8
		MCWB	65.8	65.3	64.2	60.1	57.2	54.8	52.8	53.4	55.5	57.7	61.8	63.7
	5%	DB	72.5	72.6	70.7	66.0	61.4	57.9	56.5	57.6	60.1	63.4	66.4	69.0
		MCWB	63.9	64.6	62.9	59.3	56.9	53.9	52.1	52.6	54.3	57.0	60.3	61.4
	10%	DB	69.1	69.6	67.5	63.7	59.9	56.8	55.6	56.1	57.9	60.2	63.2	65.8
		MCWB	62.3	62.9	61.3	58.5	56.0	53.0	51.5	51.7	53.1	55.3	58.3	59.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.3	69.2	67.3	63.6	60.3	57.9	55.8	56.4	59.4	62.0	65.7	66.9
		MCDB	78.8	77.7	74.2	68.0	62.6	59.2	57.8	60.2	64.6	70.9	71.4	76.4
	2%	WB	66.9	67.1	65.5	62.0	58.9	55.9	54.3	54.7	56.8	59.3	62.9	64.6
		MCDB	74.7	73.5	71.6	65.6	61.5	57.8	56.3	57.8	61.0	65.0	68.6	71.6
	5%	WB	64.9	65.5	63.9	60.8	57.7	54.8	53.2	53.5	55.3	57.5	60.9	62.4
		MCDB	71.0	70.8	69.2	64.7	60.4	57.0	55.4	56.6	58.7	62.2	65.2	67.6
	10%	WB	63.2	64.2	62.5	59.2	56.6	53.7	52.3	52.4	54.0	55.9	59.0	60.7
		MCDB	68.4	68.3	67.0	63.3	59.4	56.3	54.9	55.5	57.2	59.9	62.6	64.9
Mean Daily Temperature Range	5% DB	MDBR	14.1	13.2	12.8	11.7	9.6	9.0	8.5	9.1	10.2	11.6	11.9	12.9
		MCDBR	20.4	18.2	18.1	15.3	11.6	9.9	8.8	10.8	13.4	17.6	17.5	19.8
		MCWBR	10.2	9.3	8.9	8.7	8.0	7.4	6.6	7.1	8.3	9.7	10.2	10.9
	5% WB	MCDBR	17.8	15.6	16.1	13.8	10.3	8.9	7.4	10.0	11.6	15.2	15.7	17.6
		MCWBR	9.6	8.8	8.6	8.7	8.0	7.4	6.4	7.5	8.1	9.3	9.5	10.3
Clear-Sky Solar Irradiance	taub	0.355	0.347	0.335	0.328	0.316	0.315	0.312	0.326	0.345	0.341	0.344	0.343	
	taud	2.514	2.555	2.588	2.589	2.598	2.581	2.594	2.557	2.493	2.519	2.528	2.547	
	Ebn at Noon	309	304	294	275	258	247	257	272	286	303	311	315	
	Edh at Noon	35	32	29	25	21	20	21	25	31	33	34	34	
All-Sky Solar Radiation	RadAvg	2164	1866	1421	980	643	502	553	822	1207	1669	1964	2188	
	RadStd	143	88	68	47	30	32	33	54	68	93	111	125	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	+0.81	N/A	N/A	+1.31	+0.85	+0.95	N/A	-250	+265	+38

Nomenclature: See separate page