

KING ISLAND AP, Australia

WMO: 948500

Lat: 39.880S

Lon: 143.883E

Elev: 38

StdP: 100.87

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.2	5.3	0.8	4.0	8.3	1.7	4.3	8.6	17.3	11.8	15.6	11.5	1.9	120	0.703

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.3	26.4	18.4	23.7	17.8	21.9	17.1	19.5	23.5	18.7	22.1	17.9	20.8	6.4	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.2	20.4	17.5	12.6	19.8	16.7	12.0	19.1	55.7	23.6	53.1	22.3	50.7	20.8	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.5	13.1	11.9	DB	1.5	33.2	0.9	2.4	0.9	34.9	0.4	36.3	-0.1	37.7	-0.8	39.4	(4)
(5)			WB	1.2	21.7	0.9	1.5	0.5	22.8	0.0	23.6	-0.5	24.5	-1.2	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.2	16.3	16.8	15.8	14.0	12.3	11.0	10.5	10.5	11.3	12.2	13.4	14.8
	DBStd	3.11	2.75	2.62	2.65	2.25	1.88	1.69	1.56	1.67	1.86	2.31	2.41	2.46
	HDD10.0	51	0	0	0	1	3	9	13	13	7	4	1	0
	HDD18.3	1919	77	57	89	133	186	221	244	242	212	192	149	116
	CDD10.0	1224	196	191	180	119	76	38	27	30	45	71	103	148
	CDD18.3	48	14	14	10	1	0	0	0	0	0	1	2	6
	CDH23.3	278	91	67	52	7	0	0	0	0	0	6	14	41
CDH26.7	85	33	21	16	1	0	0	0	0	0	1	2	12	
Wind	WSAvg	6.3	6.1	6.3	6.0	5.7	6.1	6.1	6.7	6.7	6.7	6.4	6.2	6.4
Precipitation	PrecAvg	888	34	35	56	67	99	99	130	114	84	73	62	46
	PrecMax	1286	96	105	162	168	220	166	242	193	182	161	149	130
	PrecMin	556	8	6	10	18	30	32	37	26	26	21	14	8
	PrecStd	170	18	26	34	38	46	33	51	42	35	38	34	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.7	29.9	28.3	24.2	19.1	16.2	15.2	17.2	19.7	23.8	25.4	28.2
		MCWB	19.4	19.7	17.6	16.0	14.6	13.2	12.2	12.4	14.2	15.6	17.5	17.9
	2%	DB	25.6	24.9	23.9	20.8	17.4	15.1	14.2	15.3	17.2	20.1	21.4	23.2
		MCWB	18.8	18.5	17.9	15.6	14.0	12.7	11.6	11.9	13.0	14.3	16.6	17.6
	5%	DB	22.5	22.6	21.5	18.9	16.3	14.4	13.6	14.2	15.6	17.5	19.1	20.6
		MCWB	17.7	18.1	17.2	15.2	13.8	12.1	11.2	11.5	12.4	13.9	15.7	16.4
	10%	DB	20.6	20.9	19.7	17.6	15.5	13.8	13.1	13.4	14.4	15.7	17.3	18.8
		MCWB	16.8	17.2	16.3	14.7	13.3	11.7	10.8	11.0	11.7	12.9	14.6	15.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	20.7	19.6	17.5	15.7	14.4	13.2	13.6	15.2	16.7	18.7	19.4
		MCDB	26.0	25.4	23.4	20.0	17.0	15.1	14.3	15.6	18.1	21.6	21.9	24.7
	2%	WB	19.4	19.5	18.6	16.7	15.0	13.3	12.4	12.6	13.8	15.1	17.2	18.1
		MCDB	23.7	23.1	22.0	18.7	16.4	14.3	13.5	14.3	16.1	18.3	20.3	22.0
	5%	WB	18.3	18.6	17.7	16.0	14.3	12.7	11.8	11.9	13.0	14.2	16.1	16.9
		MCDB	21.7	21.5	20.7	18.2	15.8	13.9	13.0	13.7	14.8	16.8	18.5	19.8
	10%	WB	17.4	17.9	16.9	15.1	13.7	12.1	11.3	11.3	12.2	13.3	15.0	16.0
		MCDB	20.2	20.2	19.5	17.4	15.2	13.5	12.7	13.0	14.0	15.5	17.0	18.3
Mean Daily Temperature Range	5% DB	MDBR	7.8	7.3	7.1	6.5	5.3	5.0	4.7	5.1	5.7	6.5	6.6	7.2
		MCDBR	11.4	10.1	10.0	8.5	6.5	5.5	4.9	6.0	7.4	9.8	9.7	11.0
		MCWBR	5.7	5.1	5.0	4.9	4.4	4.1	3.7	4.0	4.6	5.4	5.7	6.1
	5% WB	MCDBR	9.9	8.7	8.9	7.6	5.7	4.9	4.1	5.6	6.5	8.5	8.7	9.8
		MCWBR	5.3	4.9	4.8	4.8	4.4	4.1	3.6	4.2	4.5	5.2	5.3	5.7
Clear-Sky Solar Irradiance	taub	0.355	0.347	0.335	0.328	0.316	0.315	0.312	0.326	0.345	0.341	0.344	0.343	
	taud	2.514	2.555	2.588	2.589	2.598	2.581	2.594	2.557	2.493	2.519	2.528	2.547	
	Ebn at Noon	975	958	928	868	814	779	809	857	901	954	979	992	
	Edh at Noon	111	101	90	78	67	62	66	79	97	104	108	108	
All-Sky Solar Radiation	RadAvg	6.82	5.88	4.48	3.09	2.03	1.58	1.74	2.59	3.81	5.26	6.19	6.90	
	RadStd	0.45	0.28	0.21	0.15	0.10	0.10	0.10	0.17	0.21	0.29	0.35	0.40	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		+0.45	N/A	N/A	+0.73	+0.47	+0.53	N/A	-139	+147	+21

Nomenclature: See separate page