

KING ISLAND CURRIE, Australia

WMO: 948510

Lat: 39.933S

Lon: 143.850E

Elev: 79

StdP: 14.65

Time Zone: 10.00 (AUS)

Period: 82-95

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	43.4	44.9	35.0	29.9	48.2	36.7	32.0	48.8	44.4	54.0	40.2	53.1	6.5	50	0.681

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.8	79.1	66.9	73.8	64.8	70.6	63.4	67.8	75.8	66.0	71.8	64.5	69.1	14.4	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.1	93.1	70.1	63.8	88.7	68.5	62.5	84.8	67.5	32.2	76.2	30.8	71.8	29.7	69.1	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
39.4	33.5	29.7		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	61.5	62.5	61.5	58.9	55.5	52.1	51.2	51.8	52.5	54.7	57.5	59.7	(6)
(7)		DBStd	5.31	3.73	4.47	4.18	4.00	2.87	2.70	2.59	2.67	2.70	3.36	3.83	4.11	(7)
(8)		HDD50	49	0	0	0	0	1	11	18	11	6	2	0	0	(8)
(9)		HDD65	3154	123	94	128	189	295	388	429	408	375	319	230	176	(9)
(10)		CDD50	2454	357	351	356	266	171	74	55	68	81	149	225	301	(10)
(11)		CDD65	83	16	25	19	5	0	0	0	0	0	1	5	12	(11)
(12)		CDH74	379	77	133	55	11	0	0	0	0	1	3	25	74	(12)
(13)		CDH80	106	26	40	10	1	0	0	0	0	0	0	3	26	(13)
(14)	Wind	WSAvg	14.5	15.1	14.5	13.6	12.9	12.2	14.3	14.4	16.4	14.4	15.7	15.2	15.0	(14)
(15)	Precipitation	PrecAvg	35.0	1.3	1.4	2.2	2.6	3.9	3.9	5.1	4.5	3.3	2.9	2.4	1.8	(15)
(16)		PrecMax	50.6	3.8	4.1	6.4	6.6	8.7	6.5	9.5	7.6	7.2	6.3	5.9	5.1	(16)
(17)		PrecMin	21.9	0.3	0.2	0.4	0.7	1.2	1.3	1.5	1.0	1.0	0.8	0.6	0.3	(17)
(18)		PrecStd	6.7	0.7	1.0	1.3	1.5	1.8	1.3	2.0	1.7	1.4	1.5	1.3	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.4	85.9	81.0	75.1	65.9	60.4	59.4	61.6	66.8	71.1	79.8	83.3	(19)
(20)			MCWB	70.0	67.8	65.6	64.0	59.6	55.7	54.6	55.4	58.4	60.2	65.9	67.4	(20)
(21)		2%	DB	75.3	78.7	73.7	70.0	62.9	58.5	58.1	59.1	61.7	65.6	71.6	72.9	(21)
(22)			MCWB	67.3	67.4	64.6	62.0	58.5	55.0	53.7	54.1	55.7	58.3	62.0	64.8	(22)
(23)		5%	DB	70.4	72.3	70.4	66.9	61.2	57.5	56.5	57.5	59.0	62.0	66.8	68.5	(23)
(24)			MCWB	64.1	64.5	63.7	61.2	57.4	54.3	52.7	53.3	54.7	56.8	60.6	62.9	(24)
(25)		10%	DB	67.5	68.9	67.5	64.4	59.9	56.5	55.4	56.1	57.2	59.8	63.4	65.6	(25)
(26)			MCWB	62.2	62.9	62.6	60.2	56.6	53.4	52.1	52.5	53.3	55.3	58.6	60.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.5	70.9	68.2	66.0	61.1	57.3	56.3	56.3	59.0	61.8	66.4	68.2	(27)
(28)			MCD B	81.7	81.3	75.4	72.2	64.0	58.9	58.4	59.8	65.4	68.3	75.1	78.1	(28)
(29)		2%	WB	67.2	67.7	66.0	63.6	59.3	56.1	54.6	55.1	56.5	59.0	63.2	65.6	(29)
(30)			MCD B	73.4	76.4	71.0	67.9	61.9	58.0	57.0	57.9	60.4	63.5	70.1	72.1	(30)
(31)		5%	WB	65.0	65.7	64.5	61.9	58.3	55.1	53.5	54.1	55.1	57.4	60.8	63.3	(31)
(32)			MCD B	69.4	71.0	68.8	65.5	60.7	57.1	55.8	56.8	58.2	61.2	65.8	68.0	(32)
(33)		10%	WB	63.0	63.9	63.2	60.5	57.3	53.8	52.6	53.0	53.9	56.1	59.2	61.4	(33)
(34)			MCD B	66.8	67.9	67.2	63.9	59.5	55.9	55.0	55.6	56.7	59.5	63.2	65.0	(34)
(35)	Mean Daily Temperature Range		MDBR	10.0	10.8	9.1	8.3	6.4	5.7	6.1	6.3	8.1	8.6	9.7	9.5	(35)
(36)		5% DB	MCD BR	17.1	17.9	14.6	12.3	8.6	7.1	6.8	7.8	12.1	13.5	15.8	15.5	(36)
(37)			MCWBR	10.2	7.8	7.3	6.2	5.6	5.4	5.5	5.4	8.4	8.2	9.1	8.6	(37)
(38)		5% WB	MCD BR	15.4	15.2	12.7	10.8	7.1	6.1	5.9	7.0	11.1	12.1	14.0	14.6	(38)
(39)			MCWBR	9.9	7.8	7.3	6.7	5.7	5.6	5.7	5.3	8.5	8.5	8.7	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.354	0.347	0.336	0.328	0.317	0.316	0.314	0.326	0.346	0.342	0.345	0.343	(40)	
(41)		taud	2.516	2.553	2.584	2.589	2.596	2.579	2.589	2.556	2.490	2.514	2.526	2.545	(41)	
(42)		Ebn at Noon	309	304	294	275	258	246	256	272	285	302	311	315	(42)	
(43)		Edh at Noon	35	32	29	25	21	20	21	25	31	33	34	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2162	1864	1417	978	640	500	551	820	1205	1666	1964	2187	(44)	
(45)		RadStd	143	89	68	47	30	32	33	54	68	92	112	126	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)		+0.70	N/A	N/A	+1.30	+0.83	+0.92	N/A	-212	+232	+29

Nomenclature: See separate page