

BENDIGO, AustraliaWMO: **948550**Lat: **36.7394S**Lon: **144.3267E**Elev: **209**StdP: **98.84**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.6	0.5	-3.6	2.9	19.3	-2.0	3.3	14.8	9.2	11.8	8.4	11.1	0.7	150	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.9	36.5	18.4	34.0	17.9	31.9	17.4	21.1	28.3	19.9	28.8	19.0	27.9	5.3	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.3	22.8	17.6	12.9	22.0	16.1	11.7	21.5	62.0	27.6	58.0	28.9	54.8	28.0	33.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.1	8.2	7.4	-2.8	40.5	1.0	1.9	-3.6	41.9	-4.2	43.0	-4.7	44.1	-5.5	45.4		
(5)			-2.5	23.1	1.3	2.5	-3.4	24.9	-4.2	26.4	-5.0	27.8	-5.9	29.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	22.0	21.7	18.8	14.6	11.0	8.5	7.7	8.4	10.6	13.7	17.3	19.6
	DBStd	6.04	4.19	3.89	3.81	3.18	2.52	2.16	2.00	2.20	2.78	3.50	4.06	4.06
	HDD10.0	240	0	0	0	2	18	54	77	60	24	4	1	0
	HDD18.3	1827	12	12	40	118	228	294	331	308	233	152	67	33
	CDD10.0	1862	372	328	273	140	48	10	4	11	41	118	221	296
	CDD18.3	408	125	107	55	6	0	0	0	0	1	7	37	71
	CDH23.3	5320	1644	1233	617	83	1	0	0	0	12	160	546	1023
CDH26.7	2422	852	579	234	13	0	0	0	0	2	48	219	474	
Wind	WSAvg	3.6	4.4	4.1	3.8	3.2	2.9	2.8	2.9	3.1	3.5	3.9	4.1	4.3
Precipitation	PrecAvg	582	35	27	35	47	63	54	62	69	61	53	36	40
	PrecMax	1016	116	209	103	124	147	157	122	139	151	207	100	104
	PrecMin	210	1	0	2	4	2	9	12	10	15	4	5	1
	PrecStd	162	31	43	28	34	40	38	28	32	35	44	25	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.7	38.3	35.2	28.5	21.6	16.6	15.6	19.2	24.9	31.4	35.1	38.3
		MCWB	18.9	19.1	18.2	15.8	13.6	11.4	10.9	12.6	13.2	15.1	16.8	17.9
	2%	DB	37.1	34.8	31.7	25.6	19.2	15.0	14.0	16.7	21.4	27.5	31.9	34.7
		MCWB	18.8	18.5	17.4	14.9	13.0	11.0	10.1	11.0	13.1	14.3	16.5	17.2
	5%	DB	34.2	32.5	29.1	23.6	17.5	13.8	12.9	15.0	18.8	24.5	29.1	31.8
		MCWB	18.1	18.2	16.9	14.3	12.3	10.4	9.6	10.3	12.2	13.8	15.8	16.6
	10%	DB	31.4	30.3	26.7	21.6	16.0	12.8	11.9	13.6	16.8	21.9	26.4	29.1
		MCWB	17.6	17.6	16.1	13.7	11.8	9.8	9.1	9.5	11.4	12.9	15.2	16.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	22.8	20.6	17.4	15.6	13.4	12.4	13.3	15.9	17.6	20.1	21.2
		MCDB	28.6	31.6	27.9	23.6	18.1	14.5	13.6	17.1	20.7	24.4	27.6	26.1
	2%	WB	21.1	21.1	19.3	16.3	14.2	11.8	11.0	12.0	14.2	16.1	18.5	19.4
		MCDB	29.3	27.8	26.9	21.4	16.9	13.7	12.9	15.5	19.0	22.2	25.6	27.1
	5%	WB	19.9	19.8	18.3	15.4	13.1	11.1	10.2	10.9	13.0	14.9	17.3	18.2
		MCDB	30.3	28.3	25.9	21.2	16.3	13.0	12.1	14.2	17.8	21.6	25.0	27.4
	10%	WB	18.8	18.9	17.2	14.4	12.3	10.3	9.5	9.9	11.8	13.7	16.3	17.2
		MCDB	28.9	27.7	24.6	20.6	15.4	12.2	11.4	13.0	16.1	20.8	24.1	27.0
Mean Daily Temperature Range	5% DB	MDBR	14.9	14.1	13.0	12.3	10.2	8.7	8.6	10.2	11.6	13.3	13.9	14.9
		MCDBR	19.1	17.2	16.4	15.3	12.4	10.0	10.1	12.8	15.2	18.2	18.4	19.1
		MCWBR	5.8	5.4	5.8	6.5	6.8	6.2	6.4	7.5	7.8	7.6	6.3	6.1
	5% WB	MCDBR	14.9	13.9	12.9	12.0	9.9	7.9	8.5	11.1	12.7	14.0	14.0	14.3
		MCWBR	5.9	5.5	5.5	5.8	6.0	5.5	5.8	7.0	7.2	7.0	5.8	6.1
Clear-Sky Solar Irradiance	taub	0.337	0.334	0.317	0.307	0.296	0.289	0.288	0.296	0.319	0.327	0.338	0.329	
	taud	2.503	2.525	2.563	2.563	2.573	2.586	2.585	2.545	2.471	2.465	2.473	2.518	
	Ebn at Noon	997	978	956	906	859	838	860	905	938	973	990	1010	
	Edh at Noon	113	106	94	83	71	65	69	82	101	111	116	112	
All-Sky Solar Radiation	RadAvg	7.65	6.77	5.46	3.88	2.63	2.02	2.20	3.13	4.41	5.86	6.81	7.60	
	RadStd	0.41	0.34	0.27	0.19	0.15	0.19	0.12	0.22	0.33	0.44	0.37	0.38	